



Rita Bright Community Center Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005534	4/4/2024	4/4/2025	1	Cooler	In hallway adjacent to main entrance	WF-04042024-005534	4/23/2024	FT-FY24-04082024-005534-A	<1	FT-FY24-04082024-005534-B	<1
WS- 005537	12/20/2023	12/20/2024	1	Food Prep Sink	In kitchen	WF-12202023-005537	4/23/2024	FT-FY24-04082024-005537-A	<1	FT-FY24-04082024-005537-B	<1