



Rita Bright CC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005534	5/2/2018	5/2/2019	1	Cooler	In hallway adjacent to main entrance	WF-05022018-005534	2/4/2019	FT-FY19-012019-005534-A	<1	FT-FY19-012019-005534-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005537	5/2/2018	5/2/2019	1	Food Prep Sink	In kitchen	WF-05022018-005537	2/4/2019	FT-FY19-012019-005537-A	<1	FT-FY19-012019-005537-B	<1