



Rita Bright CC Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005534	4/24/2021	4/24/2022	1	Cooler	In hallway adjacent to main entrance	WF-04242021-005534	2/3/2022	FT-FY22-01102022-005534-A	<1	FT-FY22-01102022-005534-B	1.0