



Rita Bright CC Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005534	5/3/2019	5/3/2020	1	Cooler	In hallway adjacent to main entrance	WF-05032019-005534	1/27/2020	FT-FY20-012020-005534-A	<1	FT-FY20-012020-005534-B	<1
WS- 005537	5/3/2019	5/3/2020	1	Food Prep Sink	In kitchen	WF-05032019-005537	1/27/2020	FT-FY20-012020-005537-A	<1	FT-FY20-012020-005537-B	<1