



Rita Bright Recreation Center Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005534	4/19/2022	4/19/2023	1	Cooler	In hallway adjacent to main entrance	WF-04192022-005534	1/26/2023	FT-FY23-01092023-005534-A	<1	FT-FY23-01092023-005534-B	<1
WS- 005537	2/17/2022	2/17/2023	1	Food Prep Sink	In kitchen	WF-02172022-005537	1/26/2023	FT-FY23-01092023-005537-A	<1	FT-FY23-01092023-005537-B	<1