



RIVER TERRACE LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004661	12/11/2016	1	Break Room	In break room 102E	FT-102016-004661-A	< 1	FT-102016-004661-B	< 1
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004662	12/12/2016	1	Break Room	In break room 102G	FT-102016-004662-A	< 1	FT-102016-004662-B	< 1
3	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004664	12/12/2016	1	Combo Faucet	In classroom 110	FT-122016-004664-A	< 1	FT-122016-004664-B	< 1
4	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004666	12/12/2016	1	Combo Faucet	In classroom 112 Mid	FT-122016-004666-A	< 1	FT-122016-004666-B	< 1
5	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004668	12/12/2016	1	Combo Faucet	In classroom 114 Mid	FT-122016-004668-A	< 1	FT-122016-004668-B	< 1
6	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004672	12/12/2016	1	Combo Faucet	In classroom 118	FT-122016-004672-A	< 1	FT-122016-004672-B	< 1
7	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004674	12/12/2016	1	Combo Faucet	In classroom 120 Mid	FT-122016-004674-A	< 1	FT-122016-004674-B	< 1
8	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004676	12/12/2016	1	Combo Faucet	In classroom 122	FT-122016-004676-A	< 1	FT-122016-004676-B	< 1
9	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004680	12/12/2016	1	Break Room	In break room 132 Mid	FT-102016-004680-A	< 1	FT-102016-004680-B	< 1
10	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004682	12/12/2016	1	Combo Faucet	In classroom 124	FT-122016-004682-A	< 1	FT-122016-004682-B	< 1
11	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004684	12/12/2016	1	Combo Faucet	In classroom 126	FT-122016-004684-A	< 1	FT-122016-004684-B	< 1
12	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004689	12/12/2016	1	Combo Faucet	In classroom 136 Mid	FT-122016-004689-A	< 1	FT-122016-004689-B	< 1
13	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004691	12/12/2016	1	Combo Faucet	In classroom 138 Mid	FT-122016-004691-A	< 1	FT-122016-004691-B	< 1
14	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004703	12/12/2016	1	Break Room	In break room 121B	FT-102016-004703-A	< 1	FT-102016-004703-B	< 1
15	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004704	12/12/2016	1	Combo Faucet	In classroom 117	FT-122016-004704-A	< 1	FT-122016-004704-B	< 1
16	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004706	12/12/2016	1	Combo Faucet	In classroom 113	FT-122016-004706-A	< 1	FT-122016-004706-B	< 1
17	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004708	12/12/2016	1	Combo Faucet	In classroom 111	FT-122016-004708-A	< 1	FT-122016-004708-B	< 1
18	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004710	12/12/2016	1	Combo Faucet	In classroom 109	FT-122016-004710-A	< 1	FT-122016-004710-B	< 1
19	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004712	12/12/2016	1	Combo Faucet	In classroom 107	FT-122016-004712-A	< 1	FT-122016-004712-B	< 1
20	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004714	12/12/2016	1	Combo Faucet	In classroom 115	FT-122016-004714-A	< 1	FT-122016-004714-B	< 1
21	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004717	12/12/2016	1	Combo Faucet	In classroom 142	FT-122016-004717-A	< 1	FT-122016-004717-B	< 1
22	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004718	12/12/2016	1	Combo Faucet	In classroom 144	FT-122016-004718-A	< 1	FT-122016-004718-B	< 1
23	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004720	12/12/2016	1	Combo Faucet	In classroom 146	FT-122016-004720-A	< 1	FT-122016-004720-B	< 1
24	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004728	12/12/2016	1	Combo Faucet	In classroom 104 Right	FT-122016-004728-A	< 1	FT-122016-004728-B	< 1
25	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004730	12/12/2016	1	Combo Faucet	entry door	FT-122016-004730-A	< 1	FT-122016-004730-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004663	12/12/2016	1	Combo Faucet	In classroom 106C	FT-122016-004663-A	1.3	FT-122016-004663-B	< 1
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004670	12/12/2016	1	Combo Faucet	In classroom 116 Mid	FT-122016-004670-A	1.7	FT-122016-004670-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004663	1/25/2017	1	Combo Faucet	In classroom 106C	FT-122016-004663-A	3.5	FT-122016-004663-B	< 1
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004670	1/25/2017	1	Combo Faucet	In classroom 116 Mid	FT-122016-004670-A	3.3	FT-122016-004670-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation											
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004663	3/30/2017	1	Combo Faucet	In classroom 106C		FT-122016-004663-A	4.3	FT-122016-004663-B	< 1
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004670	3/30/2017	1	Combo Faucet	In classroom 116	Mid	FT-122016-004670-A	3.5	FT-122016-004670-B	< 1

Filter Re-Test (Post Consultation; After Dual Supply Faucet Installation)

Less than 5 ppb - Devices Returned to Service											
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004663	8/11/2017	1	Combo Faucet	In classroom 106C		FT-122016-004663-A	< 1	FT-122016-004663-B	< 1
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	WS- 004670	8/11/2017	1	Combo Faucet	In classroom 116	Mid	FT-122016-004670-A	< 1	FT-122016-004670-B	< 1