



River Terrace Education Campus Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004652	2/20/2023	2/20/2024	1	Cooler	In pool room 106 High Left	WF-02202023-004652	1/22/2024	FT-FY24-11272023-004652-A	<1	FT-FY24-11272023-004652-B	<1
WS- 004653	2/20/2023	2/20/2024	1	Cooler	In pool room 106 Low Right	WF-02202023-004653	1/22/2024	FT-FY24-11272023-004653-A	<1	FT-FY24-11272023-004653-B	<1
WS- 004654	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 104 High Left	WF-02202023-004654	1/22/2024	FT-FY24-11272023-004654-A	<1	FT-FY24-11272023-004654-B	<1
WS- 004655	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 104 Low Right	WF-02202023-004655	1/22/2024	FT-FY24-11272023-004655-A	<1	FT-FY24-11272023-004655-B	<1
WS- 004656	2/20/2023	2/20/2024	1	Health Suite	In health suite 104A across from room 104G	WF-02202023-004656	1/22/2024	FT-FY24-11272023-004656-A	1.6	FT-FY24-11272023-004656-B	<1
WS- 004657	2/20/2023	2/20/2024	1	Health Suite	In health suite in treatment room 104J	WF-02202023-004657	1/22/2024	FT-FY24-11272023-004657-A	2.3	FT-FY24-11272023-004657-B	<1
WS- 004659	2/20/2023	2/20/2024	1	Health Suite	In health suite in dentist room 104E	WF-02202023-004659	1/22/2024	FT-FY24-11272023-004659-A	1.4	FT-FY24-11272023-004659-B	<1
WS- 004660	2/20/2023	2/20/2024	1	Health Suite	In health suite in exam room 104L	WF-02202023-004660	1/22/2024	FT-FY24-11272023-004660-A	1.1	FT-FY24-11272023-004660-B	<1
WS- 004661	2/20/2023	2/20/2024	1	Break Room	In break room 102E	WF-02202023-004661	1/22/2024	FT-FY24-11272023-004661-A	<1	FT-FY24-11272023-004661-B	<1
WS- 004662	2/20/2023	2/20/2024	1	Break Room	In break room 102G	WF-02202023-004662	1/22/2024	FT-FY24-11272023-004662-A	<1	FT-FY24-11272023-004662-B	<1
WS- 004663	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 106C	WF-09052023-004663	1/22/2024	FT-FY24-11272023-004663-A	1.6	FT-FY24-11272023-004663-B	<1
WS- 004664	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 110	WF-09052023-004664	1/22/2024	FT-FY24-11272023-004664-A	2.1	FT-FY24-11272023-004664-B	<1
WS- 004665	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 110 Right	WF-02202023-004665	1/22/2024	FT-FY24-11272023-004665-A	<1	FT-FY24-11272023-004665-B	<1
WS- 004666	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 112 Mid	WF-09052023-004666	1/22/2024	FT-FY24-11272023-004666-A	2.1	FT-FY24-11272023-004666-B	<1
WS- 004667	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 112 Right	WF-02202023-004667	1/22/2024	FT-FY24-11272023-004667-A	<1	FT-FY24-11272023-004667-B	<1
WS- 004668	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 114 Mid	WF-09052023-004668	1/22/2024	FT-FY24-11272023-004668-A	2.0	FT-FY24-11272023-004668-B	<1
WS- 004669	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 114 Right	WF-02202023-004669	1/22/2024	FT-FY24-11272023-004669-A	<1	FT-FY24-11272023-004669-B	<1
WS- 004670	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 116 Mid	WF-09052023-004670	1/22/2024	FT-FY24-11272023-004670-A	1.2	FT-FY24-11272023-004670-B	<1
WS- 004671	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 116 Right	WF-02202023-004671	1/22/2024	FT-FY24-11272023-004671-A	<1	FT-FY24-11272023-004671-B	<1
WS- 004672	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 118	WF-09052023-004672	1/22/2024	FT-FY24-11272023-004672-A	<1	FT-FY24-11272023-004672-B	<1
WS- 004673	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 118	WF-02202023-004673	1/22/2024	FT-FY24-11272023-004673-A	1.5	FT-FY24-11272023-004673-B	<1
WS- 004676	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 122	WF-09052023-004676	1/22/2024	FT-FY24-11272023-004676-A	1.2	FT-FY24-11272023-004676-B	<1
WS- 004677	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 122	WF-02202023-004677	1/22/2024	FT-FY24-11272023-004677-A	1.9	FT-FY24-11272023-004677-B	<1
WS- 004678	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 130 High Left	WF-02202023-004678	1/22/2024	FT-FY24-11272023-004678-A	<1	FT-FY24-11272023-004678-B	<1
WS- 004679	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 130 Low Right	WF-02202023-004679	1/22/2024	FT-FY24-11272023-004679-A	<1	FT-FY24-11272023-004679-B	<1
WS- 004680	2/20/2023	2/20/2024	1	Break Room	In break room 132 Mid	WF-02202023-004680	1/22/2024	FT-FY24-11272023-004680-A	<1	FT-FY24-11272023-004680-B	<1
WS- 004682	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 124	WF-09052023-004682	1/22/2024	FT-FY24-11272023-004682-A	<1	FT-FY24-11272023-004682-B	<1
WS- 004683	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 124	WF-02202023-004683	1/22/2024	FT-FY24-11272023-004683-A	2.3	FT-FY24-11272023-004683-B	<1
WS- 004684	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 126	WF-09052023-004684	1/22/2024	FT-FY24-11272023-004684-A	<1	FT-FY24-11272023-004684-B	<1
WS- 004685	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 126	WF-02202023-004685	1/22/2024	FT-FY24-11272023-004685-A	<1	FT-FY24-11272023-004685-B	<1
WS- 004689	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 136 Mid	WF-09052023-004689	1/22/2024	FT-FY24-11272023-004689-A	1.8	FT-FY24-11272023-004689-B	<1
WS- 004690	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 136 Right	WF-02202023-004690	1/22/2024	FT-FY24-11272023-004690-A	1.1	FT-FY24-11272023-004690-B	<1
WS- 004691	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 138 Mid	WF-09052023-004691	1/22/2024	FT-FY24-11272023-004691-A	2.0	FT-FY24-11272023-004691-B	<1
WS- 004692	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 138 Right	WF-02202023-004692	1/22/2024	FT-FY24-11272023-004692-A	<1	FT-FY24-11272023-004692-B	<1
WS- 004693	2/20/2023	2/20/2024	1	Cooler	In cafeteria 129 Low Left	WF-02202023-004693	1/22/2024	FT-FY24-11272023-004693-A	<1	FT-FY24-11272023-004693-B	<1

WS-004694	2/20/2023	2/20/2024	1	Cooler	In cafeteria 129	High Right	WF-02202023-004694	1/22/2024	FT-FY24-11272023-004694-A	<1	FT-FY24-11272023-004694-B	<1
WS-004698	2/20/2023	2/20/2024	1	Ice Maker	In kitchen room 131B (ice maker)		WF-02202023-004698	1/22/2024	FT-FY24-11272023-004698-A	<1	FT-FY24-11272023-004698-B	<1
WS-004700	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 123	High Right	WF-02202023-004700	1/22/2024	FT-FY24-11272023-004700-A	<1	FT-FY24-11272023-004700-B	<1
WS-004701	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 123	Low Left	WF-02202023-004701	1/22/2024	FT-FY24-11272023-004701-A	<1	FT-FY24-11272023-004701-B	<1
WS-004703	2/20/2023	2/20/2024	1	Break Room	In break room 121B		WF-02202023-004703	1/22/2024	FT-FY24-11272023-004703-A	<1	FT-FY24-11272023-004703-B	<1
WS-004704	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 117		WF-09052023-004704	1/22/2024	FT-FY24-11272023-004704-A	1.9	FT-FY24-11272023-004704-B	<1
WS-004705	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 117	Right	WF-02202023-004705	1/22/2024	FT-FY24-11272023-004705-A	1.3	FT-FY24-11272023-004705-B	<1
WS-004706	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 113		WF-09052023-004706	1/22/2024	FT-FY24-11272023-004706-A	<1	FT-FY24-11272023-004706-B	<1
WS-004707	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 113		WF-02202023-004707	1/22/2024	FT-FY24-11272023-004707-A	<1	FT-FY24-11272023-004707-B	<1
WS-004708	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 111		WF-09052023-004708	1/22/2024	FT-FY24-11272023-004708-A	1.1	FT-FY24-11272023-004708-B	<1
WS-004709	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 111	Right	WF-02202023-004709	1/22/2024	FT-FY24-11272023-004709-A	<1	FT-FY24-11272023-004709-B	<1
WS-004710	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 109		WF-09052023-004710	1/22/2024	FT-FY24-11272023-004710-A	2.2	FT-FY24-11272023-004710-B	<1
WS-004711	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 109		WF-02202023-004711	1/22/2024	FT-FY24-11272023-004711-A	<1	FT-FY24-11272023-004711-B	<1
WS-004712	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 107		WF-09052023-004712	1/22/2024	FT-FY24-11272023-004712-A	2.5	FT-FY24-11272023-004712-B	<1
WS-004713	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 107	Right	WF-02202023-004713	1/22/2024	FT-FY24-11272023-004713-A	<1	FT-FY24-11272023-004713-B	<1
WS-004714	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 115		WF-09052023-004714	1/22/2024	FT-FY24-11272023-004714-A	1.2	FT-FY24-11272023-004714-B	<1
WS-004715	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 115		WF-02202023-004715	1/22/2024	FT-FY24-11272023-004715-A	<1	FT-FY24-11272023-004715-B	<1
WS-004716	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 142	Right	WF-02202023-004716	1/22/2024	FT-FY24-11272023-004716-A	<1	FT-FY24-11272023-004716-B	<1
WS-004717	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 142		WF-09052023-004717	1/22/2024	FT-FY24-11272023-004717-A	<1	FT-FY24-11272023-004717-B	<1
WS-004719	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 144		WF-02202023-004719	1/22/2024	FT-FY24-11272023-004719-A	<1	FT-FY24-11272023-004719-B	<1
WS-004720	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 146		WF-09052023-004720	1/22/2024	FT-FY24-11272023-004720-A	3.7	FT-FY24-11272023-004720-B	<1
WS-004721	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 146		WF-02202023-004721	1/22/2024	FT-FY24-11272023-004721-A	<1	FT-FY24-11272023-004721-B	<1
WS-004725	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-02202023-004725	1/22/2024	FT-FY24-11272023-004725-A	<1	FT-FY24-11272023-004725-B	<1
WS-004726	2/20/2023	2/20/2024	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-02202023-004726	1/22/2024	FT-FY24-11272023-004726-A	<1	FT-FY24-11272023-004726-B	<1
WS-004728	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 104	Right	WF-09052023-004728	1/22/2024	FT-FY24-11272023-004728-A	1.8	FT-FY24-11272023-004728-B	<1
WS-004729	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 104	Right	WF-02202023-004729	1/22/2024	FT-FY24-11272023-004729-A	<1	FT-FY24-11272023-004729-B	<1
WS-004730	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-09052023-004730	1/22/2024	FT-FY24-11272023-004730-A	2.4	FT-FY24-11272023-004730-B	<1
WS-004731	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-02202023-004731	1/22/2024	FT-FY24-11272023-004731-A	<1	FT-FY24-11272023-004731-B	<1
WS-004732	2/20/2023	2/20/2024	1	Health Suite	In health suite in feeding room 104C	Right	WF-02202023-004732	1/22/2024	FT-FY24-11272023-004732-A	2.7	FT-FY24-11272023-004732-B	<1
WS-004733	2/20/2023	2/20/2024	1	Health Suite	In health suite in feeding room 104C	Left	WF-02202023-004733	1/22/2024	FT-FY24-11272023-004733-A	<1	FT-FY24-11272023-004733-B	<1
WS-004737	2/20/2023	2/20/2024	1	Combo Fountain	In classroom 106C		WF-02202023-004737	1/22/2024	FT-FY24-11272023-004737-A	1.5	FT-FY24-11272023-004737-B	<1
WS-007180	2/20/2023	2/20/2024	1	Bottle Filler	In hallway adjacent to room 101-A		WF-02202023-007180	1/22/2024	FT-FY24-11272023-007180-A	<1	FT-FY24-11272023-007180-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004699	1/17/2023	1/17/2024	1	Food Prep Sink	In kitchen room 131A	WF-01172023-004699	1/22/2024	FT-FY24-11272023-004699-A	2.4	FT-FY24-11272023-004699-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004718	9/5/2023	9/5/2024	1	Combo Faucet	In classroom 144	WF-09052023-004718	1/22/2024	FT-FY24-11272023-004718-A	5.9	FT-FY24-11272023-004718-B	1.1

First Re-test (After Plumbing Check)

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004718	1/24/2024	1/24/2025	1	Combo Faucet	In classroom 144	WF-01242024-004718	1/31/2024	FT-FY24-01242024-004718-A	7.0	FT-FY24-01242024-004718-B	<1

Second Re-test (After Device Replacement)

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004718	2/8/2024	2/8/2025	1	Combo Faucet	In classroom 144	WF-02082024-004718	2/12/2024	FT-FY24-02082024-004718-A	5.3	FT-FY24-02082024-004718-B	<1

Third Re-test (After Consultation)

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004718	2/15/2024	2/15/2025	1	Combo Faucet	In classroom 144	WF-02152024-004718	2/22/2024	FT-FY24-02202024-004718-A	<1	FT-FY24-02202024-004718-B	<1