



River Terrace Education Campus Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004652	5/17/2021	5/17/2022	1	Cooler	In pool room 106	High Left	WF-05172021-004652	2/4/2022	FT-FY22-01102022-004652-A	<1	FT-FY22-01102022-004652-B	<1
WS-004653	5/17/2021	5/17/2022	1	Cooler	In pool room 106	Low Right	WF-05172021-004653	2/4/2022	FT-FY22-01102022-004653-A	<1	FT-FY22-01102022-004653-B	<1
WS-004654	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 104	High Left	WF-05172021-004654	2/4/2022	FT-FY22-01102022-004654-A	<1	FT-FY22-01102022-004654-B	<1
WS-004655	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 104	Low Right	WF-05172021-004655	2/4/2022	FT-FY22-01102022-004655-A	<1	FT-FY22-01102022-004655-B	<1
WS-004656	5/17/2021	5/17/2022	1	Health Suite	In health suite 104A across from room 104G		WF-05172021-004656	2/4/2022	FT-FY22-01102022-004656-A	<1	FT-FY22-01102022-004656-B	<1
WS-004657	5/17/2021	5/17/2022	1	Health Suite	In health suite in treatment room 104J		WF-05172021-004657	2/4/2022	FT-FY22-01102022-004657-A	<1	FT-FY22-01102022-004657-B	<1
WS-004659	5/17/2021	5/17/2022	1	Health Suite	In health suite in dentist room 104E		WF-05172021-004659	2/4/2022	FT-FY22-01102022-004659-A	<1	FT-FY22-01102022-004659-B	<1
WS-004660	5/17/2021	5/17/2022	1	Health Suite	In health suite in exam room 104L		WF-05172021-004660	2/4/2022	FT-FY22-01102022-004660-A	<1	FT-FY22-01102022-004660-B	<1
WS-004661	5/17/2021	5/17/2022	1	Break Room	In break room 102E		WF-05172021-004661	2/4/2022	FT-FY22-01102022-004661-A	<1	FT-FY22-01102022-004661-B	<1
WS-004662	5/17/2021	5/17/2022	1	Break Room	In break room 102G		WF-05172021-004662	2/4/2022	FT-FY22-01102022-004662-A	<1	FT-FY22-01102022-004662-B	<1
WS-004663	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 106C		WF-09202021-004663	2/4/2022	FT-FY22-01102022-004663-A	<1	FT-FY22-01102022-004663-B	<1
WS-004664	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 110		WF-09202021-004664	2/4/2022	FT-FY22-01102022-004664-A	<1	FT-FY22-01102022-004664-B	<1
WS-004665	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 110	Right	WF-05172021-004665	2/4/2022	FT-FY22-01102022-004665-A	<1	FT-FY22-01102022-004665-B	<1
WS-004666	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 112	Mid	WF-09202021-004666	2/4/2022	FT-FY22-01102022-004666-A	<1	FT-FY22-01102022-004666-B	<1
WS-004667	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 112	Right	WF-05172021-004667	2/4/2022	FT-FY22-01102022-004667-A	<1	FT-FY22-01102022-004667-B	<1
WS-004668	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 114	Mid	WF-09202021-004668	2/4/2022	FT-FY22-01102022-004668-A	<1	FT-FY22-01102022-004668-B	<1
WS-004669	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 114	Right	WF-05172021-004669	2/4/2022	FT-FY22-01102022-004669-A	<1	FT-FY22-01102022-004669-B	<1
WS-004670	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 116	Mid	WF-09202021-004670	2/4/2022	FT-FY22-01102022-004670-A	<1	FT-FY22-01102022-004670-B	<1
WS-004671	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 116	Right	WF-05172021-004671	2/4/2022	FT-FY22-01102022-004671-A	<1	FT-FY22-01102022-004671-B	<1
WS-004672	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 118		WF-09202021-004672	2/4/2022	FT-FY22-01102022-004672-A	<1	FT-FY22-01102022-004672-B	<1
WS-004673	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 118		WF-05172021-004673	2/4/2022	FT-FY22-01102022-004673-A	<1	FT-FY22-01102022-004673-B	<1
WS-004676	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 122		WF-09202021-004676	2/4/2022	FT-FY22-01102022-004676-A	<1	FT-FY22-01102022-004676-B	<1
WS-004677	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 122		WF-05172021-004677	2/4/2022	FT-FY22-01102022-004677-A	<1	FT-FY22-01102022-004677-B	<1
WS-004678	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 130	High Left	WF-05172021-004678	2/4/2022	FT-FY22-01102022-004678-A	<1	FT-FY22-01102022-004678-B	<1
WS-004679	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 130	Low Right	WF-05172021-004679	2/4/2022	FT-FY22-01102022-004679-A	<1	FT-FY22-01102022-004679-B	<1
WS-004680	5/17/2021	5/17/2022	1	Break Room	In break room 132	Mid	WF-05172021-004680	2/4/2022	FT-FY22-01102022-004680-A	<1	FT-FY22-01102022-004680-B	<1
WS-004682	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 124		WF-09202021-004682	2/4/2022	FT-FY22-01102022-004682-A	1.2	FT-FY22-01102022-004682-B	<1
WS-004683	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 124		WF-05172021-004683	2/4/2022	FT-FY22-01102022-004683-A	<1	FT-FY22-01102022-004683-B	<1
WS-004684	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 126		WF-09202021-004684	2/4/2022	FT-FY22-01102022-004684-A	<1	FT-FY22-01102022-004684-B	<1
WS-004685	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 126		WF-05172021-004685	2/4/2022	FT-FY22-01102022-004685-A	<1	FT-FY22-01102022-004685-B	<1
WS-004689	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 136	Mid	WF-09202021-004689	2/4/2022	FT-FY22-01102022-004689-A	<1	FT-FY22-01102022-004689-B	<1
WS-004690	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 136	Right	WF-05172021-004690	2/4/2022	FT-FY22-01102022-004690-A	<1	FT-FY22-01102022-004690-B	<1
WS-004691	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 138	Mid	WF-09202021-004691	2/4/2022	FT-FY22-01102022-004691-A	<1	FT-FY22-01102022-004691-B	<1
WS-004692	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 138	Right	WF-05172021-004692	2/4/2022	FT-FY22-01102022-004692-A	<1	FT-FY22-01102022-004692-B	<1
WS-004693	5/17/2021	5/17/2022	1	Cooler	In cafeteria 129	Low Left	WF-05172021-004693	2/4/2022	FT-FY22-01102022-004693-A	<1	FT-FY22-01102022-004693-B	<1
WS-004694	5/17/2021	5/17/2022	1	Cooler	In cafeteria 129	High Right	WF-05172021-004694	2/4/2022	FT-FY22-01102022-004694-A	<1	FT-FY22-01102022-004694-B	<1

WS-004698	5/17/2021	5/17/2022	1	Ice Maker	In kitchen room 131B (ice maker)		WF-05172021-004698	2/4/2022	FT-FY22-01102022-004698-A	<1	FT-FY22-01102022-004698-B	<1
WS-004700	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 123	High Right	WF-05172021-004700	2/4/2022	FT-FY22-01102022-004700-A	<1	FT-FY22-01102022-004700-B	<1
WS-004701	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 123	Low Left	WF-05172021-004701	2/4/2022	FT-FY22-01102022-004701-A	<1	FT-FY22-01102022-004701-B	<1
WS-004703	5/17/2021	5/17/2022	1	Break Room	In break room 121B		WF-05172021-004703	2/4/2022	FT-FY22-01102022-004703-A	<1	FT-FY22-01102022-004703-B	<1
WS-004704	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 117		WF-09202021-004704	2/4/2022	FT-FY22-01102022-004704-A	<1	FT-FY22-01102022-004704-B	<1
WS-004705	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 117	Right	WF-05172021-004705	2/4/2022	FT-FY22-01102022-004705-A	<1	FT-FY22-01102022-004705-B	<1
WS-004706	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 113		WF-09202021-004706	2/4/2022	FT-FY22-01102022-004706-A	1.5	FT-FY22-01102022-004706-B	<1
WS-004707	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 113		WF-05172021-004707	2/4/2022	FT-FY22-01102022-004707-A	<1	FT-FY22-01102022-004707-B	<1
WS-004708	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 111		WF-09202021-004708	2/4/2022	FT-FY22-01102022-004708-A	<1	FT-FY22-01102022-004708-B	<1
WS-004709	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 111	Right	WF-05172021-004709	2/4/2022	FT-FY22-01102022-004709-A	<1	FT-FY22-01102022-004709-B	<1
WS-004710	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 109		WF-09202021-004710	2/4/2022	FT-FY22-01102022-004710-A	<1	FT-FY22-01102022-004710-B	<1
WS-004711	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 109		WF-05172021-004711	2/4/2022	FT-FY22-01102022-004711-A	<1	FT-FY22-01102022-004711-B	<1
WS-004712	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 107		WF-09202021-004712	2/4/2022	FT-FY22-01102022-004712-A	<1	FT-FY22-01102022-004712-B	<1
WS-004713	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 107	Right	WF-05172021-004713	2/4/2022	FT-FY22-01102022-004713-A	<1	FT-FY22-01102022-004713-B	<1
WS-004714	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 115		WF-09202021-004714	2/4/2022	FT-FY22-01102022-004714-A	<1	FT-FY22-01102022-004714-B	<1
WS-004715	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 115		WF-05172021-004715	2/4/2022	FT-FY22-01102022-004715-A	<1	FT-FY22-01102022-004715-B	<1
WS-004716	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 142	Right	WF-05172021-004716	2/4/2022	FT-FY22-01102022-004716-A	<1	FT-FY22-01102022-004716-B	<1
WS-004717	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 142		WF-09202021-004717	2/4/2022	FT-FY22-01102022-004717-A	1.0	FT-FY22-01102022-004717-B	<1
WS-004718	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 144		WF-09202021-004718	2/4/2022	FT-FY22-01102022-004718-A	<1	FT-FY22-01102022-004718-B	<1
WS-004719	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 144		WF-05172021-004719	2/4/2022	FT-FY22-01102022-004719-A	<1	FT-FY22-01102022-004719-B	<1
WS-004720	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 146		WF-09202021-004720	2/4/2022	FT-FY22-01102022-004720-A	<1	FT-FY22-01102022-004720-B	<1
WS-004721	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 146		WF-05172021-004721	2/4/2022	FT-FY22-01102022-004721-A	<1	FT-FY22-01102022-004721-B	<1
WS-004725	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-05172021-004725	2/4/2022	FT-FY22-01102022-004725-A	<1	FT-FY22-01102022-004725-B	<1
WS-004726	5/17/2021	5/17/2022	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-05172021-004726	2/4/2022	FT-FY22-01102022-004726-A	<1	FT-FY22-01102022-004726-B	<1
WS-004728	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 104	Right	WF-09202021-004728	2/4/2022	FT-FY22-01102022-004728-A	<1	FT-FY22-01102022-004728-B	<1
WS-004729	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 104	Right	WF-05172021-004729	2/4/2022	FT-FY22-01102022-004729-A	<1	FT-FY22-01102022-004729-B	<1
WS-004730	9/20/2021	9/20/2022	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-09202021-004730	2/4/2022	FT-FY22-01102022-004730-A	1.9	FT-FY22-01102022-004730-B	<1
WS-004731	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-05172021-004731	2/4/2022	FT-FY22-01102022-004731-A	<1	FT-FY22-01102022-004731-B	<1
WS-004732	5/17/2021	5/17/2022	1	Health Suite	In health suite in feeding room 104C	Right	WF-05172021-004732	2/4/2022	FT-FY22-01102022-004732-A	<1	FT-FY22-01102022-004732-B	<1
WS-004733	5/17/2021	5/17/2022	1	Health Suite	In health suite in feeding room 104C	Left	WF-05172021-004733	2/4/2022	FT-FY22-01102022-004733-A	<1	FT-FY22-01102022-004733-B	<1
WS-004737	5/17/2021	5/17/2022	1	Combo Fountain	In classroom 106C		WF-05172021-004737	2/4/2022	FT-FY22-01102022-004737-A	<1	FT-FY22-01102022-004737-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004699	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen room 131A	WF-02172021-004699	2/4/2022	FT-FY22-01102022-004699-A	<1	FT-FY22-01102022-004699-B	<1