



# River Terrace Eduaction Campus Lead in Water Test Results

## FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004652	2/14/2024	2/14/2025	1	Cooler	In pool room 106 High Left	WF-02142024-004652	1/31/2025	FT-FY25-12262024-004652-A	<2	FT-FY25-12262024-004652-B	<2
WS- 004653	2/14/2024	2/14/2025	1	Cooler	In pool room 106 Low Right	WF-02142024-004653	1/31/2025	FT-FY25-12262024-004653-A	<2	FT-FY25-12262024-004653-B	<2
WS- 004654	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 104 High Left	WF-02142024-004654	1/31/2025	FT-FY25-12262024-004654-A	<2	FT-FY25-12262024-004654-B	<2
WS- 004655	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 104 Low Right	WF-02142024-004655	1/31/2025	FT-FY25-12262024-004655-A	<2	FT-FY25-12262024-004655-B	<2
WS- 004656	2/14/2024	2/14/2025	1	Health Suite	In health suite 104A across from room 104G	WF-02142024-004656	1/31/2025	FT-FY25-12262024-004656-A	<2	FT-FY25-12262024-004656-B	<2
WS- 004657	2/14/2024	2/14/2025	1	Health Suite	In health suite in treatment room 104J	WF-02142024-004657	1/31/2025	FT-FY25-12262024-004657-A	<2	FT-FY25-12262024-004657-B	<2
WS- 004659	2/14/2024	2/14/2025	1	Health Suite	In health suite in dentist room 104E	WF-02142024-004659	1/31/2025	FT-FY25-12262024-004659-A	<2	FT-FY25-12262024-004659-B	<2
WS- 004660	2/14/2024	2/14/2025	1	Health Suite	In health suite in exam room 104L	WF-02142024-004660	1/31/2025	FT-FY25-12262024-004660-A	<2	FT-FY25-12262024-004660-B	<2
WS- 004661	2/14/2024	2/14/2025	1	Break Room	In break room 102E	WF-02142024-004661	1/31/2025	FT-FY25-12262024-004661-A	<2	FT-FY25-12262024-004661-B	<2
WS- 004662	2/14/2024	2/14/2025	1	Break Room	In break room 102G	WF-02142024-004662	1/31/2025	FT-FY25-12262024-004662-A	<2	FT-FY25-12262024-004662-B	<2
WS- 004663	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 106C	WF-09042024-004663	1/31/2025	FT-FY25-12262024-004663-A	2.4	FT-FY25-12262024-004663-B	<2
WS- 004664	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 110	WF-09042024-004664	1/31/2025	FT-FY25-12262024-004664-A	<2	FT-FY25-12262024-004664-B	<2
WS- 004665	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 110 Right	WF-02142024-004665	1/31/2025	FT-FY25-12262024-004665-A	<2	FT-FY25-12262024-004665-B	<2
WS- 004666	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 112 Mid	WF-09042024-004666	1/31/2025	FT-FY25-12262024-004666-A	<2	FT-FY25-12262024-004666-B	<2
WS- 004667	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 112 Right	WF-02142024-004667	1/31/2025	FT-FY25-12262024-004667-A	<2	FT-FY25-12262024-004667-B	<2
WS- 004668	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 114 Mid	WF-09042024-004668	1/31/2025	FT-FY25-12262024-004668-A	<2	FT-FY25-12262024-004668-B	<2
WS- 004669	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 114 Right	WF-02142024-004669	1/31/2025	FT-FY25-12262024-004669-A	<2	FT-FY25-12262024-004669-B	<2
WS- 004670	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 116 Mid	WF-09042024-004670	1/31/2025	FT-FY25-12262024-004670-A	<2	FT-FY25-12262024-004670-B	<2
WS- 004671	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 116 Right	WF-02142024-004671	1/31/2025	FT-FY25-12262024-004671-A	<2	FT-FY25-12262024-004671-B	<2
WS- 004672	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 118	WF-09042024-004672	1/31/2025	FT-FY25-12262024-004672-A	<2	FT-FY25-12262024-004672-B	<2
WS- 004673	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 118	WF-02142024-004673	1/31/2025	FT-FY25-12262024-004673-A	<2	FT-FY25-12262024-004673-B	<2
WS- 004674	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 120 Mid	WF-09042024-004674	1/31/2025	FT-FY25-12262024-004674-A	<2	FT-FY25-12262024-004674-B	<2
WS- 004676	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 122	WF-09042024-004676	1/31/2025	FT-FY25-12262024-004676-A	<2	FT-FY25-12262024-004676-B	<2
WS- 004677	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 122	WF-02142024-004677	1/31/2025	FT-FY25-12262024-004677-A	<2	FT-FY25-12262024-004677-B	<2
WS- 004678	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 130 High Left	WF-02142024-004678	1/31/2025	FT-FY25-12262024-004678-A	<2	FT-FY25-12262024-004678-B	<2
WS- 004679	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 130 Low Right	WF-02142024-004679	1/31/2025	FT-FY25-12262024-004679-A	<2	FT-FY25-12262024-004679-B	<2
WS- 004680	2/14/2024	2/14/2025	1	Break Room	In break room 132 Mid	WF-02142024-004680	1/31/2025	FT-FY25-12262024-004680-A	<2	FT-FY25-12262024-004680-B	<2
WS- 004682	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 124	WF-09042024-004682	1/31/2025	FT-FY25-12262024-004682-A	<2	FT-FY25-12262024-004682-B	<2
WS- 004683	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 124	WF-02142024-004683	1/31/2025	FT-FY25-12262024-004683-A	<2	FT-FY25-12262024-004683-B	<2
WS- 004684	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 126	WF-09042024-004684	1/31/2025	FT-FY25-12262024-004684-A	<2	FT-FY25-12262024-004684-B	<2
WS- 004685	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 126	WF-02142024-004685	1/31/2025	FT-FY25-12262024-004685-A	<2	FT-FY25-12262024-004685-B	<2
WS- 004689	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 136 Mid	WF-09042024-004689	1/31/2025	FT-FY25-12262024-004689-A	<2	FT-FY25-12262024-004689-B	<2
WS- 004690	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 136 Right	WF-02142024-004690	1/31/2025	FT-FY25-12262024-004690-A	<2	FT-FY25-12262024-004690-B	<2

WS- 004691	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 138	Mid	WF-09042024-004691	1/31/2025	FT-FY25-12262024-004691-A	<2	FT-FY25-12262024-004691-B	<2
WS- 004693	2/14/2024	2/14/2025	1	Cooler	In cafeteria 129	Low Left	WF-02142024-004693	1/31/2025	FT-FY25-12262024-004693-A	<2	FT-FY25-12262024-004693-B	<2
WS- 004694	2/14/2024	2/14/2025	1	Cooler	In cafeteria 129	High Right	WF-02142024-004694	1/31/2025	FT-FY25-12262024-004694-A	<2	FT-FY25-12262024-004694-B	<2
WS- 004700	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 123	High Right	WF-02142024-004700	1/31/2025	FT-FY25-12262024-004700-A	<2	FT-FY25-12262024-004700-B	<2
WS- 004701	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 123	Low Left	WF-02142024-004701	1/31/2025	FT-FY25-12262024-004701-A	<2	FT-FY25-12262024-004701-B	<2
WS- 004703	2/14/2024	2/14/2025	1	Break Room	In break room 121B		WF-02142024-004703	1/31/2025	FT-FY25-12262024-004703-A	<2	FT-FY25-12262024-004703-B	<2
WS- 004704	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 117		WF-09042024-004704	1/31/2025	FT-FY25-12262024-004704-A	2.5	FT-FY25-12262024-004704-B	<2
WS- 004705	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 117	Right	WF-02142024-004705	1/31/2025	FT-FY25-12262024-004705-A	<2	FT-FY25-12262024-004705-B	<2
WS- 004706	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 113		WF-09042024-004706	1/31/2025	FT-FY25-12262024-004706-A	<2	FT-FY25-12262024-004706-B	<2
WS- 004708	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 111		WF-09042024-004708	1/31/2025	FT-FY25-12262024-004708-A	<2	FT-FY25-12262024-004708-B	<2
WS- 004710	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 109		WF-09042024-004710	1/31/2025	FT-FY25-12262024-004710-A	<2	FT-FY25-12262024-004710-B	<2
WS- 004712	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 107		WF-09042024-004712	1/31/2025	FT-FY25-12262024-004712-A	<2	FT-FY25-12262024-004712-B	<2
WS- 004714	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 115		WF-09042024-004714	1/31/2025	FT-FY25-12262024-004714-A	<2	FT-FY25-12262024-004714-B	<2
WS- 004717	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 142		WF-09042024-004717	1/31/2025	FT-FY25-12262024-004717-A	<2	FT-FY25-12262024-004717-B	<2
WS- 004718	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 144		WF-09042024-004718	1/31/2025	FT-FY25-12262024-004718-A	<2	FT-FY25-12262024-004718-B	<2
WS- 004720	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 146		WF-09042024-004720	1/31/2025	FT-FY25-12262024-004720-A	2.3	FT-FY25-12262024-004720-B	<2
WS- 004725	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-02142024-004725	1/31/2025	FT-FY25-12262024-004725-A	<2	FT-FY25-12262024-004725-B	<2
WS- 004726	2/14/2024	2/14/2025	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-02142024-004726	1/31/2025	FT-FY25-12262024-004726-A	<2	FT-FY25-12262024-004726-B	<2
WS- 004728	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 104	Right	WF-09042024-004728	1/31/2025	FT-FY25-12262024-004728-A	<2	FT-FY25-12262024-004728-B	<2
WS- 004729	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 104	Right	WF-02142024-004729	1/31/2025	FT-FY25-12262024-004729-A	<2	FT-FY25-12262024-004729-B	<2
WS- 004730	9/4/2024	9/4/2025	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-09042024-004730	1/31/2025	FT-FY25-12262024-004730-A	<2	FT-FY25-12262024-004730-B	<2
WS- 004731	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-02142024-004731	1/31/2025	FT-FY25-12262024-004731-A	<2	FT-FY25-12262024-004731-B	<2
WS- 004732	2/14/2024	2/14/2025	1	Health Suite	In health suite in feeding room 104C	Right	WF-02142024-004732	1/31/2025	FT-FY25-12262024-004732-A	<2	FT-FY25-12262024-004732-B	<2
WS- 004733	2/14/2024	2/14/2025	1	Health Suite	In health suite in feeding room 104C	Left	WF-02142024-004733	1/31/2025	FT-FY25-12262024-004733-A	<2	FT-FY25-12262024-004733-B	<2
WS- 004737	2/14/2024	2/14/2025	1	Combo Fountain	In classroom 106C		WF-02142024-004737	1/31/2025	FT-FY25-12262024-004737-A	<2	FT-FY25-12262024-004737-B	<2
WS- 007180	2/14/2024	2/14/2025	1	Bottle Filler	In hallway adjacent to room 101-A		WF-02142024-007180	1/31/2025	FT-FY25-12262024-007180-A	<2	FT-FY25-12262024-007180-B	<2

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004699	1/8/2025	1/8/2026	1	Food Prep Sink	In kitchen room 131A	WF-01082025-004699	1/31/2025	FT-FY25-12262024-004699-A	2.2	FT-FY25-12262024-004699-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.