



River Terrace Education Campus Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004652	6/15/2020	6/15/2021	1	Cooler	In pool room 106 High Left	WF-06152020-004652	3/10/2021	FT-FY21-022021-004652-A	<1	FT-FY21-022021-004652-B	<1
WS-004653	6/15/2020	6/15/2021	1	Cooler	In pool room 106 Low Right	WF-06152020-004653	3/10/2021	FT-FY21-022021-004653-A	<1	FT-FY21-022021-004653-B	<1
WS-004654	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 104 High Left	WF-06152020-004654	3/10/2021	FT-FY21-022021-004654-A	<1	FT-FY21-022021-004654-B	<1
WS-004655	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 104 Low Right	WF-06152020-004655	3/10/2021	FT-FY21-022021-004655-A	<1	FT-FY21-022021-004655-B	<1
WS-004656	6/15/2020	6/15/2021	1	Health Suite	In health suite 104A across from room 104G	WF-06152020-004656	3/10/2021	FT-FY21-022021-004656-A	<1	FT-FY21-022021-004656-B	<1
WS-004657	6/15/2020	6/15/2021	1	Health Suite	In health suite in treatment room 104J	WF-06152020-004657	3/10/2021	FT-FY21-022021-004657-A	<1	FT-FY21-022021-004657-B	<1
WS-004659	6/15/2020	6/15/2021	1	Health Suite	In health suite in dentist room 104E	WF-06152020-004659	3/10/2021	FT-FY21-022021-004659-A	<1	FT-FY21-022021-004659-B	<1
WS-004660	6/15/2020	6/15/2021	1	Health Suite	In health suite in exam room 104L	WF-06152020-004660	3/10/2021	FT-FY21-022021-004660-A	<1	FT-FY21-022021-004660-B	<1
WS-004661	6/15/2020	6/15/2021	1	Break Room	In break room 102E	WF-06152020-004661	3/10/2021	FT-FY21-022021-004661-A	<1	FT-FY21-022021-004661-B	<1
WS-004662	6/15/2020	6/15/2021	1	Break Room	In break room 102G	WF-06152020-004662	3/10/2021	FT-FY21-022021-004662-A	<1	FT-FY21-022021-004662-B	<1
WS-004663	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 106C	WF-09282020-004663	3/10/2021	FT-FY21-022021-004663-A	<1	FT-FY21-022021-004663-B	<1
WS-004664	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 110	WF-09282020-004664	3/10/2021	FT-FY21-022021-004664-A	<1	FT-FY21-022021-004664-B	<1
WS-004665	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 110 Right	WF-06152020-004665	3/10/2021	FT-FY21-022021-004665-A	<1	FT-FY21-022021-004665-B	<1
WS-004666	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 112 Mid	WF-09282020-004666	3/10/2021	FT-FY21-022021-004666-A	<1	FT-FY21-022021-004666-B	<1
WS-004667	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 112 Right	WF-06152020-004667	3/10/2021	FT-FY21-022021-004667-A	<1	FT-FY21-022021-004667-B	<1
WS-004668	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 114 Mid	WF-09282020-004668	3/10/2021	FT-FY21-022021-004668-A	<1	FT-FY21-022021-004668-B	<1
WS-004669	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 114 Right	WF-06152020-004669	3/10/2021	FT-FY21-022021-004669-A	<1	FT-FY21-022021-004669-B	<1
WS-004670	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 116 Mid	WF-09282020-004670	3/10/2021	FT-FY21-022021-004670-A	<1	FT-FY21-022021-004670-B	<1
WS-004671	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 116 Right	WF-06152020-004671	3/10/2021	FT-FY21-022021-004671-A	<1	FT-FY21-022021-004671-B	<1
WS-004672	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 118	WF-09282020-004672	3/10/2021	FT-FY21-022021-004672-A	<1	FT-FY21-022021-004672-B	<1
WS-004673	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 118	WF-06152020-004673	3/10/2021	FT-FY21-022021-004673-A	<1	FT-FY21-022021-004673-B	<1
WS-004674	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 120 Mid	WF-09282020-004674	3/10/2021	FT-FY21-022021-004674-A	<1	FT-FY21-022021-004674-B	<1
WS-004675	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 120 Right	WF-06152020-004675	3/10/2021	FT-FY21-022021-004675-A	<1	FT-FY21-022021-004675-B	<1
WS-004676	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 122	WF-09282020-004676	3/10/2021	FT-FY21-022021-004676-A	<1	FT-FY21-022021-004676-B	<1
WS-004677	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 122	WF-06152020-004677	3/10/2021	FT-FY21-022021-004677-A	<1	FT-FY21-022021-004677-B	<1
WS-004678	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 130 High Left	WF-06152020-004678	3/10/2021	FT-FY21-022021-004678-A	<1	FT-FY21-022021-004678-B	<1
WS-004679	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 130 Low Right	WF-06152020-004679	3/10/2021	FT-FY21-022021-004679-A	<1	FT-FY21-022021-004679-B	<1
WS-004680	6/15/2020	6/15/2021	1	Break Room	In break room 132 Mid	WF-06152020-004680	3/10/2021	FT-FY21-022021-004680-A	<1	FT-FY21-022021-004680-B	<1
WS-004682	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 124	WF-09282020-004682	3/10/2021	FT-FY21-022021-004682-A	<1	FT-FY21-022021-004682-B	<1
WS-004683	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 124	WF-06152020-004683	3/10/2021	FT-FY21-022021-004683-A	<1	FT-FY21-022021-004683-B	<1
WS-004684	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 126	WF-09282020-004684	3/10/2021	FT-FY21-022021-004684-A	<1	FT-FY21-022021-004684-B	<1
WS-004685	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 126	WF-06152020-004685	3/10/2021	FT-FY21-022021-004685-A	<1	FT-FY21-022021-004685-B	<1

WS- 004689	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 136	Mid	WF-09282020-004689	3/10/2021	FT-FY21-022021-004689-A	<1	FT-FY21-022021-004689-B	<1
WS- 004690	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 136	Right	WF-06152020-004690	3/10/2021	FT-FY21-022021-004690-A	<1	FT-FY21-022021-004690-B	<1
WS- 004691	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 138	Mid	WF-09282020-004691	3/10/2021	FT-FY21-022021-004691-A	<1	FT-FY21-022021-004691-B	<1
WS- 004692	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 138	Right	WF-06152020-004692	3/10/2021	FT-FY21-022021-004692-A	<1	FT-FY21-022021-004692-B	<1
WS- 004693	6/15/2020	6/15/2021	1	Cooler	In cafeteria 129	Low Left	WF-06152020-004693	3/10/2021	FT-FY21-022021-004693-A	<1	FT-FY21-022021-004693-B	<1
WS- 004694	6/15/2020	6/15/2021	1	Cooler	In cafeteria 129	High Right	WF-06152020-004694	3/10/2021	FT-FY21-022021-004694-A	<1	FT-FY21-022021-004694-B	<1
WS- 004698	6/15/2020	6/15/2021	1	Ice Maker	In kitchen room 131B (ice maker)		WF-06152020-004698	3/10/2021	FT-FY21-022021-004698-A	<1	FT-FY21-022021-004698-B	<1
WS- 004700	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 123	High Right	WF-06152020-004700	3/10/2021	FT-FY21-022021-004700-A	<1	FT-FY21-022021-004700-B	<1
WS- 004701	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 123	Low Left	WF-06152020-004701	3/10/2021	FT-FY21-022021-004701-A	<1	FT-FY21-022021-004701-B	<1
WS- 004703	6/15/2020	6/15/2021	1	Break Room	In break room 121B		WF-06152020-004703	3/10/2021	FT-FY21-022021-004703-A	<1	FT-FY21-022021-004703-B	<1
WS- 004704	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 117		WF-09282020-004704	3/10/2021	FT-FY21-022021-004704-A	<1	FT-FY21-022021-004704-B	<1
WS- 004705	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 117	Right	WF-06152020-004705	3/10/2021	FT-FY21-022021-004705-A	<1	FT-FY21-022021-004705-B	<1
WS- 004706	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 113		WF-09282020-004706	3/10/2021	FT-FY21-022021-004706-A	<1	FT-FY21-022021-004706-B	<1
WS- 004707	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 113		WF-06152020-004707	3/10/2021	FT-FY21-022021-004707-A	<1	FT-FY21-022021-004707-B	<1
WS- 004708	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 111		WF-09282020-004708	3/10/2021	FT-FY21-022021-004708-A	<1	FT-FY21-022021-004708-B	<1
WS- 004709	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 111	Right	WF-06152020-004709	3/10/2021	FT-FY21-022021-004709-A	<1	FT-FY21-022021-004709-B	<1
WS- 004710	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 109		WF-09282020-004710	3/10/2021	FT-FY21-022021-004710-A	<1	FT-FY21-022021-004710-B	<1
WS- 004711	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 109		WF-06152020-004711	3/10/2021	FT-FY21-022021-004711-A	<1	FT-FY21-022021-004711-B	<1
WS- 004712	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 107		WF-09282020-004712	3/10/2021	FT-FY21-022021-004712-A	<1	FT-FY21-022021-004712-B	<1
WS- 004713	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 107	Right	WF-06152020-004713	3/10/2021	FT-FY21-022021-004713-A	<1	FT-FY21-022021-004713-B	<1
WS- 004714	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 115		WF-09282020-004714	3/10/2021	FT-FY21-022021-004714-A	<1	FT-FY21-022021-004714-B	<1
WS- 004715	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 115		WF-06152020-004715	3/10/2021	FT-FY21-022021-004715-A	<1	FT-FY21-022021-004715-B	<1
WS- 004716	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 142	Right	WF-06152020-004716	3/10/2021	FT-FY21-022021-004716-A	<1	FT-FY21-022021-004716-B	<1
WS- 004717	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 142		WF-09282020-004717	3/10/2021	FT-FY21-022021-004717-A	<1	FT-FY21-022021-004717-B	<1
WS- 004718	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 144		WF-09282020-004718	3/10/2021	FT-FY21-022021-004718-A	<1	FT-FY21-022021-004718-B	<1
WS- 004719	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 144		WF-06152020-004719	3/10/2021	FT-FY21-022021-004719-A	<1	FT-FY21-022021-004719-B	<1
WS- 004720	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 146		WF-09282020-004720	3/10/2021	FT-FY21-022021-004720-A	<1	FT-FY21-022021-004720-B	<1
WS- 004721	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 146		WF-06152020-004721	3/10/2021	FT-FY21-022021-004721-A	<1	FT-FY21-022021-004721-B	<1
WS- 004725	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-06152020-004725	3/10/2021	FT-FY21-022021-004725-A	<1	FT-FY21-022021-004725-B	<1
WS- 004726	6/15/2020	6/15/2021	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-06152020-004726	3/10/2021	FT-FY21-022021-004726-A	<1	FT-FY21-022021-004726-B	<1
WS- 004728	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 104	Right	WF-09282020-004728	3/10/2021	FT-FY21-022021-004728-A	<1	FT-FY21-022021-004728-B	<1
WS- 004729	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 104	Right	WF-06152020-004729	3/10/2021	FT-FY21-022021-004729-A	<1	FT-FY21-022021-004729-B	<1
WS- 004730	9/28/2020	9/28/2021	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-09282020-004730	3/10/2021	FT-FY21-022021-004730-A	<1	FT-FY21-022021-004730-B	<1
WS- 004731	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-06152020-004731	3/10/2021	FT-FY21-022021-004731-A	<1	FT-FY21-022021-004731-B	<1
WS- 004732	6/15/2020	6/15/2021	1	Health Suite	In health suite in feeding room 104C	Right	WF-06152020-004732	3/10/2021	FT-FY21-022021-004732-A	<1	FT-FY21-022021-004732-B	<1
WS- 004733	6/15/2020	6/15/2021	1	Health Suite	In health suite in feeding room 104C	Left	WF-06152020-004733	3/10/2021	FT-FY21-022021-004733-A	<1	FT-FY21-022021-004733-B	<1
WS- 004737	6/15/2020	6/15/2021	1	Combo Fountain	In classroom 106C		WF-06152020-004737	3/10/2021	FT-FY21-022021-004737-A	<1	FT-FY21-022021-004737-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004699	2/17/2021	2/17/2022	1	Food Prep Sink	In kitchen room 131A	WF-02172021-004699	3/10/2021	FT-FY21-022021-004699-A	<1	FT-FY21-022021-004699-B	<1