



River Terrace Education Campus Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004654	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 104	High Left	WF-05092022-004654	11/10/2022	FT-FY23-10102022-004654-A	<1	FT-FY23-10102022-004654-B	<1
WS- 004655	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 104	Low Right	WF-05092022-004655	11/10/2022	FT-FY23-10102022-004655-A	<1	FT-FY23-10102022-004655-B	<1
WS- 004656	5/9/2022	5/9/2023	1	Health Suite	In health suite 104A across from room 104G		WF-05092022-004656	11/10/2022	FT-FY23-10102022-004656-A	<1	FT-FY23-10102022-004656-B	<1
WS- 004657	5/9/2022	5/9/2023	1	Health Suite	In health suite in treatment room 104J		WF-05092022-004657	11/10/2022	FT-FY23-10102022-004657-A	<1	FT-FY23-10102022-004657-B	<1
WS- 004659	5/9/2022	5/9/2023	1	Health Suite	In health suite in dentist room 104E		WF-05092022-004659	11/10/2022	FT-FY23-10102022-004659-A	<1	FT-FY23-10102022-004659-B	<1
WS- 004660	5/9/2022	5/9/2023	1	Health Suite	In health suite in exam room 104L		WF-05092022-004660	11/10/2022	FT-FY23-10102022-004660-A	<1	FT-FY23-10102022-004660-B	<1
WS- 004663	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 106C		WF-09122022-004663	11/10/2022	FT-FY23-10102022-004663-A	<1	FT-FY23-10102022-004663-B	<1
WS- 004664	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 110		WF-09122022-004664	11/10/2022	FT-FY23-10102022-004664-A	<1	FT-FY23-10102022-004664-B	<1
WS- 004665	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 110	Right	WF-05092022-004665	11/10/2022	FT-FY23-10102022-004665-A	<1	FT-FY23-10102022-004665-B	<1
WS- 004666	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 112	Mid	WF-09122022-004666	11/10/2022	FT-FY23-10102022-004666-A	<1	FT-FY23-10102022-004666-B	<1
WS- 004667	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 112	Right	WF-05092022-004667	11/10/2022	FT-FY23-10102022-004667-A	<1	FT-FY23-10102022-004667-B	<1
WS- 004670	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 116	Mid	WF-09122022-004670	11/10/2022	FT-FY23-10102022-004670-A	<1	FT-FY23-10102022-004670-B	<1
WS- 004671	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 116	Right	WF-05092022-004671	11/10/2022	FT-FY23-10102022-004671-A	<1	FT-FY23-10102022-004671-B	<1
WS- 004672	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 118		WF-09122022-004672	11/10/2022	FT-FY23-10102022-004672-A	<1	FT-FY23-10102022-004672-B	<1
WS- 004673	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 118		WF-05092022-004673	11/10/2022	FT-FY23-10102022-004673-A	<1	FT-FY23-10102022-004673-B	<1
WS- 004676	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 122		WF-09122022-004676	11/10/2022	FT-FY23-10102022-004676-A	<1	FT-FY23-10102022-004676-B	<1
WS- 004677	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 122		WF-05092022-004677	11/10/2022	FT-FY23-10102022-004677-A	<1	FT-FY23-10102022-004677-B	<1
WS- 004678	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 130	High Left	WF-05092022-004678	11/10/2022	FT-FY23-10102022-004678-A	<1	FT-FY23-10102022-004678-B	<1
WS- 004679	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 130	Low Right	WF-05092022-004679	11/10/2022	FT-FY23-10102022-004679-A	<1	FT-FY23-10102022-004679-B	<1
WS- 004680	5/9/2022	5/9/2023	1	Break Room	In break room 132	Mid	WF-05092022-004680	11/10/2022	FT-FY23-10102022-004680-A	<1	FT-FY23-10102022-004680-B	<1
WS- 004682	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 124		WF-09122022-004682	11/10/2022	FT-FY23-10102022-004682-A	<1	FT-FY23-10102022-004682-B	<1
WS- 004683	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 124		WF-05092022-004683	11/10/2022	FT-FY23-10102022-004683-A	<1	FT-FY23-10102022-004683-B	<1
WS- 004684	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 126		WF-09122022-004684	11/10/2022	FT-FY23-10102022-004684-A	<1	FT-FY23-10102022-004684-B	<1
WS- 004685	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 126		WF-05092022-004685	11/10/2022	FT-FY23-10102022-004685-A	<1	FT-FY23-10102022-004685-B	<1
WS- 004689	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 136	Mid	WF-09122022-004689	11/10/2022	FT-FY23-10102022-004689-A	<1	FT-FY23-10102022-004689-B	<1
WS- 004690	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 136	Right	WF-05092022-004690	11/10/2022	FT-FY23-10102022-004690-A	<1	FT-FY23-10102022-004690-B	<1
WS- 004691	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 138	Mid	WF-09122022-004691	11/10/2022	FT-FY23-10102022-004691-A	<1	FT-FY23-10102022-004691-B	<1
WS- 004692	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 138	Right	WF-05092022-004692	11/10/2022	FT-FY23-10102022-004692-A	<1	FT-FY23-10102022-004692-B	<1
WS- 004693	5/9/2022	5/9/2023	1	Cooler	In cafeteria 129	Low Left	WF-05092022-004693	11/10/2022	FT-FY23-10102022-004693-A	<1	FT-FY23-10102022-004693-B	<1
WS- 004694	5/9/2022	5/9/2023	1	Cooler	In cafeteria 129	High Right	WF-05092022-004694	11/10/2022	FT-FY23-10102022-004694-A	<1	FT-FY23-10102022-004694-B	<1
WS- 004698	5/9/2022	5/9/2023	1	Ice Maker	In kitchen room 131B (ice maker)		WF-05092022-004698	11/10/2022	FT-FY23-10102022-004698-A	<1	FT-FY23-10102022-004698-B	<1
WS- 004700	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 123	High Right	WF-05092022-004700	11/10/2022	FT-FY23-10102022-004700-A	<1	FT-FY23-10102022-004700-B	<1
WS- 004701	5/9/2022	5/9/2023	1	Cooler	In hallway adjacent to room 123	Low Left	WF-05092022-004701	11/10/2022	FT-FY23-10102022-004701-A	<1	FT-FY23-10102022-004701-B	<1
WS- 004703	5/9/2022	5/9/2023	1	Break Room	In break room 121B		WF-05092022-004703	11/10/2022	FT-FY23-10102022-004703-A	<1	FT-FY23-10102022-004703-B	<1

WS- 004704	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 117		WF-09122022-004704	11/10/2022	FT-FY23-10102022-004704-A	<1	FT-FY23-10102022-004704-B	<1
WS- 004705	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 117	Right	WF-05092022-004705	11/10/2022	FT-FY23-10102022-004705-A	<1	FT-FY23-10102022-004705-B	<1
WS- 004706	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 113		WF-09122022-004706	11/10/2022	FT-FY23-10102022-004706-A	<1	FT-FY23-10102022-004706-B	<1
WS- 004707	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 113		WF-05092022-004707	11/10/2022	FT-FY23-10102022-004707-A	<1	FT-FY23-10102022-004707-B	<1
WS- 004708	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 111		WF-09122022-004708	11/10/2022	FT-FY23-10102022-004708-A	<1	FT-FY23-10102022-004708-B	<1
WS- 004709	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 111	Right	WF-05092022-004709	11/10/2022	FT-FY23-10102022-004709-A	<1	FT-FY23-10102022-004709-B	<1
WS- 004710	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 109		WF-09122022-004710	11/10/2022	FT-FY23-10102022-004710-A	<1	FT-FY23-10102022-004710-B	<1
WS- 004711	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 109		WF-05092022-004711	11/10/2022	FT-FY23-10102022-004711-A	<1	FT-FY23-10102022-004711-B	<1
WS- 004712	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 107		WF-09122022-004712	11/10/2022	FT-FY23-10102022-004712-A	<1	FT-FY23-10102022-004712-B	<1
WS- 004713	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 107	Right	WF-05092022-004713	11/10/2022	FT-FY23-10102022-004713-A	<1	FT-FY23-10102022-004713-B	<1
WS- 004714	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 115		WF-09122022-004714	11/10/2022	FT-FY23-10102022-004714-A	<1	FT-FY23-10102022-004714-B	<1
WS- 004715	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 115		WF-05092022-004715	11/10/2022	FT-FY23-10102022-004715-A	<1	FT-FY23-10102022-004715-B	<1
WS- 004716	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 142	Right	WF-05092022-004716	11/10/2022	FT-FY23-10102022-004716-A	<1	FT-FY23-10102022-004716-B	<1
WS- 004717	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 142		WF-09122022-004717	11/10/2022	FT-FY23-10102022-004717-A	<1	FT-FY23-10102022-004717-B	<1
WS- 004718	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 144		WF-09122022-004718	11/10/2022	FT-FY23-10102022-004718-A	<1	FT-FY23-10102022-004718-B	<1
WS- 004719	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 144		WF-05092022-004719	11/10/2022	FT-FY23-10102022-004719-A	<1	FT-FY23-10102022-004719-B	<1
WS- 004720	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 146		WF-09122022-004720	11/10/2022	FT-FY23-10102022-004720-A	<1	FT-FY23-10102022-004720-B	<1
WS- 004721	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 146		WF-05092022-004721	11/10/2022	FT-FY23-10102022-004721-A	<1	FT-FY23-10102022-004721-B	<1
WS- 004728	9/12/2022	9/12/2023	1	Combo Faucet	In classroom 104	Right	WF-09122022-004728	11/10/2022	FT-FY23-10102022-004728-A	<1	FT-FY23-10102022-004728-B	<1
WS- 004729	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 104	Right	WF-05092022-004729	11/10/2022	FT-FY23-10102022-004729-A	<1	FT-FY23-10102022-004729-B	<1
WS- 004732	5/9/2022	5/9/2023	1	Health Suite	In health suite in feeding room 104C	Right	WF-05092022-004732	11/10/2022	FT-FY23-10102022-004732-A	<1	FT-FY23-10102022-004732-B	<1
WS- 004733	5/9/2022	5/9/2023	1	Health Suite	In health suite in feeding room 104C	Left	WF-05092022-004733	11/10/2022	FT-FY23-10102022-004733-A	<1	FT-FY23-10102022-004733-B	<1
WS- 004737	5/9/2022	5/9/2023	1	Combo Fountain	In classroom 106C		WF-05092022-004737	11/10/2022	FT-FY23-10102022-004737-A	<1	FT-FY23-10102022-004737-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004699	2/9/2022	2/9/2023	1	Food Prep Sink	In kitchen room 131A	WF-02092022-004699	11/10/2022	FT-FY23-10102022-004699-A	<1	FT-FY23-10102022-004699-B	<1