



River Terrace EC Lead Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004652	4/29/2019	4/29/2020	1	Cooler	In pool room 106 High Left	WF-04292019-004652	11/6/2019	FT-FY20-102019-004652-A	<1	FT-FY20-102019-004652-B	<1
WS-004653	4/29/2019	4/29/2020	1	Cooler	In pool room 106 Low Right	WF-04292019-004653	11/6/2019	FT-FY20-102019-004653-A	<1	FT-FY20-102019-004653-B	<1
WS-004654	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 104 High Left	WF-04292019-004654	11/6/2019	FT-FY20-102019-004654-A	<1	FT-FY20-102019-004654-B	<1
WS-004655	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 104 Low Right	WF-04292019-004655	11/6/2019	FT-FY20-102019-004655-A	<1	FT-FY20-102019-004655-B	<1
WS-004656	4/29/2019	4/29/2020	1	Health Suite	In health suite 104A across from room 104G	WF-04292019-004656	11/6/2019	FT-FY20-102019-004656-A	<1	FT-FY20-102019-004656-B	<1
WS-004657	4/29/2019	4/29/2020	1	Health Suite	In health suite in treatment room 104J	WF-04292019-004657	11/6/2019	FT-FY20-102019-004657-A	<1	FT-FY20-102019-004657-B	<1
WS-004659	4/29/2019	4/29/2020	1	Health Suite	In health suite in dentist room 104E	WF-04292019-004659	11/6/2019	FT-FY20-102019-004659-A	<1	FT-FY20-102019-004659-B	<1
WS-004660	4/29/2019	4/29/2020	1	Health Suite	In health suite in exam room 104L	WF-04292019-004660	11/6/2019	FT-FY20-102019-004660-A	<1	FT-FY20-102019-004660-B	<1
WS-004661	4/29/2019	4/29/2020	1	Break Room	In break room 102E	WF-04292019-004661	11/6/2019	FT-FY20-102019-004661-A	<1	FT-FY20-102019-004661-B	<1
WS-004662	4/29/2019	4/29/2020	1	Break Room	In break room 102G	WF-04292019-004662	11/6/2019	FT-FY20-102019-004662-A	<1	FT-FY20-102019-004662-B	<1
WS-004663	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 106C	WF-10092019-004663	11/6/2019	FT-FY20-102019-004663-A	<1	FT-FY20-102019-004663-B	<1
WS-004664	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 110	WF-10092019-004664	11/6/2019	FT-FY20-102019-004664-A	<1	FT-FY20-102019-004664-B	<1
WS-004665	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 110 Right	WF-04292019-004665	11/6/2019	FT-FY20-102019-004665-A	<1	FT-FY20-102019-004665-B	<1
WS-004666	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 112 Mid	WF-10092019-004666	11/6/2019	FT-FY20-102019-004666-A	<1	FT-FY20-102019-004666-B	<1
WS-004667	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 112 Right	WF-04292019-004667	11/6/2019	FT-FY20-102019-004667-A	<1	FT-FY20-102019-004667-B	<1
WS-004668	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 114 Mid	WF-10092019-004668	11/6/2019	FT-FY20-102019-004668-A	<1	FT-FY20-102019-004668-B	<1
WS-004669	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 114 Right	WF-04292019-004669	11/6/2019	FT-FY20-102019-004669-A	<1	FT-FY20-102019-004669-B	<1
WS-004670	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 116 Mid	WF-10092019-004670	11/6/2019	FT-FY20-102019-004670-A	<1	FT-FY20-102019-004670-B	<1
WS-004671	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 116 Right	WF-04292019-004671	11/6/2019	FT-FY20-102019-004671-A	<1	FT-FY20-102019-004671-B	<1
WS-004672	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 118	WF-10092019-004672	11/6/2019	FT-FY20-102019-004672-A	<1	FT-FY20-102019-004672-B	<1
WS-004673	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 118	WF-04292019-004673	11/6/2019	FT-FY20-102019-004673-A	<1	FT-FY20-102019-004673-B	<1
WS-004674	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 120 Mid	WF-10092019-004674	11/6/2019	FT-FY20-102019-004674-A	<1	FT-FY20-102019-004674-B	<1
WS-004675	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 120 Right	WF-04292019-004675	11/6/2019	FT-FY20-102019-004675-A	<1	FT-FY20-102019-004675-B	<1
WS-004676	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 122	WF-10092019-004676	11/6/2019	FT-FY20-102019-004676-A	<1	FT-FY20-102019-004676-B	<1
WS-004677	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 122	WF-04292019-004677	11/6/2019	FT-FY20-102019-004677-A	<1	FT-FY20-102019-004677-B	<1
WS-004678	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 130 High Left	WF-04292019-004678	11/6/2019	FT-FY20-102019-004678-A	<1	FT-FY20-102019-004678-B	<1
WS-004679	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 130 Low Right	WF-04292019-004679	11/6/2019	FT-FY20-102019-004679-A	<1	FT-FY20-102019-004679-B	<1
WS-004680	4/29/2019	4/29/2020	1	Break Room	In break room 132 Mid	WF-04292019-004680	11/6/2019	FT-FY20-102019-004680-A	<1	FT-FY20-102019-004680-B	<1
WS-004682	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 124	WF-10092019-004682	11/6/2019	FT-FY20-102019-004682-A	<1	FT-FY20-102019-004682-B	<1
WS-004683	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 124	WF-04292019-004683	11/6/2019	FT-FY20-102019-004683-A	<1	FT-FY20-102019-004683-B	<1
WS-004684	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 126	WF-10092019-004684	11/6/2019	FT-FY20-102019-004684-A	<1	FT-FY20-102019-004684-B	<1
WS-004685	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 126	WF-04292019-004685	11/6/2019	FT-FY20-102019-004685-A	<1	FT-FY20-102019-004685-B	<1
WS-004689	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 136 Mid	WF-10092019-004689	11/6/2019	FT-FY20-102019-004689-A	<1	FT-FY20-102019-004689-B	<1
WS-004690	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 136 Right	WF-04292019-004690	11/6/2019	FT-FY20-102019-004690-A	<1	FT-FY20-102019-004690-B	<1
WS-004691	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 138 Mid	WF-10092019-004691	11/6/2019	FT-FY20-102019-004691-A	<1	FT-FY20-102019-004691-B	<1

WS-004692	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 138	Right	WF-04292019-004692	11/6/2019	FT-FY20-102019-004692-A	<1	FT-FY20-102019-004692-B	<1
WS-004693	4/29/2019	4/29/2020	1	Cooler	In cafeteria 129	Low Left	WF-04292019-004693	11/6/2019	FT-FY20-102019-004693-A	<1	FT-FY20-102019-004693-B	<1
WS-004694	4/29/2019	4/29/2020	1	Cooler	In cafeteria 129	High Right	WF-04292019-004694	11/6/2019	FT-FY20-102019-004694-A	<1	FT-FY20-102019-004694-B	<1
WS-004698	4/29/2019	4/29/2020	1	Ice Maker	In kitchen room 131B (ice maker)		WF-04292019-004698	11/6/2019	FT-FY20-102019-004698-A	<1	FT-FY20-102019-004698-B	<1
WS-004700	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 123	High Right	WF-04292019-004700	11/6/2019	FT-FY20-102019-004700-A	<1	FT-FY20-102019-004700-B	<1
WS-004701	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 123	Low Left	WF-04292019-004701	11/6/2019	FT-FY20-102019-004701-A	<1	FT-FY20-102019-004701-B	<1
WS-004703	4/29/2019	4/29/2020	1	Break Room	In break room 121B		WF-04292019-004703	11/6/2019	FT-FY20-102019-004703-A	<1	FT-FY20-102019-004703-B	<1
WS-004704	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 117		WF-10092019-004704	11/6/2019	FT-FY20-102019-004704-A	<1	FT-FY20-102019-004704-B	<1
WS-004705	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 117	Right	WF-04292019-004705	11/6/2019	FT-FY20-102019-004705-A	<1	FT-FY20-102019-004705-B	<1
WS-004706	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 113		WF-10092019-004706	11/6/2019	FT-FY20-102019-004706-A	<1	FT-FY20-102019-004706-B	<1
WS-004707	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 113		WF-04292019-004707	11/6/2019	FT-FY20-102019-004707-A	<1	FT-FY20-102019-004707-B	<1
WS-004708	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 111		WF-10092019-004708	11/6/2019	FT-FY20-102019-004708-A	<1	FT-FY20-102019-004708-B	<1
WS-004709	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 111	Right	WF-04292019-004709	11/6/2019	FT-FY20-102019-004709-A	<1	FT-FY20-102019-004709-B	<1
WS-004710	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 109		WF-10092019-004710	11/6/2019	FT-FY20-102019-004710-A	<1	FT-FY20-102019-004710-B	<1
WS-004711	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 109		WF-04292019-004711	11/6/2019	FT-FY20-102019-004711-A	<1	FT-FY20-102019-004711-B	<1
WS-004712	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 107		WF-10092019-004712	11/6/2019	FT-FY20-102019-004712-A	<1	FT-FY20-102019-004712-B	<1
WS-004713	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 107	Right	WF-04292019-004713	11/6/2019	FT-FY20-102019-004713-A	<1	FT-FY20-102019-004713-B	<1
WS-004714	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 115		WF-10092019-004714	11/6/2019	FT-FY20-102019-004714-A	<1	FT-FY20-102019-004714-B	<1
WS-004715	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 115		WF-04292019-004715	11/6/2019	FT-FY20-102019-004715-A	<1	FT-FY20-102019-004715-B	<1
WS-004716	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 142	Right	WF-04292019-004716	11/6/2019	FT-FY20-102019-004716-A	<1	FT-FY20-102019-004716-B	<1
WS-004717	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 142		WF-10092019-004717	11/6/2019	FT-FY20-102019-004717-A	<1	FT-FY20-102019-004717-B	<1
WS-004718	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 144		WF-10092019-004718	11/6/2019	FT-FY20-102019-004718-A	<1	FT-FY20-102019-004718-B	<1
WS-004719	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 144		WF-04292019-004719	11/6/2019	FT-FY20-102019-004719-A	<1	FT-FY20-102019-004719-B	<1
WS-004720	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 146		WF-10092019-004720	11/6/2019	FT-FY20-102019-004720-A	<1	FT-FY20-102019-004720-B	<1
WS-004721	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 146		WF-04292019-004721	11/6/2019	FT-FY20-102019-004721-A	<1	FT-FY20-102019-004721-B	<1
WS-004725	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-04292019-004725	11/6/2019	FT-FY20-102019-004725-A	<1	FT-FY20-102019-004725-B	<1
WS-004726	4/29/2019	4/29/2020	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-04292019-004726	11/6/2019	FT-FY20-102019-004726-A	<1	FT-FY20-102019-004726-B	<1
WS-004728	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 104	Right	WF-10092019-004728	11/6/2019	FT-FY20-102019-004728-A	<1	FT-FY20-102019-004728-B	<1
WS-004729	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 104	Right	WF-04292019-004729	11/6/2019	FT-FY20-102019-004729-A	<1	FT-FY20-102019-004729-B	<1
WS-004730	10/9/2019	10/9/2020	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-10092019-004730	11/6/2019	FT-FY20-102019-004730-A	<1	FT-FY20-102019-004730-B	<1
WS-004731	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-04292019-004731	11/6/2019	FT-FY20-102019-004731-A	<1	FT-FY20-102019-004731-B	<1
WS-004732	4/29/2019	4/29/2020	1	Health Suite	In health suite in feeding room 104C	Right	WF-04292019-004732	11/6/2019	FT-FY20-102019-004732-A	4	FT-FY20-102019-004732-B	<1
WS-004737	4/29/2019	4/29/2020	1	Combo Fountain	In classroom 106C		WF-04292019-004737	11/6/2019	FT-FY20-102019-004737-A	<1	FT-FY20-102019-004737-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004699	7/2/2019	7/2/2020	1	Food Prep Sink	In kitchen room 131A	WF-07022019-004699	11/6/2019	FT-FY20-102019-004699-A	<1	FT-FY20-102019-004699-B	<1

FY20 Filter Test

Greater than 5ppb - Devices requiring remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
-----------	-----------------------	------------------------	-------	-------------	-----------------	---------------------	---------------	----------------------	----------------------------------	----------------------	----------------------------------

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004733	4/29/2019	4/29/2020	1	Health Suite	In health suite in feeding room 104C Left	WF-04292019-004733	11/6/2019	FT-FY20-102019-004733-A	10.2	FT-FY20-102019-004733-B	<1

FY20 Filter Test (After Plumbing Check)

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004733	11/7/2019	11/7/2020	1	Health Suite	In health suite in feeding room 104C Left	WF-11072019-004733	11/17/2019	FT-FY20-112019-004733-A	<1	FT-FY20-112019-004733-B	<1