



# RIVER TERRACE LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/9/2016	WS- 004737	Fountain	1	In room 106-C	WT-042916-4754- A	< 1	WT-042916-4754- B	< 1				
2	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004736	Classroom	1	In room 101g north wall	WT-042916-4753- A	9.2	WT-042916-4753- B	< 1				
3	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004735	Break Room	1	In 102-G break room ice maker	WT-042916-4752- A	< 1	WT-042916-4752- B	< 1				
4	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004734	Break Room	1	In room 102-E	WT-042916-4751- A	< 1	WT-042916-4751- B	< 1				
5	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/7/2016	WS- 004733	Health Suite	1	In health suite 104-C sink Left	WT-042916-4750- A	< 1	WT-042916-4750- B	< 1				
6	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/7/2016	WS- 004732	Health Suite	1	In health suite 104-C sink Right	WT-042916-4749- A	< 1	WT-042916-4749- B	< 1				
7	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004731	Fountain	1	In classroom 101-G Right	WT-042916-4748- A	< 1	WT-042916-4748- B	< 1				
8	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004730	Classroom	1	In classroom 101-G	WT-042916-4747- A	< 1	WT-042916-4747- B	< 1				
9	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004729	Fountain	1	In classroom 104 Right	WT-042916-4746- A	< 1	WT-042916-4746- B	< 1				
10	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004728	Classroom	1	In classroom 104	WT-042916-4745- A	< 1	WT-042916-4745- B	< 1				
11	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004727	Classroom	1	In classroom 104	WT-042916-4744- A	< 1	WT-042916-4744- B	< 1				
12	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004726	Cooler	1	In hallway adjacent to room 101-A Low	WT-042916-4743- A	< 1	WT-042916-4743- B	< 1				
13	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004725	Cooler	1	In hallway adjacent to room 101-A High	WT-042916-4742- A	< 1	WT-042916-4742- B	< 1				
14	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004724	Other	1	In room 101-A ice maker	WT-042916-4741- A	< 1	WT-042916-4741- B	< 1				
15	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004723	Classroom	1	In room 101-A Right	WT-042916-4740- A	< 1	WT-042916-4740- B	< 1				
16	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004722	Classroom	1	In room 101-A Left	WT-042916-4739- A	< 1	WT-042916-4739- B	< 1				
17	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004721	Fountain	1	In room 146	WT-042916-4738- A	< 1	WT-042916-4738- B	< 1				
18	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004720	Classroom	1	In room 146	WT-042916-4737- A	< 1	WT-042916-4737- B	< 1				
19	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004719	Fountain	1	In room 144	WT-042916-4736- A	< 1	WT-042916-4736- B	< 1				
20	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004718	Classroom	1	In room 144	WT-042916-4735- A	< 1	WT-042916-4735- B	< 1				
21	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004717	Classroom	1	In classroom 142	WT-042916-4734- A	< 1	WT-042916-4734- B	< 1				
22	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004716	Fountain	1	In classroom 142 Right	WT-042916-4733- A	< 1	WT-042916-4733- B	< 1				
23	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004715	Fountain	1	In room 115	WT-042916-4732- A	< 1	WT-042916-4732- B	< 1				
24	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004714	Classroom	1	In room 115	WT-042916-4731- A	< 1	WT-042916-4731- B	< 1				
25	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004713	Fountain	1	In classroom 107 Right	WT-042916-4730- A	< 1	WT-042916-4730- B	< 1				
26	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004712	Classroom	1	In classroom 107	WT-042916-4729- A	< 1	WT-042916-4729- B	< 1				
27	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004711	Fountain	1	In room 109	WT-042916-4728- A	< 1	WT-042916-4728- B	< 1				
28	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004710	Classroom	1	In room 109	WT-042916-4727- A	< 1	WT-042916-4727- B	< 1				
29	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004709	Fountain	1	In classroom 111 Right	WT-042916-4726- A	< 1	WT-042916-4726- B	< 1				
30	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004708	Classroom	1	In classroom 111	WT-042916-4725- A	< 1	WT-042916-4725- B	< 1				
31	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004707	Fountain	1	In room 113	WT-042916-4724- A	< 1	WT-042916-4724- B	< 1				
32	RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004706	Classroom	1	In room 113	WT-042916-4723- A	< 1	WT-042916-4723- B	< 1				



# RIVER TERRACE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
33 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004705	Fountain	1	In classroom 117 Right	WT-042916-4722- A	< 1	WT-042916-4722- B	< 1				
34 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004704	Classroom	1	In classroom 117	WT-042916-4721- A	< 1	WT-042916-4721- B	< 1				
35 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004703	Break Room	1	In break room 121-B sink	WT-042916-4720- A	< 1	WT-042916-4720- B	< 1				
36 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004702	Break Room	1	In break room ice maker	WT-042916-4719- A	< 1	WT-042916-4719- B	< 1				
37 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004701	Cooler	1	In hallway adjacent to room 123 Left Low	WT-042916-4718- A	< 1	WT-042916-4718- B	< 1				
38 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004700	Cooler	1	In hallway adjacent to room 123 High	WT-042916-4717- A	< 1	WT-042916-4717- B	< 1				
39 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004699	Kitchen	1	In kitchen section 131-A	WT-042916-4716- A	< 1	WT-042916-4716- B	< 1				
40 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004698	Kitchen	1	In kitchen ice machine	WT-042916-4715- A	< 1	WT-042916-4715- B	< 1				
41 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004697	Kitchen	1	In room 131-B Right	WT-042916-4714- A	< 1	WT-042916-4714- B	< 1				
42 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004696	Kitchen	1	In room 131-B Mid	WT-042916-4713- A	< 1	WT-042916-4713- B	< 1				
43 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004695	Kitchen	1	In room 131-B Left	WT-042916-4712- A	< 1	WT-042916-4712- B	< 1				
44 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004694	Cooler	1	In cafeteria 129 High	WT-042916-4711- A	< 1	WT-042916-4711- B	< 1				
45 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004693	Cooler	1	In cafeteria 129 Low	WT-042916-4710- A	< 1	WT-042916-4710- B	< 1				
46 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004692	Fountain	1	In classroom 138 Right	WT-042916-4709- A	1	WT-042916-4709- B	< 1				
47 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004691	Classroom	1	In classroom 138 Mid	WT-042916-4708- A	1.1	WT-042916-4708- B	< 1				
48 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004690	Fountain	1	In classroom 136 Right	WT-042916-4707- A	< 1	WT-042916-4707- B	< 1				
49 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004689	Classroom	1	In classroom 136 Mid	WT-042916-4706- A	< 1	WT-042916-4706- B	< 1				
50 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004688	Other	1	In room 134	WT-042916-4705- A	< 1	WT-042916-4705- B	< 1				
51 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004687	Classroom	1	In room 134 Left	WT-042916-4704- A	< 1	WT-042916-4704- B	< 1				
52 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004686	Classroom	1	In room 134 Right	WT-042916-4703- A	< 1	WT-042916-4703- B	< 1				
53 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004685	Fountain	1	In room 126	WT-042916-4702- A	< 1	WT-042916-4702- B	< 1				
54 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004684	Classroom	1	In room 126	WT-042916-4701- A	< 1	WT-042916-4701- B	< 1				
55 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004683	Fountain	1	In room 124	WT-042916-4700- A	< 1	WT-042916-4700- B	< 1				
56 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004682	Classroom	1	In room 124	WT-042916-4699- A	< 1	WT-042916-4699- B	< 1				
57 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004681	Break Room	1	Refrigerator outlet in break room 132 Right	WT-042916-4698- A	< 1	WT-042916-4698- B	< 1				
58 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004680	Break Room	1	In break room 123 Mid	WT-042916-4697- A	< 1	WT-042916-4697- B	< 1				
59 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/7/2016	WS- 004679	Cooler	1	In hallway adjacent to room 130 Right Low	WT-042916-4696- A	< 1	WT-042916-4696- B	< 1				
60 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004678	Cooler	1	In hallway adjacent to room 130 Left High	WT-042916-4695- A	< 1	WT-042916-4695- B	< 1				
61 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004677	Fountain	1	In room 122	WT-042916-4694- A	< 1	WT-042916-4694- B	< 1				
62 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004676	Classroom	1	In room 122	WT-042916-4693- A	< 1	WT-042916-4693- B	< 1				
63 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004675	Fountain	1	In classroom 120 Right	WT-042916-4692- A	< 1	WT-042916-4692- B	< 1				
64 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004674	Classroom	1	In classroom 120 Mid	WT-042916-4691- A	< 1	WT-042916-4691- B	< 1				



# RIVER TERRACE LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
65 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004673	Fountain	1	In room 118	WT-042916-4690- A	< 1	WT-042916-4690- B	< 1				
66 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004672	Classroom	1	In room 118	WT-042916-4689- A	< 1	WT-042916-4689- B	< 1				
67 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004671	Fountain	1	In classroom 116 Right	WT-042916-4688- A	1.3	WT-042916-4688- B	< 1				
68 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004670	Classroom	1	In classroom 116 Mid	WT-042916-4687- A	3.6	WT-042916-4687- B	< 1				
69 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004669	Fountain	1	In classroom 114 Right	WT-042916-4686- A	< 1	WT-042916-4686- B	< 1				
70 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004668	Classroom	1	In classroom 114 Mid	WT-042916-4685- A	< 1	WT-042916-4685- B	< 1				
71 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004667	Fountain	1	In classroom 112 Right	WT-042916-4684- A	< 1	WT-042916-4684- B	< 1				
72 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004666	Classroom	1	In classroom 112 Mid	WT-042916-4683- A	< 1	WT-042916-4683- B	< 1				
73 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004665	Fountain	1	In classroom 110 Right	WT-042916-4682- A	< 1	WT-042916-4682- B	< 1				
74 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004664	Classroom	1	In classroom 110	WT-042916-4681- A	< 1	WT-042916-4681- B	< 1				
75 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004663	Classroom	1	In classroom 106-C	WT-042916-4680- A	< 1	WT-042916-4680- B	< 1				
76 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004662	Break Room	1	In room 102-G	WT-042916-4679- A	< 1	WT-042916-4679- B	< 1				
77 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004661	Break Room	1	In room 102-E Mid	WT-042916-4678- A	< 1	WT-042916-4678- B	< 1				
78 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004660	Health Suite	1	In room 104-L	WT-042916-4677- A	7.7	WT-042916-4677- B	< 1				
79 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004659	Health Suite	1	In room 104-E Mid	WT-042916-4676- A	< 1	WT-042916-4676- B	< 1				
80 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004658	Health Suite	1	In room 104-G Mid	WT-042916-4675- A	< 1	WT-042916-4675- B	< 1				
81 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004657	Health Suite	1	In health suite room 104-J	WT-042916-4674- A	< 1	WT-042916-4674- B	< 1				
82 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004656	Health Suite	1	In health suite adjacent to 104-G Mid	WT-042916-4673- A	< 1	WT-042916-4673- B	< 1				
83 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004655	Cooler	1	In hallway next to health suite Low	WT-042916-4672- A	< 1	WT-042916-4672- B	< 1				
84 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004654	Cooler	1	In hallway next to health suite High	WT-042916-4671- A	< 1	WT-042916-4671- B	< 1				
85 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004653	Cooler	1	In room 106 pool room Low	WT-042916-4670- A	< 1	WT-042916-4670- B	< 1				
86 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004652	Cooler	1	In 106 pool room High	WT-042916-4669- A	< 1	WT-042916-4669- B	< 1				
87 RIVER TERRACE SPECIAL EDUCATION SCHOOL	5/6/2016	WS- 004651	Utility	1	In boiler room	WT-042916-4668- A	5.1	WT-042916-4668- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.