



River Terrace Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004660	6/8/17	6/8/18	1	Health Suite	In health suite in exam room 104L	WF-62017-004660	12/4/17	FT-FY18--62017-004660-A	<1	FT-FY18--62017-004660-B	<1	
WS-004661	6/9/17	6/9/18	1	Break Room	In break room 102E	WF-62017-004661	12/4/17	FT-FY18--62017-004661-A	<1	FT-FY18--62017-004661-B	<1	
WS-004663	11/10/17	11/10/18	1	Combo Faucet	In classroom 106C	WF-112017-004663	12/4/17	FT-FY18-112017-004663-A	<1	FT-FY18-112017-004663-B	<1	
WS-004664	11/10/17	11/10/18	1	Combo Faucet	In classroom 110	WF-112017-004664	12/4/17	FT-FY18-112017-004664-A	<1	FT-FY18-112017-004664-B	<1	
WS-004665	6/8/17	6/8/18	1	Combo Fountain	In classroom 110	Right	WF-62017-004665	12/4/17	FT-FY18--62017-004665-A	<1	FT-FY18--62017-004665-B	<1
WS-004667	6/8/17	6/8/18	1	Combo Fountain	In classroom 112	Right	WF-62017-004667	12/4/17	FT-FY18--62017-004667-A	<1	FT-FY18--62017-004667-B	<1
WS-004669	6/8/17	6/8/18	1	Combo Fountain	In classroom 114	Right	WF-62017-004669	12/4/17	FT-FY18--62017-004669-A	<1	FT-FY18--62017-004669-B	<1
WS-004670	11/10/17	11/10/18	1	Combo Faucet	In classroom 116	Mid	WF-112017-004670	12/4/17	FT-FY18-112017-004670-A	<1	FT-FY18-112017-004670-B	<1
WS-004671	6/8/17	6/8/18	1	Combo Fountain	In classroom 116	Right	WF-62017-004671	12/4/17	FT-FY18--62017-004671-A	<1	FT-FY18--62017-004671-B	<1
WS-004673	6/8/17	6/8/18	1	Combo Fountain	In classroom 118		WF-62017-004673	12/4/17	FT-FY18--62017-004673-A	<1	FT-FY18--62017-004673-B	<1
WS-004674	11/10/17	11/10/18	1	Combo Faucet	In classroom 120	Mid	WF-112017-004674	12/4/17	FT-FY18-112017-004674-A	<1	FT-FY18-112017-004674-B	<1
WS-004675	6/8/17	6/8/18	1	Combo Fountain	In classroom 120	Right	WF-62017-004675	12/4/17	FT-FY18--62017-004675-A	<1	FT-FY18--62017-004675-B	<1
WS-004691	11/10/17	11/10/18	1	Combo Faucet	In classroom 138	Mid	WF-112017-004691	12/4/17	FT-FY18-112017-004691-A	<1	FT-FY18-112017-004691-B	<1
WS-004698	6/8/17	6/8/18	1	Ice Maker	In kitchen room 131B (ice maker)		WF-62017-004698	12/4/17	FT-FY18--62017-004698-A	<1	FT-FY18--62017-004698-B	<1
WS-004704	11/10/17	11/10/18	1	Combo Faucet	In classroom 117		WF-112017-004704	12/4/17	FT-FY18-112017-004704-A	<1	FT-FY18-112017-004704-B	<1
WS-004707	6/8/17	6/8/18	1	Combo Fountain	In classroom 113		WF-62017-004707	12/4/17	FT-FY18--62017-004707-A	<1	FT-FY18--62017-004707-B	<1
WS-004709	6/8/17	6/8/18	1	Combo Fountain	In classroom 111	Right	WF-62017-004709	12/4/17	FT-FY18--62017-004709-A	<1	FT-FY18--62017-004709-B	<1
WS-004715	6/8/17	6/8/18	1	Combo Fountain	In classroom 115		WF-62017-004715	12/4/17	FT-FY18--62017-004715-A	<1	FT-FY18--62017-004715-B	<1
WS-004716	6/8/17	6/8/18	1	Combo Fountain	In classroom 142	Right	WF-62017-004716	12/4/17	FT-FY18--62017-004716-A	<1	FT-FY18--62017-004716-B	<1
WS-004726	6/9/17	6/9/18	1	Cooler	In hallway adjacent to room 101-A	Right Low	WF-62017-004726	12/4/17	FT-FY18--62017-004726-A	<1	FT-FY18--62017-004726-B	<1
WS-004730	11/10/17	11/10/18	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-112017-004730	12/4/17	FT-FY18-112017-004730-A	<1	FT-FY18-112017-004730-B	<1
WS-004731	6/9/17	6/9/18	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-62017-004731	12/4/17	FT-FY18--62017-004731-A	<1	FT-FY18--62017-004731-B	<1
WS-004732	6/8/17	6/8/18	1	Health Suite	In health suite in feeding room 104C	Right	WF-62017-004732	12/4/17	FT-FY18--62017-004732-A	<1	FT-FY18--62017-004732-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-004699	1	Food Prep Sink	In kitchen room 131A	12/4/17	FT-FY18-102017-004699-A	<1	FT-FY18-102017-004699-B	<1	