



River Terrace EC Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-004652	5/7/2018	5/7/2019	1	Cooler	In pool room 106	High Left	WF-05072018-004652	11/9/2018	FT-FY19-102018-004652-A	< 1	FT-FY19-102018-004652-B	< 1
WS-004653	5/7/2018	5/7/2019	1	Cooler	In pool room 106	Low Right	WF-05072018-004653	11/9/2018	FT-FY19-102018-004653-A	< 1	FT-FY19-102018-004653-B	< 1
WS-004654	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 104	High Left	WF-05072018-004654	11/9/2018	FT-FY19-102018-004654-A	< 1	FT-FY19-102018-004654-B	< 1
WS-004655	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 104	Low Right	WF-05072018-004655	11/9/2018	FT-FY19-102018-004655-A	< 1	FT-FY19-102018-004655-B	< 1
WS-004656	5/7/2018	5/7/2019	1	Health Suite	In health suite 104A across from room 104G		WF-05072018-004656	11/9/2018	FT-FY19-102018-004656-A	< 1	FT-FY19-102018-004656-B	< 1
WS-004657	5/7/2018	5/7/2019	1	Health Suite	In health suite in treatment room 104J		WF-05072018-004657	11/9/2018	FT-FY19-102018-004657-A	< 1	FT-FY19-102018-004657-B	< 1
WS-004659	5/7/2018	5/7/2019	1	Health Suite	In health suite in dentist room 104E		WF-05072018-004659	11/9/2018	FT-FY19-102018-004659-A	< 1	FT-FY19-102018-004659-B	< 1
WS-004660	5/7/2018	5/7/2019	1	Health Suite	In health suite in exam room 104L		WF-05072018-004660	11/9/2018	FT-FY19-102018-004660-A	< 1	FT-FY19-102018-004660-B	< 1
WS-004661	5/7/2018	5/7/2019	1	Break Room	In break room 102E		WF-05072018-004661	11/9/2018	FT-FY19-102018-004661-A	< 1	FT-FY19-102018-004661-B	< 1
WS-004662	5/7/2018	5/7/2019	1	Break Room	In break room 102G		WF-05072018-004662	11/9/2018	FT-FY19-102018-004662-A	< 1	FT-FY19-102018-004662-B	< 1
WS-004663	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 106C		WF-10152018-004663	11/9/2018	FT-FY19-102018-004663-A	< 1	FT-FY19-102018-004663-B	< 1
WS-004664	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 110		WF-10152018-004664	11/9/2018	FT-FY19-102018-004664-A	< 1	FT-FY19-102018-004664-B	< 1
WS-004665	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 110	Right	WF-05072018-004665	11/9/2018	FT-FY19-102018-004665-A	< 1	FT-FY19-102018-004665-B	< 1
WS-004666	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 112	Mid	WF-10152018-004666	11/9/2018	FT-FY19-102018-004666-A	< 1	FT-FY19-102018-004666-B	< 1
WS-004667	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 112	Right	WF-05072018-004667	11/9/2018	FT-FY19-102018-004667-A	< 1	FT-FY19-102018-004667-B	< 1
WS-004668	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 114	Mid	WF-10152018-004668	11/9/2018	FT-FY19-102018-004668-A	< 1	FT-FY19-102018-004668-B	< 1
WS-004669	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 114	Right	WF-05072018-004669	11/9/2018	FT-FY19-102018-004669-A	< 1	FT-FY19-102018-004669-B	< 1
WS-004670	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 116	Mid	WF-10152018-004670	11/9/2018	FT-FY19-102018-004670-A	< 1	FT-FY19-102018-004670-B	< 1
WS-004671	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 116	Right	WF-05072018-004671	11/9/2018	FT-FY19-102018-004671-A	< 1	FT-FY19-102018-004671-B	< 1
WS-004672	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 118		WF-10152018-004672	11/9/2018	FT-FY19-102018-004672-A	< 1	FT-FY19-102018-004672-B	< 1
WS-004673	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 118		WF-05072018-004673	11/9/2018	FT-FY19-102018-004673-A	< 1	FT-FY19-102018-004673-B	< 1
WS-004674	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 120	Mid	WF-10152018-004674	11/9/2018	FT-FY19-102018-004674-A	< 1	FT-FY19-102018-004674-B	< 1
WS-004675	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 120	Right	WF-05072018-004675	11/9/2018	FT-FY19-102018-004675-A	< 1	FT-FY19-102018-004675-B	< 1
WS-004676	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 122		WF-10152018-004676	11/9/2018	FT-FY19-102018-004676-A	< 1	FT-FY19-102018-004676-B	< 1
WS-004677	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 122		WF-05072018-004677	11/9/2018	FT-FY19-102018-004677-A	< 1	FT-FY19-102018-004677-B	< 1
WS-004678	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 130	High Left	WF-05072018-004678	11/9/2018	FT-FY19-102018-004678-A	< 1	FT-FY19-102018-004678-B	< 1
WS-004679	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 130	Low Right	WF-05072018-004679	11/9/2018	FT-FY19-102018-004679-A	< 1	FT-FY19-102018-004679-B	< 1
WS-004680	5/7/2018	5/7/2019	1	Break Room	In break room 132	Mid	WF-05072018-004680	11/9/2018	FT-FY19-102018-004680-A	< 1	FT-FY19-102018-004680-B	< 1
WS-004682	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 124		WF-10152018-004682	11/9/2018	FT-FY19-102018-004682-A	< 1	FT-FY19-102018-004682-B	< 1
WS-004683	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 124		WF-05072018-004683	11/9/2018	FT-FY19-102018-004683-A	< 1	FT-FY19-102018-004683-B	< 1
WS-004684	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 126		WF-10152018-004684	11/9/2018	FT-FY19-102018-004684-A	< 1	FT-FY19-102018-004684-B	< 1
WS-004685	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 126		WF-05072018-004685	11/9/2018	FT-FY19-102018-004685-A	< 1	FT-FY19-102018-004685-B	< 1

WS- 004689	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 136	Mid	WF-10152018-004689	11/9/2018	FT-FY19-102018-004689-A	< 1	FT-FY19-102018-004689-B	< 1
WS- 004690	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 136	Right	WF-05072018-004690	11/9/2018	FT-FY19-102018-004690-A	< 1	FT-FY19-102018-004690-B	< 1
WS- 004691	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 138	Mid	WF-10152018-004691	11/9/2018	FT-FY19-102018-004691-A	< 1	FT-FY19-102018-004691-B	< 1
WS- 004692	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 138	Right	WF-05072018-004692	11/9/2018	FT-FY19-102018-004692-A	< 1	FT-FY19-102018-004692-B	< 1
WS- 004693	5/7/2018	5/7/2019	1	Cooler	In cafeteria 129	Low Left	WF-05072018-004693	11/9/2018	FT-FY19-102018-004693-A	< 1	FT-FY19-102018-004693-B	< 1
WS- 004694	5/7/2018	5/7/2019	1	Cooler	In cafeteria 129	High Right	WF-05072018-004694	11/9/2018	FT-FY19-102018-004694-A	< 1	FT-FY19-102018-004694-B	< 1
WS- 004698	5/7/2018	5/7/2019	1	Ice Maker	In kitchen room 131B (ice maker)		WF-05072018-004698	11/9/2018	FT-FY19-102018-004698-A	< 1	FT-FY19-102018-004698-B	< 1
WS- 004700	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 123	High Right	WF-05072018-004700	11/9/2018	FT-FY19-102018-004700-A	< 1	FT-FY19-102018-004700-B	< 1
WS- 004701	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 123	Low Left	WF-05072018-004701	11/9/2018	FT-FY19-102018-004701-A	< 1	FT-FY19-102018-004701-B	< 1
WS- 004703	5/7/2018	5/7/2019	1	Break Room	In break room 121B		WF-05072018-004703	11/9/2018	FT-FY19-102018-004703-A	< 1	FT-FY19-102018-004703-B	< 1
WS- 004704	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 117		WF-10152018-004704	11/9/2018	FT-FY19-102018-004704-A	< 1	FT-FY19-102018-004704-B	< 1
WS- 004705	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 117	Right	WF-05072018-004705	11/9/2018	FT-FY19-102018-004705-A	< 1	FT-FY19-102018-004705-B	< 1
WS- 004706	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 113		WF-10152018-004706	11/9/2018	FT-FY19-102018-004706-A	< 1	FT-FY19-102018-004706-B	< 1
WS- 004707	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 113		WF-05072018-004707	11/9/2018	FT-FY19-102018-004707-A	< 1	FT-FY19-102018-004707-B	< 1
WS- 004708	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 111		WF-10152018-004708	11/9/2018	FT-FY19-102018-004708-A	< 1	FT-FY19-102018-004708-B	< 1
WS- 004709	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 111	Right	WF-05072018-004709	11/9/2018	FT-FY19-102018-004709-A	< 1	FT-FY19-102018-004709-B	< 1
WS- 004710	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 109		WF-10152018-004710	11/9/2018	FT-FY19-102018-004710-A	< 1	FT-FY19-102018-004710-B	< 1
WS- 004711	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 109		WF-05072018-004711	11/9/2018	FT-FY19-102018-004711-A	< 1	FT-FY19-102018-004711-B	< 1
WS- 004712	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 107		WF-10152018-004712	11/9/2018	FT-FY19-102018-004712-A	< 1	FT-FY19-102018-004712-B	< 1
WS- 004713	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 107	Right	WF-05072018-004713	11/9/2018	FT-FY19-102018-004713-A	< 1	FT-FY19-102018-004713-B	< 1
WS- 004714	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 115		WF-10152018-004714	11/9/2018	FT-FY19-102018-004714-A	< 1	FT-FY19-102018-004714-B	< 1
WS- 004715	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 115		WF-05072018-004715	11/9/2018	FT-FY19-102018-004715-A	< 1	FT-FY19-102018-004715-B	< 1
WS- 004716	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 142	Right	WF-05072018-004716	11/9/2018	FT-FY19-102018-004716-A	< 1	FT-FY19-102018-004716-B	< 1
WS- 004717	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 142		WF-10152018-004717	11/9/2018	FT-FY19-102018-004717-A	< 1	FT-FY19-102018-004717-B	< 1
WS- 004718	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 144		WF-10152018-004718	11/9/2018	FT-FY19-102018-004718-A	< 1	FT-FY19-102018-004718-B	< 1
WS- 004719	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 144		WF-05072018-004719	11/9/2018	FT-FY19-102018-004719-A	< 1	FT-FY19-102018-004719-B	< 1
WS- 004720	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 146		WF-10152018-004720	11/9/2018	FT-FY19-102018-004720-A	< 1	FT-FY19-102018-004720-B	< 1
WS- 004721	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 146		WF-05072018-004721	11/9/2018	FT-FY19-102018-004721-A	< 1	FT-FY19-102018-004721-B	< 1
WS- 004725	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 101-A	High Left	WF-05072018-004725	11/9/2018	FT-FY19-102018-004725-A	< 1	FT-FY19-102018-004725-B	< 1
WS- 004726	5/7/2018	5/7/2019	1	Cooler	In hallway adjacent to room 101-A	Low Right	WF-05072018-004726	11/9/2018	FT-FY19-102018-004726-A	< 1	FT-FY19-102018-004726-B	< 1
WS- 004728	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 104	Right	WF-10152018-004728	11/9/2018	FT-FY19-102018-004728-A	< 1	FT-FY19-102018-004728-B	< 1
WS- 004729	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 104	Right	WF-05072018-004729	11/9/2018	FT-FY19-102018-004729-A	< 1	FT-FY19-102018-004729-B	< 1
WS- 004730	10/15/2018	10/15/2019	1	Combo Faucet	In classroom 101G second clockwise from entry door		WF-10152018-004730	11/9/2018	FT-FY19-102018-004730-A	< 1	FT-FY19-102018-004730-B	< 1
WS- 004731	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 101G second clockwise from entry door	Right	WF-05072018-004731	11/9/2018	FT-FY19-102018-004731-A	< 1	FT-FY19-102018-004731-B	< 1
WS- 004732	5/7/2018	5/7/2019	1	Health Suite	In health suite in feeding room 104C	Right	WF-05072018-004732	11/9/2018	FT-FY19-102018-004732-A	< 1	FT-FY19-102018-004732-B	< 1
WS- 004733	5/7/2018	5/7/2019	1	Health Suite	In health suite in feeding room 104C	Left	WF-05072018-004733	11/9/2018	FT-FY19-102018-004733-A	< 1	FT-FY19-102018-004733-B	< 1
WS- 004737	5/7/2018	5/7/2019	1	Combo Fountain	In classroom 106C		WF-05072018-004737	11/9/2018	FT-FY19-102018-004737-A	< 1	FT-FY19-102018-004737-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 004699	1	Food Prep Sink	In kitchen room 131A	11/9/2018	FT-FY19-102018-004699-A	< 1	FT-FY19-102018-004699-B	< 1