



Ron Brown High School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003183	3/14/2022	3/14/2023	1	Ice Maker	In kitchen (Icemaker)	WF-03142022-003183	2/13/2023	FT-FY23-01262023-003183-A	<1	FT-FY23-01262023-003183-B	<1
WS- 003184	3/14/2022	3/14/2023	1	Cooler	In hallway across from athletic storage 1241	WF-03142022-003184	2/13/2023	FT-FY23-01262023-003184-A	<1	FT-FY23-01262023-003184-B	<1
WS- 003185	3/14/2022	3/14/2023	1	Bottle Filler	In hallway across from athletic storage 1241 (bottle filler)	WF-03142022-003185	2/13/2023	FT-FY23-01262023-003185-A	<1	FT-FY23-01262023-003185-B	<1
WS- 003186	3/14/2022	3/14/2023	1	Cooler	In hallway across from coaches room 1245	WF-03142022-003186	2/13/2023	FT-FY23-01262023-003186-A	<1	FT-FY23-01262023-003186-B	<1
WS- 003187	3/14/2022	3/14/2023	1	Bottle Filler	In hallway across from coaches room 1245 (bottle filler)	WF-03142022-003187	2/13/2023	FT-FY23-01262023-003187-A	<1	FT-FY23-01262023-003187-B	<1
WS- 003188	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to restroom 1181	WF-03142022-003188	2/13/2023	FT-FY23-01262023-003188-A	<1	FT-FY23-01262023-003188-B	<1
WS- 003190	3/14/2022	3/14/2023	1	Cooler	In hallway adjacent to restroom 1141	WF-03142022-003190	2/13/2023	FT-FY23-01262023-003190-A	<1	FT-FY23-01262023-003190-B	<1
WS- 003191	3/14/2022	3/14/2023	1	Bottle Filler	In hallway adjacent to restroom 1141 (bottle filler)	WF-03142022-003191	2/13/2023	FT-FY23-01262023-003191-A	<1	FT-FY23-01262023-003191-B	<1
WS- 003192	3/14/2022	3/14/2023	1	Health Suite	In health suite in treatment room 113	WF-03142022-003192	2/13/2023	FT-FY23-01262023-003192-A	<1	FT-FY23-01262023-003192-B	<1
WS- 003193	3/14/2022	3/14/2023	1	Break Room	In staff lounge 1174	WF-03142022-003193	2/13/2023	FT-FY23-01262023-003193-A	<1	FT-FY23-01262023-003193-B	<1
WS- 003210	3/14/2022	3/14/2023	2	Bottle Filler	In hallway adjacent to room 2131	WF-03142022-003210	2/13/2023	FT-FY23-01262023-003210-A	<1	FT-FY23-01262023-003210-B	<1
WS- 003211	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room 2131 Low	WF-03142022-003211	2/13/2023	FT-FY23-01262023-003211-A	<1	FT-FY23-01262023-003211-B	<1
WS- 003212	3/14/2022	3/14/2023	2	Bottle Filler	In hallway adjacent to room 2171	WF-03142022-003212	2/13/2023	FT-FY23-01262023-003212-A	<1	FT-FY23-01262023-003212-B	<1
WS- 003213	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to room 2171	WF-03142022-003213	2/13/2023	FT-FY23-01262023-003213-A	<1	FT-FY23-01262023-003213-B	<1
WS- 003214	3/14/2022	3/14/2023	2	Bottle Filler	In hallway adjacent to stairwell B7	WF-03142022-003214	2/13/2023	FT-FY23-01262023-003214-A	<1	FT-FY23-01262023-003214-B	<1
WS- 003215	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to stairwell B7	WF-03142022-003215	2/13/2023	FT-FY23-01262023-003215-A	<1	FT-FY23-01262023-003215-B	<1
WS- 003216	3/14/2022	3/14/2023	2	Bottle Filler	In hallway adjacent to auditorium	WF-03142022-003216	2/13/2023	FT-FY23-01262023-003216-A	<1	FT-FY23-01262023-003216-B	<1
WS- 003217	3/14/2022	3/14/2023	2	Cooler	In hallway adjacent to auditorium	WF-03142022-003217	2/13/2023	FT-FY23-01262023-003217-A	<1	FT-FY23-01262023-003217-B	<1
WS- 003219	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to stairwell A1	WF-03142022-003219	2/13/2023	FT-FY23-01262023-003219-A	<1	FT-FY23-01262023-003219-B	<1
WS- 003221	3/14/2022	3/14/2023	3	Cooler	In hallway adjacent to room 3182	WF-03142022-003221	2/13/2023	FT-FY23-01262023-003221-A	<1	FT-FY23-01262023-003221-B	<1
WS- 003222	3/14/2022	3/14/2023	2	Break Room	In staff lounge 2183	WF-03142022-003222	2/13/2023	FT-FY23-01262023-003222-A	<1	FT-FY23-01262023-003222-B	<1
WS- 003223	3/14/2022	3/14/2023	3	Break Room	In staff lounge 3183	WF-03142022-003223	2/13/2023	FT-FY23-01262023-003223-A	<1	FT-FY23-01262023-003223-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003182	1/23/2023	1/23/2024	1	Food Prep Sink	In kitchen adjacent to the freezer	WF-01232023-003182	2/13/2023	FT-FY23-01262023-003182-A	<1	FT-FY23-01262023-003182-B	<1