



Ron Brown HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003183	4/11/2019	4/11/2020	1	Ice Maker	In kitchen (Icemaker)	WF-04112019-003183	1/8/2020	FT-FY20-122019-003183-A	<1	FT-FY20-122019-003183-B	<1
WS-003184	4/11/2019	4/11/2020	1	Cooler	In hallway across from athletic storage 1241	WF-04112019-003184	1/8/2020	FT-FY20-122019-003184-A	<1	FT-FY20-122019-003184-B	<1
WS-003185	4/11/2019	4/11/2020	1	Bottle Filler	In hallway across from athletic storage 1241 (bottle filler)	WF-04112019-003185	1/8/2020	FT-FY20-122019-003185-A	<1	FT-FY20-122019-003185-B	<1
WS-003186	4/11/2019	4/11/2020	1	Cooler	In hallway across from coaches room 1245	WF-04112019-003186	1/8/2020	FT-FY20-122019-003186-A	<1	FT-FY20-122019-003186-B	<1
WS-003187	4/11/2019	4/11/2020	1	Bottle Filler	In hallway across from coaches room 1245 (bottle filler)	WF-04112019-003187	1/8/2020	FT-FY20-122019-003187-A	<1	FT-FY20-122019-003187-B	<1
WS-003188	4/11/2019	4/11/2020	1	Cooler	In hallway adjacent to restroom 1181	WF-04112019-003188	1/8/2020	FT-FY20-122019-003188-A	<1	FT-FY20-122019-003188-B	<1
WS-003189	4/11/2019	4/11/2020	1	Bottle Filler	In hallway adjacent to restroom 1181 (bottle filler)	WF-04112019-003189	1/8/2020	FT-FY20-122019-003189-A	<1	FT-FY20-122019-003189-B	<1
WS-003190	4/11/2019	4/11/2020	1	Cooler	In hallway adjacent to restroom 1141	WF-04112019-003190	1/8/2020	FT-FY20-122019-003190-A	<1	FT-FY20-122019-003190-B	<1
WS-003191	4/11/2019	4/11/2020	1	Bottle Filler	In hallway adjacent to restroom 1141 (bottle filler)	WF-04112019-003191	1/8/2020	FT-FY20-122019-003191-A	<1	FT-FY20-122019-003191-B	<1
WS-003192	4/11/2019	4/11/2020	1	Health Suite	In health suite in treatment room 113	WF-04112019-003192	1/8/2020	FT-FY20-122019-003192-A	<1	FT-FY20-122019-003192-B	<1
WS-003193	4/11/2019	4/11/2020	1	Break Room	In staff lounge 1174	WF-04112019-003193	1/8/2020	FT-FY20-122019-003193-A	<1	FT-FY20-122019-003193-B	<1
WS-003210	4/11/2019	4/11/2020	2	Bottle Filler	In hallway adjacent to room 2131	WF-04112019-003210	1/8/2020	FT-FY20-122019-003210-A	<1	FT-FY20-122019-003210-B	<1
WS-003211	4/11/2019	4/11/2020	2	Cooler	In hallway adjacent to room 2131	WF-04112019-003211	1/8/2020	FT-FY20-122019-003211-A	<1	FT-FY20-122019-003211-B	<1
WS-003212	4/11/2019	4/11/2020	2	Bottle Filler	In hallway adjacent to room 2171	WF-04112019-003212	1/8/2020	FT-FY20-122019-003212-A	<1	FT-FY20-122019-003212-B	<1
WS-003213	4/11/2019	4/11/2020	2	Cooler	In hallway adjacent to room 2171	WF-04112019-003213	1/8/2020	FT-FY20-122019-003213-A	<1	FT-FY20-122019-003213-B	<1
WS-003214	4/11/2019	4/11/2020	2	Bottle Filler	In hallway adjacent to stairwell B7	WF-04112019-003214	1/8/2020	FT-FY20-122019-003214-A	<1	FT-FY20-122019-003214-B	<1
WS-003215	4/11/2019	4/11/2020	2	Cooler	In hallway adjacent to stairwell B7	WF-04112019-003215	1/8/2020	FT-FY20-122019-003215-A	<1	FT-FY20-122019-003215-B	<1
WS-003216	4/11/2019	4/11/2020	2	Bottle Filler	In hallway adjacent to auditorium	WF-04112019-003216	1/8/2020	FT-FY20-122019-003216-A	<1	FT-FY20-122019-003216-B	<1
WS-003217	4/11/2019	4/11/2020	2	Cooler	In hallway adjacent to auditorium	WF-04112019-003217	1/8/2020	FT-FY20-122019-003217-A	<1	FT-FY20-122019-003217-B	<1
WS-003218	4/11/2019	4/11/2020	3	Bottle Filler	In hallway adjacent to stairwell A1	WF-04112019-003218	1/8/2020	FT-FY20-122019-003218-A	<1	FT-FY20-122019-003218-B	<1
WS-003219	4/11/2019	4/11/2020	3	Cooler	In hallway adjacent to stairwell A1	WF-04112019-003219	1/8/2020	FT-FY20-122019-003219-A	<1	FT-FY20-122019-003219-B	<1
WS-003220	4/11/2019	4/11/2020	3	Bottle Filler	In hallway adjacent to room 3182	WF-04112019-003220	1/8/2020	FT-FY20-122019-003220-A	<1	FT-FY20-122019-003220-B	<1
WS-003221	4/11/2019	4/11/2020	3	Cooler	In hallway adjacent to room 3182	WF-04112019-003221	1/8/2020	FT-FY20-122019-003221-A	<1	FT-FY20-122019-003221-B	<1
WS-003222	4/11/2019	4/11/2020	2	Break Room	In staff lounge 2183	WF-04112019-003222	1/8/2020	FT-FY20-122019-003222-A	<1	FT-FY20-122019-003222-B	<1
WS-003223	4/11/2019	4/11/2020	3	Break Room	In staff lounge 3183	WF-04112019-003223	1/8/2020	FT-FY20-122019-003223-A	<1	FT-FY20-122019-003223-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-003182	7/17/2019	7/17/2020	1	Food Prep Sink	In kitchen adjacent to the freezer	WF-07172019-003182	1/8/2020	FT-FY20-122019-003182-A	<1	FT-FY20-122019-003182-B	<1