



Ron Brown Junior High School Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation											
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003183	6/28/17	6/28/18	1	Ice Maker	In kitchen (Icemaker)	WF-62017-003183	12/13/17	FT-FY18--62017-003183-A	<1	FT-FY18--62017-003183-B	<1
WS- 003185	6/28/17	6/28/18	1	Bottle Filler	In hallway across from athletic storage 1241 (bottle filler) High	WF-62017-003185	12/13/17	FT-FY18--62017-003185-A	<1	FT-FY18--62017-003185-B	<1
WS- 003186	6/28/17	6/28/18	1	Cooler	In hallway across from coaches room 1245 Low	WF-62017-003186	12/13/17	FT-FY18--62017-003186-A	<1	FT-FY18--62017-003186-B	<1
WS- 003192	6/28/17	6/28/18	1	Health Suite	In health suite in treatment room 113	WF-62017-003192	12/13/17	FT-FY18--62017-003192-A	<1	FT-FY18--62017-003192-B	<1
WS- 003193	6/28/17	6/28/18	1	Break Room	In staff lounge 1174	WF-62017-003193	12/13/17	FT-FY18--62017-003193-A	<1	FT-FY18--62017-003193-B	<1
WS- 003210	8/14/17	8/14/18	2	Bottle Filler	In hallway adjacent to room 2131 High	WF-82017-003210	12/13/17	FT-FY18--82017-003210-A	<1	FT-FY18--82017-003210-B	<1
WS- 003211	8/14/17	8/14/18	2	Cooler	In hallway adjacent to room 2131 Low	WF-82017-003211	12/13/17	FT-FY18--82017-003211-A	<1	FT-FY18--82017-003211-B	<1
WS- 003214	8/14/17	8/14/18	2	Bottle Filler	In hallway adjacent to stairwell B7 High	WF-82017-003214	12/13/17	FT-FY18--82017-003214-A	<1	FT-FY18--82017-003214-B	<1
WS- 003220	8/14/17	8/14/18	3	Bottle Filler	In hallway adjacent to room 3182 High	WF-82017-003220	12/13/17	FT-FY18--82017-003220-A	<1	FT-FY18--82017-003220-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation									
RECORD ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 003182	1	Food Prep Sink	In kitchen adjacent to the freezer	12/13/17	FT-FY18-102017-003182-A	<1	FT-FY18-102017-003182-B	<1	