



Ron Brown HS Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003183	6/12/2018	6/12/2019	1	Ice Maker	In kitchen (Icemaker)	WF-06122018-003183	12/24/2018	FT-FY19-122018-003183-A	<1	FT-FY19-122018-003183-B	<1
WS- 003184	6/12/2018	6/12/2019	1	Cooler	In hallway across from athletic storage 1241	WF-06122018-003184	12/24/2018	FT-FY19-122018-003184-A	<1	FT-FY19-122018-003184-B	<1
WS- 003185	6/12/2018	6/12/2019	1	Bottle Filler	In hallway across from athletic storage 1241 (bottle filler)	WF-06122018-003185	12/24/2018	FT-FY19-122018-003185-A	<1	FT-FY19-122018-003185-B	<1
WS- 003186	6/12/2018	6/12/2019	1	Cooler	In hallway across from coaches room 1245	WF-06122018-003186	12/24/2018	FT-FY19-122018-003186-A	<1	FT-FY19-122018-003186-B	<1
WS- 003187	6/12/2018	6/12/2019	1	Bottle Filler	In hallway across from coaches room 1245 (bottle filler)	WF-06122018-003187	12/24/2018	FT-FY19-122018-003187-A	<1	FT-FY19-122018-003187-B	<1
WS- 003188	6/12/2018	6/12/2019	1	Cooler	In hallway adjacent to restroom 1181	WF-06122018-003188	12/24/2018	FT-FY19-122018-003188-A	<1	FT-FY19-122018-003188-B	<1
WS- 003190	6/12/2018	6/12/2019	1	Cooler	In hallway adjacent to restroom 1141	WF-06122018-003190	12/24/2018	FT-FY19-122018-003190-A	<1	FT-FY19-122018-003190-B	<1
WS- 003191	6/12/2018	6/12/2019	1	Bottle Filler	In hallway adjacent to restroom 1141 (bottle filler)	WF-06122018-003191	12/24/2018	FT-FY19-122018-003191-A	<1	FT-FY19-122018-003191-B	<1
WS- 003192	6/12/2018	6/12/2019	1	Health Suite	In health suite in treatment room 113	WF-06122018-003192	12/24/2018	FT-FY19-122018-003192-A	<1	FT-FY19-122018-003192-B	<1
WS- 003193	6/12/2018	6/12/2019	1	Break Room	In staff lounge 1174	WF-06122018-003193	12/24/2018	FT-FY19-122018-003193-A	<1	FT-FY19-122018-003193-B	<1
WS- 003210	6/12/2018	6/12/2019	2	Bottle Filler	In hallway adjacent to room 2131	WF-06122018-003210	12/24/2018	FT-FY19-122018-003210-A	<1	FT-FY19-122018-003210-B	<1
WS- 003211	6/12/2018	6/12/2019	2	Cooler	In hallway adjacent to room 2131 Low	WF-06122018-003211	12/24/2018	FT-FY19-122018-003211-A	<1	FT-FY19-122018-003211-B	<1
WS- 003212	12/11/2018	12/11/2019	2	Bottle Filler	In hallway adjacent to room 2171	WF-12112018-003212	12/24/2018	FT-FY19-122018-003212-A	<1	FT-FY19-122018-003212-B	<1
WS- 003213	12/11/2018	12/11/2019	2	Cooler	In hallway adjacent to room 2171	WF-12112018-003213	12/24/2018	FT-FY19-122018-003213-A	<1	FT-FY19-122018-003213-B	<1
WS- 003214	6/12/2018	6/12/2019	2	Bottle Filler	In hallway adjacent to stairwell B7	WF-06122018-003214	12/24/2018	FT-FY19-122018-003214-A	<1	FT-FY19-122018-003214-B	<1
WS- 003215	6/12/2018	6/12/2019	2	Cooler	In hallway adjacent to stairwell B7	WF-06122018-003215	12/24/2018	FT-FY19-122018-003215-A	<1	FT-FY19-122018-003215-B	<1
WS- 003216	6/12/2018	6/12/2019	2	Bottle Filler	In hallway adjacent to auditorium	WF-06122018-003216	12/24/2018	FT-FY19-122018-003216-A	<1	FT-FY19-122018-003216-B	<1
WS- 003217	6/12/2018	6/12/2019	2	Cooler	In hallway adjacent to auditorium	WF-06122018-003217	12/24/2018	FT-FY19-122018-003217-A	<1	FT-FY19-122018-003217-B	<1
WS- 003218	6/12/2018	6/12/2019	3	Bottle Filler	In hallway adjacent to stairwell A1	WF-06122018-003218	12/24/2018	FT-FY19-122018-003218-A	<1	FT-FY19-122018-003218-B	<1
WS- 003219	6/12/2018	6/12/2019	3	Cooler	In hallway adjacent to stairwell A1	WF-06122018-003219	12/24/2018	FT-FY19-122018-003219-A	<1	FT-FY19-122018-003219-B	<1
WS- 003220	6/12/2018	6/12/2019	3	Bottle Filler	In hallway adjacent to room 3182	WF-06122018-003220	12/24/2018	FT-FY19-122018-003220-A	<1	FT-FY19-122018-003220-B	<1
WS- 003221	6/12/2018	6/12/2019	3	Cooler	In hallway adjacent to room 3182	WF-06122018-003221	12/24/2018	FT-FY19-122018-003221-A	<1	FT-FY19-122018-003221-B	<1
WS- 003222	6/12/2018	6/12/2019	2	Break Room	In staff lounge 2183	WF-06122018-003222	12/24/2018	FT-FY19-122018-003222-A	<1	FT-FY19-122018-003222-B	<1
WS- 003223	6/12/2018	6/12/2019	3	Break Room	In staff lounge 3183	WF-06122018-003223	12/24/2018	FT-FY19-122018-003223-A	<1	FT-FY19-122018-003223-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation								
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003182	1	Food Prep Sink	In kitchen adjacent to the freezer	12/24/2018	FT-FY19-122018-003182-A	<1	FT-FY19-122018-003182-B	<1