



ROOSEVELT HS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003002	8/24/2016	Basement	Cooler	In hallway across from room BG09	High Left	FT-82016-003002-A	< 1	FT-82016-003002-B	< 1
2	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003003	8/24/2016	Basement	Cooler	In hallway across from room BG09	Low Right	FT-82016-003003-A	< 1	FT-82016-003003-B	< 1
3	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003004	8/24/2016	Basement	Cooler	In hallway across from room BG07	High Left	FT-82016-003004-A	< 1	FT-82016-003004-B	< 1
4	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003005	8/24/2016	Basement	Cooler	In hallway across from room BG07	Low Right	FT-82016-003005-A	< 1	FT-82016-003005-B	< 1
5	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003008	8/24/2016	Basement	Food Prep Sink	In kitchen BG19 on island		FT-82016-003008-A	< 1	FT-82016-003008-B	< 1
6	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003009	8/24/2016	Basement	Food Prep Sink	In kitchen BG19 across from freezer		FT-82016-003009-A	2	FT-82016-003009-B	< 1
7	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003011	8/24/2016	Basement	Cooler	In cafeteria BG21	High Left	FT-82016-003011-A	< 1	FT-82016-003011-B	< 1
8	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003012	8/24/2016	Basement	Bottle Filler	In cafeteria BG21 (bottle filler)	High Left	FT-82016-003012-A	< 1	FT-82016-003012-B	< 1
9	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003013	8/24/2016	Basement	Cooler	In cafeteria BG21	Low Right	FT-82016-003013-A	< 1	FT-82016-003013-B	< 1
10	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003014	8/24/2016	Basement	Food Prep Sink	In kitchen AG39		FT-82016-003014-A	< 1	FT-82016-003014-B	< 1
11	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003015	8/24/2016	Basement	Food Prep Sink	In kitchen AG39 across from freezer		FT-82016-003015-A	< 1	FT-82016-003015-B	< 1
12	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003017	8/24/2016	Basement	Health Suite	In health suite CG08		FT-82016-003017-A	< 1	FT-82016-003017-B	< 1
13	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003018	8/24/2016	Basement	Health Suite	In health suite break room across from CG20		FT-82016-003018-A	< 1	FT-82016-003018-B	< 1
14	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003019	8/24/2016	Basement	Health Suite	In health suite dentist room CG30		FT-82016-003019-A	< 1	FT-82016-003019-B	< 1
15	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003020	8/24/2016	Basement	Cooler	In poolside adjacent to women's locker	High Left	FT-82016-003020-A	< 1	FT-82016-003020-B	< 1
16	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003022	8/24/2016	Basement	Cooler	In poolside adjacent to men's locker room	High Left	FT-82016-003022-A	< 1	FT-82016-003022-B	< 1
17	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003023	8/24/2016	Basement	Fountain	In poolside adjacent to men's locker room	Low Right	FT-82016-003023-A	< 1	FT-82016-003023-B	< 1
18	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003024	8/24/2016	Basement	Cooler	In poolside adjacent to women's locker room	Low Right	FT-82016-003024-A	< 1	FT-82016-003024-B	< 1
19	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003025	8/24/2016	Ground Floor	Cooler	In poolside hallway across from stair c1	High Left	FT-82016-003025-A	< 1	FT-82016-003025-B	< 1
20	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003026	8/24/2016	Ground Floor	Cooler	In poolside hallway across from stair C1	Low Right	FT-82016-003026-A	< 1	FT-82016-003026-B	< 1
21	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003027	8/24/2016	1	Cooler	In hallway adjacent to restroom A108	High Left	FT-82016-003027-A	< 1	FT-82016-003027-B	< 1
22	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003028	8/24/2016	1	Cooler	In hallway adjacent to restroom A108	Low Right	FT-82016-003028-A	< 1	FT-82016-003028-B	< 1
23	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003029	8/24/2016	1	Cooler	In hallway adjacent to restroom B120	High Left	FT-82016-003029-A	< 1	FT-82016-003029-B	< 1
24	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003030	8/24/2016	1	Cooler	In hallway adjacent to restroom B118	Low Right	FT-82016-003030-A	< 1	FT-82016-003030-B	< 1

25	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003031	8/24/2016	1	Cooler	In hallway adjacent to restroom B156	High Left	FT-82016-003031-A	< 1	FT-82016-003031-B	< 1
26	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003032	8/24/2016	1	Cooler	In hallway adjacent to restroom B156	Low Right	FT-82016-003032-A	< 1	FT-82016-003032-B	< 1
27	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003033	8/24/2016	1	Cooler	In hallway across from gym C104	High Left	FT-82016-003033-A	< 1	FT-82016-003033-B	< 1
28	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003034	8/24/2016	1	Cooler	In hallway across from gym C104	Low Right	FT-82016-003034-A	< 1	FT-82016-003034-B	< 1
29	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003035	8/24/2016	1	Cooler	In hallway adjacent to room C111	High Left	FT-82016-003035-A	< 1	FT-82016-003035-B	< 1
30	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003036	8/24/2016	1	Cooler	In hallway adjacent to room C111	Low Right	FT-82016-003036-A	2	FT-82016-003036-B	< 1
31	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003037	8/24/2016	1	Cooler	In hallway across from restroom C110	High Left	FT-82016-003037-A	< 1	FT-82016-003037-B	< 1
32	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003038	8/24/2016	1	Cooler	In hallway across from restroom C110	Low Right	FT-82016-003038-A	< 1	FT-82016-003038-B	< 1
33	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003039	8/24/2016	1	Cooler	In hallway across from restroom C118	High Left	FT-82016-003039-A	< 1	FT-82016-003039-B	< 1
34	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003040	8/24/2016	1	Bottle Filler	In hallway across from restroom C118 (bottle filler)	High Left	FT-82016-003040-A	< 1	FT-82016-003040-B	< 1
35	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003041	8/24/2016	1	Cooler	In hallway across from restroom C118	Low Right	FT-82016-003041-A	< 1	FT-82016-003041-B	< 1
36	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003043	8/24/2016	2	Cooler	In hallway adjacent to restroom B244	High Left	FT-82016-003043-A	< 1	FT-82016-003043-B	< 1
37	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003044	8/24/2016	2	Cooler	In hallway adjacent to restroom B244	Low Right	FT-82016-003044-A	< 1	FT-82016-003044-B	< 1
38	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003045	8/24/2016	2	Cooler	In hallway adjacent to restroom B214	High Left	FT-82016-003045-A	< 1	FT-82016-003045-B	< 1
39	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003046	8/24/2016	2	Cooler	In hallway adjacent to restroom B214	Low Right	FT-82016-003046-A	< 1	FT-82016-003046-B	< 1
40	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003047	8/24/2016	3	Cooler	In hallway adjacent to restroom B344	High Left	FT-82016-003047-A	< 1	FT-82016-003047-B	< 1
41	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003048	8/24/2016	2	Cooler	In hallway adjacent to restroom B344	Low Right	FT-82016-003048-A	< 1	FT-82016-003048-B	< 1
42	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003049	8/24/2016	3	Cooler	In hallway adjacent to restroom B316	High Left	FT-82016-003049-A	< 1	FT-82016-003049-B	< 1
43	ROOSEVELT HIGH SCHOOL @ MCFARLAND	WS- 003050	8/24/2016	3	Cooler	In hallway adjacent to restroom B316	Low Right	FT-82016-003050-A	< 1	FT-82016-003050-B	< 1