



Roosevelt High School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002031	3/18/2024	3/18/2025	Basement	Bottle Filler	In poolside adjacent to women's locker room	WF-03182024-002031	11/26/2024	FT-FY25-11072024-002031-A	<2	FT-FY25-11072024-002031-B	<2
WS-003002	3/18/2024	3/18/2025	Ground Floor	Cooler	In hallway across from room BG09 High Left	WF-03182024-003002	11/26/2024	FT-FY25-10312024-003002-A	<2	FT-FY25-10312024-003002-B	<2
WS-003003	3/18/2024	3/18/2025	Ground Floor	Cooler	In hallway across from room BG09 Low Right	WF-03182024-003003	11/26/2024	FT-FY25-10312024-003003-A	<2	FT-FY25-10312024-003003-B	<2
WS-003004	3/18/2024	3/18/2025	Ground Floor	Cooler	In hallway across from room BG07 High Left	WF-03182024-003004	11/26/2024	FT-FY25-10312024-003004-A	<2	FT-FY25-10312024-003004-B	<2
WS-003005	3/18/2024	3/18/2025	Ground Floor	Cooler	In hallway across from room BG07 Low Right	WF-03182024-003005	11/26/2024	FT-FY25-10312024-003005-A	<2	FT-FY25-10312024-003005-B	<2
WS-003011	3/18/2024	3/18/2025	Ground Floor	Cooler	In cafeteria BG21 High Left	WF-03182024-003011	11/26/2024	FT-FY25-10312024-003011-A	<2	FT-FY25-10312024-003011-B	<2
WS-003012	3/18/2024	3/18/2025	Ground Floor	Bottle Filler	In cafeteria BG21 (bottle filler)	WF-03182024-003012	11/26/2024	FT-FY25-10312024-003012-A	<2	FT-FY25-10312024-003012-B	<2
WS-003013	3/18/2024	3/18/2025	Ground Floor	Cooler	In cafeteria BG21 Low Right	WF-03182024-003013	11/26/2024	FT-FY25-10312024-003013-A	<2	FT-FY25-10312024-003013-B	<2
WS-003017	3/18/2024	3/18/2025	Ground Floor	Health Suite	In health suite CG08	WF-03182024-003017	11/26/2024	FT-FY25-10312024-003017-A	<2	FT-FY25-10312024-003017-B	<2
WS-003018	3/18/2024	3/18/2025	Ground Floor	Health Suite	In health suite in break room across from CG20	WF-03182024-003018	11/26/2024	FT-FY25-10312024-003018-A	<2	FT-FY25-10312024-003018-B	<2
WS-003019	3/18/2024	3/18/2025	Ground Floor	Health Suite	In health suite in dentist room CG30	WF-03182024-003019	11/26/2024	FT-FY25-10312024-003019-A	<2	FT-FY25-10312024-003019-B	<2
WS-003020	3/18/2024	3/18/2025	Basement	Cooler	In poolside adjacent to women's locker High Left	WF-03182024-003020	11/26/2024	FT-FY25-10312024-003020-A	<2	FT-FY25-10312024-003020-B	<2
WS-003022	3/18/2024	3/18/2025	Basement	Cooler	In poolside adjacent to men's locker room High Left	WF-03182024-003022	11/26/2024	FT-FY25-10312024-003022-A	<2	FT-FY25-10312024-003022-B	<2
WS-003023	3/18/2024	3/18/2025	Basement	Cooler	In poolside adjacent to men's locker room Low Right	WF-03182024-003023	11/26/2024	FT-FY25-10312024-003023-A	<2	FT-FY25-10312024-003023-B	<2
WS-003024	3/18/2024	3/18/2025	Basement	Cooler	In poolside adjacent to women's locker room Low Right	WF-03182024-003024	11/26/2024	FT-FY25-10312024-003024-A	<2	FT-FY25-10312024-003024-B	<2
WS-003027	3/18/2024	3/18/2025	1	Cooler	In hallway adjacent to restroom A108 High Left	WF-03182024-003027	11/26/2024	FT-FY25-10312024-003027-A	<2	FT-FY25-10312024-003027-B	<2
WS-003028	3/18/2024	3/18/2025	1	Cooler	In hallway adjacent to restroom A108 Low Right	WF-03182024-003028	11/26/2024	FT-FY25-10312024-003028-A	<2	FT-FY25-10312024-003028-B	<2
WS-003029	3/18/2024	3/18/2025	1	Cooler	In hallway adjacent to restroom B120 High Left	WF-03182024-003029	11/26/2024	FT-FY25-10312024-003029-A	<2	FT-FY25-10312024-003029-B	<2
WS-003030	3/18/2024	3/18/2025	1	Cooler	In hallway adjacent to restroom B120 Low Right	WF-03182024-003030	11/26/2024	FT-FY25-10312024-003030-A	<2	FT-FY25-10312024-003030-B	<2
WS-003033	3/18/2024	3/18/2025	1	Cooler	In hallway across from gym C104 High Left	WF-03182024-003033	11/26/2024	FT-FY25-10312024-003033-A	<2	FT-FY25-10312024-003033-B	<2
WS-003034	3/18/2024	3/18/2025	1	Cooler	In hallway across from gym C104 Low Right	WF-03182024-003034	11/26/2024	FT-FY25-10312024-003034-A	<2	FT-FY25-10312024-003034-B	<2
WS-003037	3/18/2024	3/18/2025	1	Cooler	In hallway across from restroom C110 High Left	WF-03182024-003037	11/26/2024	FT-FY25-10312024-003037-A	<2	FT-FY25-10312024-003037-B	<2
WS-003038	3/18/2024	3/18/2025	1	Cooler	In hallway across from restroom C110 Low Right	WF-03182024-003038	11/26/2024	FT-FY25-10312024-003038-A	<2	FT-FY25-10312024-003038-B	<2
WS-003043	3/18/2024	3/18/2025	2	Cooler	In hallway adjacent to restroom B244 High Left	WF-03182024-003043	11/26/2024	FT-FY25-10312024-003043-A	<2	FT-FY25-10312024-003043-B	<2
WS-003044	3/18/2024	3/18/2025	2	Cooler	In hallway adjacent to restroom B244 Low Right	WF-03182024-003044	11/26/2024	FT-FY25-10312024-003044-A	<2	FT-FY25-10312024-003044-B	<2
WS-003045	3/18/2024	3/18/2025	2	Cooler	In hallway adjacent to restroom B214 High Left	WF-03182024-003045	11/26/2024	FT-FY25-10312024-003045-A	<2	FT-FY25-10312024-003045-B	<2
WS-003046	3/18/2024	3/18/2025	2	Cooler	In hallway adjacent to restroom B214 Low Right	WF-03182024-003046	11/26/2024	FT-FY25-10312024-003046-A	<2	FT-FY25-10312024-003046-B	<2
WS-003047	3/18/2024	3/18/2025	3	Cooler	In hallway adjacent to restroom B344 High Left	WF-03182024-003047	11/26/2024	FT-FY25-10312024-003047-A	<2	FT-FY25-10312024-003047-B	<2
WS-003048	3/18/2024	3/18/2025	3	Cooler	In hallway adjacent to restroom B344 Low Right	WF-03182024-003048	11/26/2024	FT-FY25-10312024-003048-A	<2	FT-FY25-10312024-003048-B	<2
WS-003049	3/18/2024	3/18/2025	3	Cooler	In hallway adjacent to restroom B316 High Left	WF-03182024-003049	11/26/2024	FT-FY25-10312024-003049-A	<2	FT-FY25-10312024-003049-B	<2
WS-003050	3/18/2024	3/18/2025	3	Cooler	In hallway adjacent to restroom B316 Low Right	WF-03182024-003050	11/26/2024	FT-FY25-10312024-003050-A	<2	FT-FY25-10312024-003050-B	<2
WS-003052	9/19/2024	9/19/2025	1	Classroom Faucet	In classroom (life skills) A149 Left	WF-09192024-003052	11/26/2024	FT-FY25-10312024-003052-A	<2	FT-FY25-10312024-003052-B	<2
WS-003054	3/18/2024	3/18/2025	Basement	Bottle Filler	In poolside adjacent to men's locker room	WF-03182024-003054	11/26/2024	FT-FY25-10312024-003054-A	<2	FT-FY25-10312024-003054-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003008	12/6/2023	12/6/2024	Basement	Food Prep Sink	In kitchen BG19 on island	WF-12062023-003008	11/26/2024	FT-FY25-10312024-003008-A	<2	FT-FY25-10312024-003008-B	<2
WS- 003014	12/6/2023	12/6/2024	Basement	Food Prep Sink	In kitchen AG39	WF-12062023-003014	11/26/2024	FT-FY25-10312024-003014-A	<2	FT-FY25-10312024-003014-B	<2
WS- 003015	12/6/2023	12/6/2024	Basement	Food Prep Sink	In kitchen AG39 across from freezer	WF-12062023-003015	11/26/2024	FT-FY25-10312024-003015-A	<2	FT-FY25-10312024-003015-B	<2

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003009	12/6/2023	12/6/2024	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-12062023-003009	11/26/2024	FT-FY25-10312024-003009-A	5.7	FT-FY25-10312024-003009-B	<2

After First Re-test (Plumbing Check)

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003009	12/3/2024	12/3/2025	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-12032024-003009	12/17/2024	FT-FY25-12032024-003009-A	6.1	FT-FY25-12032024-003009-B	<2

After Second Re-test (Device Replacement)

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003009	12/31/2024	12/31/2025	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-12312024-003009	1/30/2025	FT-FY25-01022025-003009-A	5.6	FT-FY25-01022025-003009-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.