



# Roosevelt High School Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation

| Record ID | Filter Installed Date | Filter Expiration Date | Floor        | Device Type      | Device Location                                       | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|-----------|-----------------------|------------------------|--------------|------------------|---|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS-003011 | 5/11/2020             | 5/11/2021              | Ground Floor | Cooler           | In cafeteria BG21 High Left                           | WF-05112020-003011  | 4/10/2021     | FT-FY21-042021-003011-A | <1                               | FT-FY21-042021-003011-B | <1                               |
| WS-003012 | 5/11/2020             | 5/11/2021              | Ground Floor | Bottle Filler    | In cafeteria BG21 (bottle filler)                     | WF-05112020-003012  | 4/10/2021     | FT-FY21-042021-003012-A | <1                               | FT-FY21-042021-003012-B | <1                               |
| WS-003013 | 5/11/2020             | 5/11/2021              | Ground Floor | Cooler           | In cafeteria BG21 Low Right                           | WF-05112020-003013  | 4/10/2021     | FT-FY21-042021-003013-A | <1                               | FT-FY21-042021-003013-B | <1                               |
| WS-003017 | 5/11/2020             | 5/11/2021              | Ground Floor | Health Suite     | In health suite CG08                                  | WF-05112020-003017  | 4/10/2021     | FT-FY21-042021-003017-A | <1                               | FT-FY21-042021-003017-B | <1                               |
| WS-003019 | 5/11/2020             | 5/11/2021              | Ground Floor | Health Suite     | In health suite in dentist room CG30                  | WF-05112020-003019  | 4/10/2021     | FT-FY21-042021-003019-A | <1                               | FT-FY21-042021-003019-B | <1                               |
| WS-003020 | 5/11/2020             | 5/11/2021              | Basement     | Cooler           | In poolside adjacent to women's locker High Left      | WF-05112020-003020  | 4/10/2021     | FT-FY21-042021-003020-A | <1                               | FT-FY21-042021-003020-B | <1                               |
| WS-003022 | 5/11/2020             | 5/11/2021              | Basement     | Cooler           | In poolside adjacent to men's locker room High Left   | WF-05112020-003022  | 4/10/2021     | FT-FY21-042021-003022-A | <1                               | FT-FY21-042021-003022-B | <1                               |
| WS-003023 | 5/11/2020             | 5/11/2021              | Basement     | Cooler           | In poolside adjacent to men's locker room Low Right   | WF-05112020-003023  | 4/10/2021     | FT-FY21-042021-003023-A | <1                               | FT-FY21-042021-003023-B | <1                               |
| WS-003024 | 5/11/2020             | 5/11/2021              | Basement     | Cooler           | In poolside adjacent to women's locker room Low Right | WF-05112020-003024  | 4/10/2021     | FT-FY21-042021-003024-A | <1                               | FT-FY21-042021-003024-B | <1                               |
| WS-003027 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom A108 High Left        | WF-05112020-003027  | 4/10/2021     | FT-FY21-042021-003027-A | <1                               | FT-FY21-042021-003027-B | <1                               |
| WS-003028 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom A108 Low Right        | WF-05112020-003028  | 4/10/2021     | FT-FY21-042021-003028-A | <1                               | FT-FY21-042021-003028-B | <1                               |
| WS-003029 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom B120 High Left        | WF-05112020-003029  | 4/10/2021     | FT-FY21-042021-003029-A | <1                               | FT-FY21-042021-003029-B | <1                               |
| WS-003030 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom B120 Low Right        | WF-05112020-003030  | 4/10/2021     | FT-FY21-042021-003030-A | <1                               | FT-FY21-042021-003030-B | <1                               |
| WS-003031 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom B156 High Left        | WF-05112020-003031  | 4/10/2021     | FT-FY21-042021-003031-A | <1                               | FT-FY21-042021-003031-B | <1                               |
| WS-003032 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway adjacent to restroom B156 Low Right        | WF-05112020-003032  | 4/10/2021     | FT-FY21-042021-003032-A | <1                               | FT-FY21-042021-003032-B | <1                               |
| WS-003033 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from gym C104 High Left             | WF-05112020-003033  | 4/10/2021     | FT-FY21-042021-003033-A | <1                               | FT-FY21-042021-003033-B | <1                               |
| WS-003034 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from gym C104 Low Right             | WF-05112020-003034  | 4/10/2021     | FT-FY21-042021-003034-A | <1                               | FT-FY21-042021-003034-B | <1                               |
| WS-003037 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from restroom C110 High Left        | WF-05112020-003037  | 4/10/2021     | FT-FY21-042021-003037-A | <1                               | FT-FY21-042021-003037-B | <1                               |
| WS-003038 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from restroom C110 Low Right        | WF-05112020-003038  | 4/10/2021     | FT-FY21-042021-003038-A | <1                               | FT-FY21-042021-003038-B | <1                               |
| WS-003039 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from restroom C118 High Left        | WF-05112020-003039  | 4/10/2021     | FT-FY21-042021-003039-A | <1                               | FT-FY21-042021-003039-B | <1                               |
| WS-003040 | 5/11/2020             | 5/11/2021              | 1            | Bottle Filler    | In hallway across from restroom C118 (bottle filler)  | WF-05112020-003040  | 4/10/2021     | FT-FY21-042021-003040-A | <1                               | FT-FY21-042021-003040-B | <1                               |
| WS-003041 | 5/11/2020             | 5/11/2021              | 1            | Cooler           | In hallway across from restroom C118 Low Right        | WF-05112020-003041  | 4/10/2021     | FT-FY21-042021-003041-A | <1                               | FT-FY21-042021-003041-B | <1                               |
| WS-003043 | 5/11/2020             | 5/11/2021              | 2            | Cooler           | In hallway adjacent to restroom B244 High Left        | WF-05112020-003043  | 4/10/2021     | FT-FY21-042021-003043-A | <1                               | FT-FY21-042021-003043-B | <1                               |
| WS-003044 | 5/11/2020             | 5/11/2021              | 2            | Cooler           | In hallway adjacent to restroom B244 Low Right        | WF-05112020-003044  | 4/10/2021     | FT-FY21-042021-003044-A | <1                               | FT-FY21-042021-003044-B | <1                               |
| WS-003045 | 5/11/2020             | 5/11/2021              | 2            | Cooler           | In hallway adjacent to restroom B214 High Left        | WF-05112020-003045  | 4/10/2021     | FT-FY21-042021-003045-A | <1                               | FT-FY21-042021-003045-B | <1                               |
| WS-003046 | 5/11/2020             | 5/11/2021              | 2            | Cooler           | In hallway adjacent to restroom B214 Low Right        | WF-05112020-003046  | 4/10/2021     | FT-FY21-042021-003046-A | <1                               | FT-FY21-042021-003046-B | <1                               |
| WS-003047 | 5/11/2020             | 5/11/2021              | 3            | Cooler           | In hallway adjacent to restroom B344 High Left        | WF-05112020-003047  | 4/10/2021     | FT-FY21-042021-003047-A | <1                               | FT-FY21-042021-003047-B | <1                               |
| WS-003048 | 5/11/2020             | 5/11/2021              | 3            | Cooler           | In hallway adjacent to restroom B344 Low Right        | WF-05112020-003048  | 4/10/2021     | FT-FY21-042021-003048-A | <1                               | FT-FY21-042021-003048-B | <1                               |
| WS-003049 | 5/11/2020             | 5/11/2021              | 3            | Cooler           | In hallway adjacent to restroom B316 High Left        | WF-05112020-003049  | 4/10/2021     | FT-FY21-042021-003049-A | <1                               | FT-FY21-042021-003049-B | <1                               |
| WS-003050 | 5/11/2020             | 5/11/2021              | 3            | Cooler           | In hallway adjacent to restroom B316 Low Right        | WF-05112020-003050  | 4/10/2021     | FT-FY21-042021-003050-A | <1                               | FT-FY21-042021-003050-B | <1                               |
| WS-003052 | 10/15/2020            | 10/15/2021             | 1            | Classroom Faucet | In classroom (life skills) A149 Left                  | WF-10152020-003052  | 4/10/2021     | FT-FY21-042021-003052-A | <1                               | FT-FY21-042021-003052-B | <1                               |

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

| Record ID  | Filter Installed Date | Filter Expiration Date | Floor    | Device Type    | Device Location                      | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID    | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID    | FT Final Result - 2nd Draw (ppb) |
|------------|-----------------------|------------------------|----------|----------------|--------------------------------------|---------------------|---------------|-------------------------|----------------------------------|-------------------------|----------------------------------|
| WS- 003006 | 2/2/2021              | 2/2/2022               | Basement | Food Prep Sink | In kitchen BG19 adjacent to entrance | WF-02022021-003006  | 4/10/2021     | FT-FY21-042021-003006-A | <1                               | FT-FY21-042021-003006-B | <1                               |
| WS- 003008 | 2/2/2021              | 2/2/2022               | Basement | Food Prep Sink | In kitchen BG19 on island            | WF-02022021-003008  | 4/10/2021     | FT-FY21-042021-003008-A | <1                               | FT-FY21-042021-003008-B | <1                               |
| WS- 003009 | 2/2/2021              | 2/2/2022               | Basement | Food Prep Sink | In kitchen BG19 across from freezer  | WF-02022021-003009  | 4/10/2021     | FT-FY21-042021-003009-A | 1.4                              | FT-FY21-042021-003009-B | <1                               |
| WS- 003010 | 2/2/2021              | 2/2/2022               | Basement | Food Prep Sink | In kitchen BG19 buffet sink          | WF-02022021-003010  | 4/10/2021     | FT-FY21-042021-003010-A | <1                               | FT-FY21-042021-003010-B | <1                               |
| WS- 003014 | 2/12/2021             | 2/12/2022              | Basement | Food Prep Sink | In kitchen AG39                      | WF-02122021-003014  | 4/10/2021     | FT-FY21-042021-003014-A | <1                               | FT-FY21-042021-003014-B | <1                               |
| WS- 003015 | 2/2/2021              | 2/2/2022               | Basement | Food Prep Sink | In kitchen AG39 across from freezer  | WF-02022021-003015  | 4/10/2021     | FT-FY21-042021-003015-A | <1                               | FT-FY21-042021-003015-B | <1                               |