



Roosevelt HS Lead in Water Test Results



FY20 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003004	5/21/2019	5/21/2020	Ground Floor	Cooler	In hallway across from room BG07	High Left	WF-05212019-003004	1/15/2020	FT-FY20-012020-003004-A	<1	FT-FY20-012020-003004-B	<1
WS- 003005	5/21/2019	5/21/2020	Ground Floor	Cooler	In hallway across from room BG07	Low Right	WF-05212019-003005	1/15/2020	FT-FY20-012020-003005-A	<1	FT-FY20-012020-003005-B	<1
WS- 003011	5/21/2019	5/21/2020	Ground Floor	Cooler	In cafeteria BG21	High Left	WF-05212019-003011	1/15/2020	FT-FY20-012020-003011-A	<1	FT-FY20-012020-003011-B	<1
WS- 003012	5/21/2019	5/21/2020	Ground Floor	Bottle Filler	In cafeteria BG21 (bottle filler)		WF-05212019-003012	1/15/2020	FT-FY20-012020-003012-A	<1	FT-FY20-012020-003012-B	<1
WS- 003013	5/21/2019	5/21/2020	Ground Floor	Cooler	In cafeteria BG21	Low Right	WF-05212019-003013	1/15/2020	FT-FY20-012020-003013-A	<1	FT-FY20-012020-003013-B	<1
WS- 003017	5/21/2019	5/21/2020	Ground Floor	Health Suite	In health suite CG08		WF-05212019-003017	1/15/2020	FT-FY20-012020-003017-A	<1	FT-FY20-012020-003017-B	<1
WS- 003018	5/21/2019	5/21/2020	Ground Floor	Health Suite	In health suite in break room across from CG20		WF-05212019-003018	1/15/2020	FT-FY20-012020-003018-A	<1	FT-FY20-012020-003018-B	<1
WS- 003019	5/21/2019	5/21/2020	Ground Floor	Health Suite	In health suite in dentist room CG30		WF-05212019-003019	1/15/2020	FT-FY20-012020-003019-A	1.4	FT-FY20-012020-003019-B	<1
WS- 003020	5/21/2019	5/21/2020	Basement	Cooler	In poolside adjacent to women's locker	High Left	WF-05212019-003020	1/15/2020	FT-FY20-012020-003020-A	<1	FT-FY20-012020-003020-B	<1
WS- 003022	5/21/2019	5/21/2020	Basement	Cooler	In poolside adjacent to men's locker room	High Left	WF-05212019-003022	1/15/2020	FT-FY20-012020-003022-A	<1	FT-FY20-012020-003022-B	<1
WS- 003023	5/21/2019	5/21/2020	Basement	Cooler	In poolside adjacent to men's locker room	Low Right	WF-05212019-003023	1/15/2020	FT-FY20-012020-003023-A	<1	FT-FY20-012020-003023-B	<1
WS- 003024	5/21/2019	5/21/2020	Basement	Cooler	In poolside adjacent to women's locker room	Low Right	WF-05212019-003024	1/15/2020	FT-FY20-012020-003024-A	<1	FT-FY20-012020-003024-B	<1
WS- 003025	5/21/2019	5/21/2020	Ground Floor	Cooler	In poolside hallway across from stair c1	High Left	WF-05212019-003025	1/15/2020	FT-FY20-012020-003025-A	<1	FT-FY20-012020-003025-B	<1
WS- 003026	5/21/2019	5/21/2020	Ground Floor	Cooler	In poolside hallway across from stair C1	Low Right	WF-05212019-003026	1/15/2020	FT-FY20-012020-003026-A	<1	FT-FY20-012020-003026-B	<1
WS- 003027	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom A108	High Left	WF-05212019-003027	1/15/2020	FT-FY20-012020-003027-A	<1	FT-FY20-012020-003027-B	<1
WS- 003028	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom A108	Low Right	WF-05212019-003028	1/15/2020	FT-FY20-012020-003028-A	<1	FT-FY20-012020-003028-B	<1
WS- 003029	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom B120	High Left	WF-05212019-003029	1/15/2020	FT-FY20-012020-003029-A	<1	FT-FY20-012020-003029-B	<1
WS- 003030	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom B120	Low Right	WF-05212019-003030	1/15/2020	FT-FY20-012020-003030-A	<1	FT-FY20-012020-003030-B	<1
WS- 003031	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom B156	High Left	WF-05212019-003031	1/15/2020	FT-FY20-012020-003031-A	<1	FT-FY20-012020-003031-B	<1
WS- 003032	5/21/2019	5/21/2020	1	Cooler	In hallway adjacent to restroom B156	Low Right	WF-05212019-003032	1/15/2020	FT-FY20-012020-003032-A	<1	FT-FY20-012020-003032-B	<1
WS- 003037	5/21/2019	5/21/2020	1	Cooler	In hallway across from restroom C110	High Left	WF-05212019-003037	1/15/2020	FT-FY20-012020-003037-A	<1	FT-FY20-012020-003037-B	<1
WS- 003038	5/21/2019	5/21/2020	1	Cooler	In hallway across from restroom C110	Low Right	WF-05212019-003038	1/15/2020	FT-FY20-012020-003038-A	<1	FT-FY20-012020-003038-B	<1
WS- 003039	5/21/2019	5/21/2020	1	Cooler	In hallway across from restroom C118	High Left	WF-05212019-003039	1/15/2020	FT-FY20-012020-003039-A	<1	FT-FY20-012020-003039-B	<1
WS- 003040	5/21/2019	5/21/2020	1	Bottle Filler	In hallway across from restroom C118 (bottle filler)		WF-05212019-003040	1/15/2020	FT-FY20-012020-003040-A	<1	FT-FY20-012020-003040-B	<1
WS- 003041	5/21/2019	5/21/2020	1	Cooler	In hallway across from restroom C118	Low Right	WF-05212019-003041	1/15/2020	FT-FY20-012020-003041-A	<1	FT-FY20-012020-003041-B	<1
WS- 003043	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to restroom B244	High Left	WF-05212019-003043	1/15/2020	FT-FY20-012020-003043-A	<1	FT-FY20-012020-003043-B	<1
WS- 003044	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to restroom B244	Low Right	WF-05212019-003044	1/15/2020	FT-FY20-012020-003044-A	<1	FT-FY20-012020-003044-B	<1
WS- 003045	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to restroom B214	High Left	WF-05212019-003045	1/15/2020	FT-FY20-012020-003045-A	<1	FT-FY20-012020-003045-B	<1
WS- 003046	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to restroom B214	Low Right	WF-05212019-003046	1/15/2020	FT-FY20-012020-003046-A	<1	FT-FY20-012020-003046-B	<1
WS- 003047	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to restroom B344	High Left	WF-05212019-003047	1/15/2020	FT-FY20-012020-003047-A	<1	FT-FY20-012020-003047-B	<1
WS- 003048	5/21/2019	5/21/2020	2	Cooler	In hallway adjacent to restroom B344	Low Right	WF-05212019-003048	1/15/2020	FT-FY20-012020-003048-A	<1	FT-FY20-012020-003048-B	<1
WS- 003049	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to restroom B316	High Left	WF-05212019-003049	1/15/2020	FT-FY20-012020-003049-A	<1	FT-FY20-012020-003049-B	<1
WS- 003050	5/21/2019	5/21/2020	3	Cooler	In hallway adjacent to restroom B316	Low Right	WF-05212019-003050	1/15/2020	FT-FY20-012020-003050-A	<1	FT-FY20-012020-003050-B	<1
WS- 003052	10/22/2019	10/22/2020	1	Classroom Faucet	In classroom (life skills) A149	Left	WF-10222019-003052	1/15/2020	FT-FY20-012020-003052-A	<1	FT-FY20-012020-003052-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003006	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen BG19 adjacent to entrance	WF-07162019-003006	1/15/2020	FT-FY20-012020-003006-A	<1	FT-FY20-012020-003006-B	<1
WS- 003008	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen BG19 on island	WF-07162019-003008	1/15/2020	FT-FY20-012020-003008-A	<1	FT-FY20-012020-003008-B	<1
WS- 003009	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-07162019-003009	1/15/2020	FT-FY20-012020-003009-A	<1	FT-FY20-012020-003009-B	<1
WS- 003010	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen BG19 buffet sink	WF-07162019-003010	1/15/2020	FT-FY20-012020-003010-A	<1	FT-FY20-012020-003010-B	<1
WS- 003014	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen AG39	WF-07162019-003014	1/15/2020	FT-FY20-012020-003014-A	<1	FT-FY20-012020-003014-B	<1
WS- 003015	7/16/2019	7/16/2020	Basement	Food Prep Sink	In kitchen AG39 across from freezer	WF-07162019-003015	1/15/2020	FT-FY20-012020-003015-A	<1	FT-FY20-012020-003015-B	<1