



Roosevelt High School Lead in Water Test Results

FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003002	4/12/2021	4/12/2022	Ground Floor	Cooler	In hallway across from room BG09	High Left	WF-04122021-003002	3/14/2022	FT-FY22-02212022-003002-A	<1	FT-FY22-02212022-003002-B	<1
WS- 003003	4/12/2021	4/12/2022	Ground Floor	Cooler	In hallway across from room BG09	Low Right	WF-04122021-003003	3/14/2022	FT-FY22-02212022-003003-A	<1	FT-FY22-02212022-003003-B	<1
WS- 003004	4/12/2021	4/12/2022	Ground Floor	Cooler	In hallway across from room BG07	High Left	WF-04122021-003004	3/14/2022	FT-FY22-02212022-003004-A	<1	FT-FY22-02212022-003004-B	<1
WS- 003005	4/12/2021	4/12/2022	Ground Floor	Cooler	In hallway across from room BG07	Low Right	WF-04122021-003005	3/14/2022	FT-FY22-02212022-003005-A	<1	FT-FY22-02212022-003005-B	<1
WS- 003017	4/12/2021	4/12/2022	Ground Floor	Health Suite	In health suite CG08		WF-04122021-003017	3/14/2022	FT-FY22-02212022-003017-A	<1	FT-FY22-02212022-003017-B	<1
WS- 003018	4/12/2021	4/12/2022	Ground Floor	Health Suite	In health suite in break room across from CG20		WF-04122021-003018	3/14/2022	FT-FY22-02212022-003018-A	<1	FT-FY22-02212022-003018-B	<1
WS- 003019	4/12/2021	4/12/2022	Ground Floor	Health Suite	In health suite in dentist room CG30		WF-04122021-003019	3/14/2022	FT-FY22-02212022-003019-A	<1	FT-FY22-02212022-003019-B	<1
WS- 003020	4/12/2021	4/12/2022	Basement	Cooler	In poolside adjacent to women's locker	High Left	WF-04122021-003020	3/14/2022	FT-FY22-02212022-003020-A	<1	FT-FY22-02212022-003020-B	<1
WS- 003022	4/12/2021	4/12/2022	Basement	Cooler	In poolside adjacent to men's locker room	High Left	WF-04122021-003022	3/14/2022	FT-FY22-02212022-003022-A	<1	FT-FY22-02212022-003022-B	<1
WS- 003023	4/12/2021	4/12/2022	Basement	Cooler	In poolside adjacent to men's locker room	Low Right	WF-04122021-003023	3/14/2022	FT-FY22-02212022-003023-A	<1	FT-FY22-02212022-003023-B	<1
WS- 003024	4/12/2021	4/12/2022	Basement	Cooler	In poolside adjacent to women's locker room	Low Right	WF-04122021-003024	3/14/2022	FT-FY22-02212022-003024-A	<1	FT-FY22-02212022-003024-B	<1
WS- 003025	4/12/2021	4/12/2022	Ground Floor	Cooler	In poolside hallway across from stair c1	High Left	WF-04122021-003025	3/14/2022	FT-FY22-02212022-003025-A	<1	FT-FY22-02212022-003025-B	<1
WS- 003026	4/12/2021	4/12/2022	Ground Floor	Cooler	In poolside hallway across from stair C1	Low Right	WF-04122021-003026	3/14/2022	FT-FY22-02212022-003026-A	<1	FT-FY22-02212022-003026-B	<1
WS- 003027	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom A108	High Left	WF-04122021-003027	3/14/2022	FT-FY22-02212022-003027-A	<1	FT-FY22-02212022-003027-B	<1
WS- 003028	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom A108	Low Right	WF-04122021-003028	3/14/2022	FT-FY22-02212022-003028-A	<1	FT-FY22-02212022-003028-B	<1
WS- 003029	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom B120	High Left	WF-04122021-003029	3/14/2022	FT-FY22-02212022-003029-A	<1	FT-FY22-02212022-003029-B	<1
WS- 003030	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom B120	Low Right	WF-04122021-003030	3/14/2022	FT-FY22-02212022-003030-A	<1	FT-FY22-02212022-003030-B	<1
WS- 003031	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom B156	High Left	WF-04122021-003031	3/14/2022	FT-FY22-02212022-003031-A	<1	FT-FY22-02212022-003031-B	<1
WS- 003032	4/12/2021	4/12/2022	1	Cooler	In hallway adjacent to restroom B156	Low Right	WF-04122021-003032	3/14/2022	FT-FY22-02212022-003032-A	<1	FT-FY22-02212022-003032-B	<1
WS- 003037	4/12/2021	4/12/2022	1	Cooler	In hallway across from restroom C110	High Left	WF-04122021-003037	3/14/2022	FT-FY22-02212022-003037-A	<1	FT-FY22-02212022-003037-B	<1
WS- 003038	4/12/2021	4/12/2022	1	Cooler	In hallway across from restroom C110	Low Right	WF-04122021-003038	3/14/2022	FT-FY22-02212022-003038-A	<1	FT-FY22-02212022-003038-B	<1
WS- 003039	11/22/2021	11/22/2022	1	Cooler	In hallway across from restroom C118	High Left	WF-11222021-003039	3/14/2022	FT-FY22-02212022-003039-A	<1	FT-FY22-02212022-003039-B	<1
WS- 003041	11/22/2021	11/22/2022	1	Cooler	In hallway across from restroom C118	Low Right	WF-11222021-003041	3/14/2022	FT-FY22-02212022-003041-A	<1	FT-FY22-02212022-003041-B	<1
WS- 003045	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to restroom B214	High Left	WF-04122021-003045	3/14/2022	FT-FY22-02212022-003045-A	<1	FT-FY22-02212022-003045-B	<1
WS- 003046	4/12/2021	4/12/2022	2	Cooler	In hallway adjacent to restroom B214	Low Right	WF-04122021-003046	3/14/2022	FT-FY22-02212022-003046-A	<1	FT-FY22-02212022-003046-B	<1
WS- 003047	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to restroom B344	High Left	WF-04122021-003047	3/14/2022	FT-FY22-02212022-003047-A	<1	FT-FY22-02212022-003047-B	<1
WS- 003048	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to restroom B344	Low Right	WF-04122021-003048	3/14/2022	FT-FY22-02212022-003048-A	<1	FT-FY22-02212022-003048-B	<1
WS- 003049	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to restroom B316	High Left	WF-04122021-003049	3/14/2022	FT-FY22-02212022-003049-A	<1	FT-FY22-02212022-003049-B	<1
WS- 003050	4/12/2021	4/12/2022	3	Cooler	In hallway adjacent to restroom B316	Low Right	WF-04122021-003050	3/14/2022	FT-FY22-02212022-003050-A	<1	FT-FY22-02212022-003050-B	<1
WS- 003052	10/6/2021	10/6/2022	1	Classroom Faucet	In classroom (life skills) A149	Left	WF-10062021-003052	3/14/2022	FT-FY22-02212022-003052-A	<1	FT-FY22-02212022-003052-B	<1
WS- 003054	4/12/2021	4/12/2022	Basement	Bottle Filler	In poolside adjacent to men's locker room		WF-04122021-003054	3/14/2022	FT-FY22-02212022-003054-A	<1	FT-FY22-02212022-003054-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003008	1/24/2022	1/24/2023	Basement	Food Prep Sink	In kitchen BG19 on island	WF-01242022-003008	3/14/2022	FT-FY22-02212022-003008-A	<1	FT-FY22-02212022-003008-B	<1
WS- 003009	1/24/2022	1/24/2023	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-01242022-003009	3/14/2022	FT-FY22-02212022-003009-A	<1	FT-FY22-02212022-003009-B	<1
WS- 003010	1/24/2022	1/24/2023	Basement	Food Prep Sink	In kitchen BG19 buffet sink	WF-01242022-003010	3/14/2022	FT-FY22-02212022-003010-A	<1	FT-FY22-02212022-003010-B	<1
WS- 003014	2/1/2022	2/1/2023	Basement	Food Prep Sink	In kitchen AG39	WF-02012022-003014	3/14/2022	FT-FY22-02212022-003014-A	<1	FT-FY22-02212022-003014-B	<1
WS- 003015	1/24/2022	1/24/2023	Basement	Food Prep Sink	In kitchen AG39 across from freezer	WF-01242022-003015	3/14/2022	FT-FY22-02212022-003015-A	<1	FT-FY22-02212022-003015-B	<1