



Roosevelt High School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003002	3/27/2023	3/27/2024	Ground Floor	Cooler	In hallway across from room BG09 High Left	WF-03272023-003002	11/21/2023	FT-FY24-10102023-003002-A	<1	FT-FY24-10102023-003002-B	<1
WS- 003003	3/27/2023	3/27/2024	Ground Floor	Cooler	In hallway across from room BG09 Low Right	WF-03272023-003003	11/21/2023	FT-FY24-10102023-003003-A	<1	FT-FY24-10102023-003003-B	<1
WS- 003004	3/27/2023	3/27/2024	Ground Floor	Cooler	In hallway across from room BG07 High Left	WF-03272023-003004	11/21/2023	FT-FY24-10102023-003004-A	<1	FT-FY24-10102023-003004-B	<1
WS- 003005	3/27/2023	3/27/2024	Ground Floor	Cooler	In hallway across from room BG07 Low Right	WF-03272023-003005	11/21/2023	FT-FY24-10102023-003005-A	<1	FT-FY24-10102023-003005-B	<1
WS- 003017	3/27/2023	3/27/2024	Ground Floor	Health Suite	In health suite CG08	WF-03272023-003017	11/21/2023	FT-FY24-10102023-003017-A	<1	FT-FY24-10102023-003017-B	<1
WS- 003018	3/27/2023	3/27/2024	Ground Floor	Health Suite	In health suite in break room across from CG20	WF-03272023-003018	11/21/2023	FT-FY24-10102023-003018-A	<1	FT-FY24-10102023-003018-B	<1
WS- 003019	3/27/2023	3/27/2024	Ground Floor	Health Suite	In health suite in dentist room CG30	WF-03272023-003019	11/21/2023	FT-FY24-10102023-003019-A	<1	FT-FY24-10102023-003019-B	<1
WS- 003020	3/27/2023	3/27/2024	Basement	Cooler	In poolside adjacent to women's locker High Left	WF-03272023-003020	11/21/2023	FT-FY24-10102023-003020-A	<1	FT-FY24-10102023-003020-B	<1
WS- 003022	3/27/2023	3/27/2024	Basement	Cooler	In poolside adjacent to men's locker room High Left	WF-03272023-003022	11/21/2023	FT-FY24-10102023-003022-A	<1	FT-FY24-10102023-003022-B	<1
WS- 003023	3/27/2023	3/27/2024	Basement	Cooler	In poolside adjacent to men's locker room Low Right	WF-03272023-003023	11/21/2023	FT-FY24-10102023-003023-A	<1	FT-FY24-10102023-003023-B	<1
WS- 003024	3/27/2023	3/27/2024	Basement	Cooler	In poolside adjacent to women's locker room Low Right	WF-03272023-003024	11/21/2023	FT-FY24-10102023-003024-A	<1	FT-FY24-10102023-003024-B	<1
WS- 003027	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom A108 High Left	WF-03272023-003027	11/21/2023	FT-FY24-10102023-003027-A	<1	FT-FY24-10102023-003027-B	<1
WS- 003028	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom A108 Low Right	WF-03272023-003028	11/21/2023	FT-FY24-10102023-003028-A	<1	FT-FY24-10102023-003028-B	<1
WS- 003029	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom B120 High Left	WF-03272023-003029	11/21/2023	FT-FY24-10102023-003029-A	<1	FT-FY24-10102023-003029-B	<1
WS- 003030	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom B120 Low Right	WF-03272023-003030	11/21/2023	FT-FY24-10102023-003030-A	<1	FT-FY24-10102023-003030-B	<1
WS- 003031	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom B156 High Left	WF-03272023-003031	11/21/2023	FT-FY24-10102023-003031-A	<1	FT-FY24-10102023-003031-B	<1
WS- 003032	3/27/2023	3/27/2024	1	Cooler	In hallway adjacent to restroom B156 Low Right	WF-03272023-003032	11/21/2023	FT-FY24-10102023-003032-A	<1	FT-FY24-10102023-003032-B	<1
WS- 003037	3/27/2023	3/27/2024	1	Cooler	In hallway across from restroom C110 High Left	WF-03272023-003037	11/21/2023	FT-FY24-10102023-003037-A	<1	FT-FY24-10102023-003037-B	<1
WS- 003038	3/27/2023	3/27/2024	1	Cooler	In hallway across from restroom C110 Low Right	WF-03272023-003038	11/21/2023	FT-FY24-10102023-003038-A	<1	FT-FY24-10102023-003038-B	<1
WS- 003039	3/27/2023	3/27/2024	1	Cooler	In hallway across from restroom C118 High Left	WF-03272023-003039	11/21/2023	FT-FY24-10102023-003039-A	<1	FT-FY24-10102023-003039-B	<1
WS- 003040	3/27/2023	3/27/2024	1	Bottle Filler	In hallway across from restroom C118 (bottle filler)	WF-03272023-003040	11/21/2023	FT-FY24-10102023-003040-A	<1	FT-FY24-10102023-003040-B	<1
WS- 003041	3/27/2023	3/27/2024	1	Cooler	In hallway across from restroom C118 Low Right	WF-03272023-003041	11/21/2023	FT-FY24-10102023-003041-A	<1	FT-FY24-10102023-003041-B	<1
WS- 003044	3/27/2023	3/27/2024	2	Cooler	In hallway adjacent to restroom B244 Low Right	WF-03272023-003044	11/21/2023	FT-FY24-10102023-003044-A	<1	FT-FY24-10102023-003044-B	<1
WS- 003045	3/27/2023	3/27/2024	2	Cooler	In hallway adjacent to restroom B214 High Left	WF-03272023-003045	11/21/2023	FT-FY24-10102023-003045-A	<1	FT-FY24-10102023-003045-B	<1
WS- 003046	3/27/2023	3/27/2024	2	Cooler	In hallway adjacent to restroom B214 Low Right	WF-03272023-003046	11/21/2023	FT-FY24-10102023-003046-A	<1	FT-FY24-10102023-003046-B	<1
WS- 003047	3/27/2023	3/27/2024	3	Cooler	In hallway adjacent to restroom B344 High Left	WF-03272023-003047	11/21/2023	FT-FY24-10102023-003047-A	<1	FT-FY24-10102023-003047-B	<1
WS- 003048	3/27/2023	3/27/2024	3	Cooler	In hallway adjacent to restroom B344 Low Right	WF-03272023-003048	11/21/2023	FT-FY24-10102023-003048-A	<1	FT-FY24-10102023-003048-B	<1
WS- 003052	9/20/2023	9/20/2024	1	Classroom Faucet	In classroom (life skills) A149 Left	WF-09202023-003052	11/21/2023	FT-FY24-10102023-003052-A	<1	FT-FY24-10102023-003052-B	<1
WS- 003054	3/27/2023	3/27/2024	Basement	Bottle Filler	In poolside adjacent to men's locker room	WF-03272023-003054	11/21/2023	FT-FY24-10102023-003054-A	<1	FT-FY24-10102023-003054-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003008	1/3/2023	1/3/2024	Basement	Food Prep Sink	In kitchen BG19 on island	WF-01032023-003008	11/21/2023	FT-FY24-10102023-003008-A	<1	FT-FY24-10102023-003008-B	<1

WS- 003009	1/3/2023	1/3/2024	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-01032023-003009	11/21/2023	FT-FY24-10102023-003009-A	<1	FT-FY24-10102023-003009-B	<1
WS- 003010	1/3/2023	1/3/2024	Basement	Food Prep Sink	In kitchen BG19 buffet sink	WF-01032023-003010	11/21/2023	FT-FY24-10102023-003010-A	<1	FT-FY24-10102023-003010-B	<1
WS- 003014	1/3/2023	1/3/2024	Basement	Food Prep Sink	In kitchen AG39	WF-01032023-003014	11/21/2023	FT-FY24-10102023-003014-A	<1	FT-FY24-10102023-003014-B	<1
WS- 003015	1/3/2023	1/3/2024	Basement	Food Prep Sink	In kitchen AG39 across from freezer	WF-01032023-003015	11/21/2023	FT-FY24-10102023-003015-A	<1	FT-FY24-10102023-003015-B	<1