



Roosevelt High School Lead in Water Test Results

FY26 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-002031	3/10/2025	3/10/2026	Basement	Bottle Filler	In poolside adjacent to women's locker room	WF-03102025-002031	11/11/2025	FT-FY26-10172025-002031-A	<2	FT-FY26-10172025-002031-B	<2
WS-003002	3/10/2025	3/10/2026	Ground Floor	Cooler	In hallway across from room BG09 High Left	WF-03102025-003002	11/11/2025	FT-FY26-10172025-003002-A	<2	FT-FY26-10172025-003002-B	<2
WS-003003	3/10/2025	3/10/2026	Ground Floor	Cooler	In hallway across from room BG09 Low Right	WF-03102025-003003	11/11/2025	FT-FY26-10172025-003003-A	<2	FT-FY26-10172025-003003-B	<2
WS-003004	3/10/2025	3/10/2026	Ground Floor	Cooler	In hallway across from room BG07 High Left	WF-03102025-003004	11/11/2025	FT-FY26-10172025-003004-A	<2	FT-FY26-10172025-003004-B	<2
WS-003005	3/10/2025	3/10/2026	Ground Floor	Cooler	In hallway across from room BG07 Low Right	WF-03102025-003005	11/11/2025	FT-FY26-10172025-003005-A	<2	FT-FY26-10172025-003005-B	<2
WS-003011	3/10/2025	3/10/2026	Ground Floor	Cooler	In cafeteria BG21 High Left	WF-03102025-003011	11/11/2025	FT-FY26-10172025-003011-A	<2	FT-FY26-10172025-003011-B	<2
WS-003012	3/10/2025	3/10/2026	Ground Floor	Bottle Filler	In cafeteria BG21 (bottle filler)	WF-03102025-003012	11/11/2025	FT-FY26-10172025-003012-A	<2	FT-FY26-10172025-003012-B	<2
WS-003013	3/10/2025	3/10/2026	Ground Floor	Cooler	In cafeteria BG21 Low Right	WF-03102025-003013	11/11/2025	FT-FY26-10172025-003013-A	<2	FT-FY26-10172025-003013-B	<2
WS-003017	3/10/2025	3/10/2026	Ground Floor	Health Suite	In health suite CG08	WF-03102025-003017	11/11/2025	FT-FY26-10172025-003017-A	<2	FT-FY26-10172025-003017-B	<2
WS-003018	3/10/2025	3/10/2026	Ground Floor	Health Suite	In health suite in break room across from CG20	WF-03102025-003018	11/11/2025	FT-FY26-10172025-003018-A	<2	FT-FY26-10172025-003018-B	<2
WS-003019	3/10/2025	3/10/2026	Ground Floor	Health Suite	In health suite in dentist room CG30	WF-03102025-003019	11/11/2025	FT-FY26-10172025-003019-A	<2	FT-FY26-10172025-003019-B	<2
WS-003020	3/10/2025	3/10/2026	Basement	Cooler	In poolside adjacent to women's locker High Left	WF-03102025-003020	11/11/2025	FT-FY26-10172025-003020-A	<2	FT-FY26-10172025-003020-B	<2
WS-003024	3/10/2025	3/10/2026	Basement	Cooler	In poolside adjacent to women's locker room Low Right	WF-03102025-003024	11/11/2025	FT-FY26-10172025-003024-A	<2	FT-FY26-10172025-003024-B	<2
WS-003027	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom A108 High Left	WF-03102025-003027	11/11/2025	FT-FY26-10172025-003027-A	<2	FT-FY26-10172025-003027-B	<2
WS-003028	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom A108 Low Right	WF-03102025-003028	11/11/2025	FT-FY26-10172025-003028-A	<2	FT-FY26-10172025-003028-B	<2
WS-003029	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom B120 High Left	WF-03102025-003029	11/11/2025	FT-FY26-10172025-003029-A	<2	FT-FY26-10172025-003029-B	<2
WS-003030	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom B120 Low Right	WF-03102025-003030	11/11/2025	FT-FY26-10172025-003030-A	<2	FT-FY26-10172025-003030-B	<2
WS-003031	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom B156 High Left	WF-03102025-003031	11/11/2025	FT-FY26-10172025-003031-A	<2	FT-FY26-10172025-003031-B	<2
WS-003032	3/10/2025	3/10/2026	1	Cooler	In hallway adjacent to restroom B156 Low Right	WF-03102025-003032	11/11/2025	FT-FY26-10172025-003032-A	<2	FT-FY26-10172025-003032-B	<2
WS-003033	3/10/2025	3/10/2026	1	Cooler	In hallway across from gym C104 High Left	WF-03102025-003033	11/11/2025	FT-FY26-10172025-003033-A	<2	FT-FY26-10172025-003033-B	<2
WS-003034	3/10/2025	3/10/2026	1	Cooler	In hallway across from gym C104 Low Right	WF-03102025-003034	11/11/2025	FT-FY26-10172025-003034-A	<2	FT-FY26-10172025-003034-B	<2
WS-003037	3/10/2025	3/10/2026	1	Cooler	In hallway across from restroom C110 High Left	WF-03102025-003037	11/11/2025	FT-FY26-10172025-003037-A	<2	FT-FY26-10172025-003037-B	<2
WS-003038	3/10/2025	3/10/2026	1	Cooler	In hallway across from restroom C110 Low Right	WF-03102025-003038	11/11/2025	FT-FY26-10172025-003038-A	<2	FT-FY26-10172025-003038-B	<2
WS-003043	3/10/2025	3/10/2026	2	Cooler	In hallway adjacent to restroom B244 High Left	WF-03102025-003043	11/11/2025	FT-FY26-10172025-003043-A	<2	FT-FY26-10172025-003043-B	<2
WS-003044	3/10/2025	3/10/2026	2	Cooler	In hallway adjacent to restroom B244 Low Right	WF-03102025-003044	11/11/2025	FT-FY26-10172025-003044-A	<2	FT-FY26-10172025-003044-B	<2
WS-003045	3/10/2025	3/10/2026	2	Cooler	In hallway adjacent to restroom B214 High Left	WF-03102025-003045	11/11/2025	FT-FY26-10172025-003045-A	<2	FT-FY26-10172025-003045-B	<2
WS-003046	3/10/2025	3/10/2026	2	Cooler	In hallway adjacent to restroom B214 Low Right	WF-03102025-003046	11/11/2025	FT-FY26-10172025-003046-A	<2	FT-FY26-10172025-003046-B	<2
WS-003047	3/10/2025	3/10/2026	3	Cooler	In hallway adjacent to restroom B344 High Left	WF-03102025-003047	11/11/2025	FT-FY26-10172025-003047-A	<2	FT-FY26-10172025-003047-B	<2
WS-003048	3/10/2025	3/10/2026	3	Cooler	In hallway adjacent to restroom B344 Low Right	WF-03102025-003048	11/11/2025	FT-FY26-10172025-003048-A	<2	FT-FY26-10172025-003048-B	<2
WS-003049	3/10/2025	3/10/2026	3	Cooler	In hallway adjacent to restroom B316 High Left	WF-03102025-003049	11/11/2025	FT-FY26-10172025-003049-A	<2	FT-FY26-10172025-003049-B	<2
WS-003050	3/10/2025	3/10/2026	3	Cooler	In hallway adjacent to restroom B316 Low Right	WF-03102025-003050	11/11/2025	FT-FY26-10172025-003050-A	<2	FT-FY26-10172025-003050-B	<2
WS-003052	9/9/2025	9/9/2026	1	Classroom Faucet	In classroom (life skills) A149 Left	WF-09092025-003052	11/11/2025	FT-FY26-10172025-003052-A	<2	FT-FY26-10172025-003052-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003006	12/5/2024	12/5/2025	Basement	Food Prep Sink	In kitchen BG19 adjacent to entrance	WF-12052024-003006	11/11/2025	FT-FY26-10172025-003006-A	<2	FT-FY26-10172025-003006-B	<2
WS- 003008	12/3/2024	12/3/2025	Basement	Food Prep Sink	In kitchen BG19 on island	WF-12032024-003008	11/11/2025	FT-FY26-10172025-003008-A	<2	FT-FY26-10172025-003008-B	<2
WS- 003009	2/13/2025	2/13/2026	Basement	Food Prep Sink	In kitchen BG19 across from freezer	WF-02132025-003009	11/11/2025	FT-FY26-10172025-003009-A	<2	FT-FY26-10172025-003009-B	<2
WS- 003010	12/3/2024	12/3/2025	Basement	Food Prep Sink	In kitchen BG19 buffet sink	WF-12032024-003010	11/11/2025	FT-FY26-10172025-003010-A	<2	FT-FY26-10172025-003010-B	<2
WS- 003014	12/3/2024	12/3/2025	Basement	Food Prep Sink	In kitchen AG39	WF-12032024-003014	11/11/2025	FT-FY26-10172025-003014-A	<2	FT-FY26-10172025-003014-B	<2
WS- 003015	12/3/2024	12/3/2025	Basement	Food Prep Sink	In kitchen AG39 across from freezer	WF-12032024-003015	11/11/2025	FT-FY26-10172025-003015-A	<2	FT-FY26-10172025-003015-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.