



Roosevelt STAY School at Garnett Patterson Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 009170	8/4/2022	8/4/2023	1	Health Suite	In health suite bathroom	WF-08042022-009170	8/24/2022	FT-FY23-08192022-009170-A	<1	FT-FY23-08192022-009170-B	<1
WS- 009171	8/4/2022	8/4/2023	1	Bottle Filler	In hallway adjacent to room 142	WF-08042022-009171	8/24/2022	FT-FY23-08192022-009171-A	<1	FT-FY23-08192022-009171-B	<1
WS- 009173	8/4/2022	8/4/2023	1	Bottle Filler	In hallway adjacent to room 112	WF-08042022-009173	8/24/2022	FT-FY23-08192022-009173-A	<1	FT-FY23-08192022-009173-B	<1
WS- 009175	8/4/2022	8/4/2023	2	Break Room	In staff lounge 216	WF-08042022-009175	8/24/2022	FT-FY23-08192022-009175-A	<1	FT-FY23-08192022-009175-B	<1
WS- 009178	8/19/2022	8/19/2023	2	Bottle Filler	In hallway across from room A214	WF-08192022-009178	8/24/2022	FT-FY23-08192022-009178-A	<1	FT-FY23-08192022-009178-B	<1