



# Roosevelt HS Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 003002	5/30/2018	5/30/2019	Ground Floor	Cooler	In hallway across from room BG09 High Left	WF-05302018-003002	1/11/2019	FT-FY19-012019-003002-A	<1	FT-FY19-012019-003002-B	<1
WS- 003003	5/30/2018	5/30/2019	Ground Floor	Cooler	In hallway across from room BG09 Low Right	WF-05302018-003003	1/11/2019	FT-FY19-012019-003003-A	<1	FT-FY19-012019-003003-B	<1
WS- 003004	5/30/2018	5/30/2019	Ground Floor	Cooler	In hallway across from room BG07 High Left	WF-05302018-003004	1/11/2019	FT-FY19-012019-003004-A	<1	FT-FY19-012019-003004-B	<1
WS- 003005	5/30/2018	5/30/2019	Ground Floor	Cooler	In hallway across from room BG07 Low Right	WF-05302018-003005	1/11/2019	FT-FY19-012019-003005-A	<1	FT-FY19-012019-003005-B	<1
WS- 003011	5/30/2018	5/30/2019	Ground Floor	Cooler	In cafeteria BG21 High Left	WF-05302018-003011	1/11/2019	FT-FY19-012019-003011-A	<1	FT-FY19-012019-003011-B	<1
WS- 003012	5/30/2018	5/30/2019	Ground Floor	Bottle Filler	In cafeteria BG21 (bottle filler)	WF-05302018-003012	1/11/2019	FT-FY19-012019-003012-A	<1	FT-FY19-012019-003012-B	<1
WS- 003013	5/30/2018	5/30/2019	Ground Floor	Cooler	In cafeteria BG21 Low Right	WF-05302018-003013	1/11/2019	FT-FY19-012019-003013-A	<1	FT-FY19-012019-003013-B	<1
WS- 003017	5/30/2018	5/30/2019	Ground Floor	Health Suite	In health suite CG08	WF-05302018-003017	1/11/2019	FT-FY19-012019-003017-A	<1	FT-FY19-012019-003017-B	<1
WS- 003018	5/30/2018	5/30/2019	Ground Floor	Health Suite	In health suite in break room across from CG20	WF-05302018-003018	1/11/2019	FT-FY19-012019-003018-A	<1	FT-FY19-012019-003018-B	<1
WS- 003019	5/30/2018	5/30/2019	Ground Floor	Health Suite	In health suite in dentist room CG30	WF-05302018-003019	1/11/2019	FT-FY19-012019-003019-A	<1	FT-FY19-012019-003019-B	<1
WS- 003020	5/30/2018	5/30/2019	Basement	Cooler	In poolside adjacent to women's locker High Left	WF-05302018-003020	1/11/2019	FT-FY19-012019-003020-A	<1	FT-FY19-012019-003020-B	<1
WS- 003022	5/30/2018	5/30/2019	Basement	Cooler	In poolside adjacent to men's locker room High Left	WF-05302018-003022	1/11/2019	FT-FY19-012019-003022-A	<1	FT-FY19-012019-003022-B	<1
WS- 003023	5/30/2018	5/30/2019	Basement	Cooler	In poolside adjacent to men's locker room Low Right	WF-05302018-003023	1/11/2019	FT-FY19-012019-003023-A	<1	FT-FY19-012019-003023-B	<1
WS- 003024	5/30/2018	5/30/2019	Basement	Cooler	In poolside adjacent to women's locker room Low Right	WF-05302018-003024	1/11/2019	FT-FY19-012019-003024-A	<1	FT-FY19-012019-003024-B	<1
WS- 003025	5/30/2018	5/30/2019	Ground Floor	Cooler	In poolside hallway across from stair c1 High Left	WF-05302018-003025	1/11/2019	FT-FY19-012019-003025-A	<1	FT-FY19-012019-003025-B	<1
WS- 003026	5/30/2018	5/30/2019	Ground Floor	Cooler	In poolside hallway across from stair C1 Low Right	WF-05302018-003026	1/11/2019	FT-FY19-012019-003026-A	<1	FT-FY19-012019-003026-B	<1
WS- 003027	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom A108 High Left	WF-05302018-003027	1/11/2019	FT-FY19-012019-003027-A	<1	FT-FY19-012019-003027-B	<1
WS- 003028	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom A108 Low Right	WF-05302018-003028	1/11/2019	FT-FY19-012019-003028-A	<1	FT-FY19-012019-003028-B	<1
WS- 003029	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom B120 High Left	WF-05302018-003029	1/11/2019	FT-FY19-012019-003029-A	<1	FT-FY19-012019-003029-B	<1
WS- 003030	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom B120 Low Right	WF-05302018-003030	1/11/2019	FT-FY19-012019-003030-A	<1	FT-FY19-012019-003030-B	<1
WS- 003031	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom B156 High Left	WF-05302018-003031	1/11/2019	FT-FY19-012019-003031-A	<1	FT-FY19-012019-003031-B	<1
WS- 003032	5/30/2018	5/30/2019	1	Cooler	In hallway adjacent to restroom B156 Low Right	WF-05302018-003032	1/11/2019	FT-FY19-012019-003032-A	<1	FT-FY19-012019-003032-B	<1
WS- 003033	5/30/2018	5/30/2019	1	Cooler	In hallway across from gym C104 High Left	WF-05302018-003033	1/11/2019	FT-FY19-012019-003033-A	<1	FT-FY19-012019-003033-B	<1
WS- 003034	5/30/2018	5/30/2019	1	Cooler	In hallway across from gym C104 Low Right	WF-05302018-003034	1/11/2019	FT-FY19-012019-003034-A	<1	FT-FY19-012019-003034-B	<1
WS- 003037	5/30/2018	5/30/2019	1	Cooler	In hallway across from restroom C110 High Left	WF-05302018-003037	1/11/2019	FT-FY19-012019-003037-A	<1	FT-FY19-012019-003037-B	<1
WS- 003038	5/30/2018	5/30/2019	1	Cooler	In hallway across from restroom C110 Low Right	WF-05302018-003038	1/11/2019	FT-FY19-012019-003038-A	<1	FT-FY19-012019-003038-B	<1
WS- 003039	5/30/2018	5/30/2019	1	Cooler	In hallway across from restroom C118 High Left	WF-05302018-003039	1/11/2019	FT-FY19-012019-003039-A	<1	FT-FY19-012019-003039-B	<1
WS- 003040	5/30/2018	5/30/2019	1	Bottle Filler	In hallway across from restroom C118 (bottle filler)	WF-05302018-003040	1/11/2019	FT-FY19-012019-003040-A	<1	FT-FY19-012019-003040-B	<1
WS- 003041	5/30/2018	5/30/2019	1	Cooler	In hallway across from restroom C118 Low Right	WF-05302018-003041	1/11/2019	FT-FY19-012019-003041-A	<1	FT-FY19-012019-003041-B	<1
WS- 003043	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to restroom B244 High Left	WF-05302018-003043	1/11/2019	FT-FY19-012019-003043-A	<1	FT-FY19-012019-003043-B	<1
WS- 003044	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to restroom B244 Low Right	WF-05302018-003044	1/11/2019	FT-FY19-012019-003044-A	<1	FT-FY19-012019-003044-B	<1
WS- 003045	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to restroom B214 High Left	WF-05302018-003045	1/11/2019	FT-FY19-012019-003045-A	<1	FT-FY19-012019-003045-B	<1
WS- 003046	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to restroom B214 Low Right	WF-05302018-003046	1/11/2019	FT-FY19-012019-003046-A	<1	FT-FY19-012019-003046-B	<1
WS- 003047	5/30/2018	5/30/2019	3	Cooler	In hallway adjacent to restroom B344 High Left	WF-05302018-003047	1/11/2019	FT-FY19-012019-003047-A	<1	FT-FY19-012019-003047-B	<1
WS- 003048	5/30/2018	5/30/2019	2	Cooler	In hallway adjacent to restroom B344 Low Right	WF-05302018-003048	1/11/2019	FT-FY19-012019-003048-A	<1	FT-FY19-012019-003048-B	<1

WS-003049	5/30/2018	5/30/2019	3	Cooler	In hallway adjacent to restroom B316	High Left	WF-05302018-003049	1/11/2019	FT-FY19-012019-003049-A	<1	FT-FY19-012019-003049-B	<1
WS-003050	5/30/2018	5/30/2019	3	Cooler	In hallway adjacent to restroom B316	Low Right	WF-05302018-003050	1/11/2019	FT-FY19-012019-003050-A	<1	FT-FY19-012019-003050-B	<1
WS-003052	12/11/2018	12/11/2019	1	Classroom Faucet	In classroom (life skills) A149	Left	WF-12112018-003052	1/11/2019	FT-FY19-012019-003052-A	<1	FT-FY19-012019-003052-B	<1

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-003008	Basement	Food Prep Sink	In kitchen BG19 on island	1/11/2019	FT-FY19-012019-003008-A	<1	FT-FY19-012019-003008-B	<1	
WS-003009	Basement	Food Prep Sink	In kitchen BG19 across from freezer	1/11/2019	FT-FY19-012019-003009-A	<1	FT-FY19-012019-003009-B	<1	
WS-003014	Basement	Food Prep Sink	In kitchen AG39	1/11/2019	FT-FY19-012019-003014-A	<1	FT-FY19-012019-003014-B	<1	
WS-003015	Basement	Food Prep Sink	In kitchen AG39 across from freezer	1/11/2019	FT-FY19-012019-003015-A	<1	FT-FY19-012019-003015-B	<1	