



ROOSEVELT @ MCFARLAND LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
1	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010918	Kitchen	Basement	In kitchen basement Right	WT-042916-10935- A	< 1	WT-042916-10935- B	< 1				
2	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010919	Kitchen	Basement	In kitchen Mid	WT-042916-10936- A	< 1	WT-042916-10936- B	< 1				
3	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010920	Kitchen	Basement	In kitchen Left	WT-042916-10937- A	< 1	WT-042916-10937- B	< 1				
4	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010921	Other	Basement	In kitchen ice machine	WT-042916-10938- A	< 1	WT-042916-10938- B	< 1				
5	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010922	Cooler	Basement	In cafeteria	WT-042916-10939- A	< 1	WT-042916-10939- B	< 1				
6	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010923	Classroom	Basement	In boiler room	WT-042916-10940- A	4.3	WT-042916-10940- B	4.4				
7	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010924	Cooler	1	In hallway adjacent to room 152	WT-042916-10941- A	< 1	WT-042916-10941- B	< 1				
8	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010925	Classroom	1	In classroom 109 Right	WT-042916-10942- A	34.6	WT-042916-10942- B	20.3	Filter will be installed and then retested			
9	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010926	Classroom	1	In classroom 109 Right	WT-042916-10943- A	30	WT-042916-10943- B	16.6	Filter will be installed and then retested			
10	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010927	Classroom	1	In classroom 109 Left	WT-042916-10944- A	14.9	WT-042916-10944- B	15.2	Filter will be installed and then retested			
11	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010928	Classroom	1	In classroom 109 Mid	WT-042916-10945- A	12.9	WT-042916-10945- B	32.1	Filter will be installed and then retested			
12	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010929	Cooler	1	In hallway adjacent to room 112	WT-042916-10946- A	< 1	WT-042916-10946- B	< 1				
13	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010930	Cooler	1	In hallway adjacent to room 114	WT-042916-10947- A	< 1	WT-042916-10947- B	< 1				
14	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010931	Cooler	1	In hallway adjacent to room 131	WT-042916-10948- A	< 1	WT-042916-10948- B	< 1				
15	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010932	Classroom	1	In classroom 131	WT-042916-10949- A	< 1	WT-042916-10949- B	1				
16	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010933	Classroom	2	In classroom 217	WT-042916-10950- A	< 1	WT-042916-10950- B	< 1				
17	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010934	Classroom	2	In classroom 215 Right	WT-042916-10951- A	< 1	WT-042916-10951- B	< 1				
18	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010935	Classroom	2	In classroom 215 Left	WT-042916-10952- A	1.2	WT-042916-10952- B	< 1				
19	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010936	Classroom	2	In classroom 215A	WT-042916-10953- A	31.5	WT-042916-10953- B	13.3	Filter will be installed and then retested			
20	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010937	Classroom	2	In classroom 216 Left	WT-042916-10954- A	1.4	WT-042916-10954- B	61.1	Filter will be installed and then retested			
21	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010938	Classroom	2	In classroom 216 mid 01 Mid	WT-042916-10955- A	116	WT-042916-10955- B	26.1	Filter will be installed and then retested			
22	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010939	Classroom	2	In classroom 216 mid 02 Mid	WT-042916-10956- A	19	WT-042916-10956- B	7.4	Filter will be installed and then retested			



ROOSEVELT @ MCFARLAND LEAD WATER TEST RESULTS

May 16th, 2016



	Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
23	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010940	Classroom	2	In classroom 216 Right	WT-042916-10957- A	38.2	WT-042916-10957- B	4.3	Filter will be installed and then retested			
24	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010941	Cooler	2	In hallway adjacent to room 213	WT-042916-10958- A	< 1	WT-042916-10958- B	< 1				
25	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010942	Classroom	2	In classroom 206 Right	WT-042916-10959- A	6.6	WT-042916-10959- B	< 1				
26	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010943	Classroom	2	In classroom 206 Mid	WT-042916-10960- A	< 1	WT-042916-10960- B	< 1				
27	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010944	Classroom	2	In classroom 206 Left	WT-042916-10961- A	1	WT-042916-10961- B	< 1				
28	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010945	Classroom	2	In classroom 206 Mid	WT-042916-10962- A	23.9	WT-042916-10962- B	3.1	Filter will be installed and then retested			
29	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010946	Classroom	2	In classroom 208 Left	WT-042916-10963- A	8.8	WT-042916-10963- B	1.2				
30	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010947	Classroom	2	In classroom 208 mid 01 Mid	WT-042916-10964- A	7	WT-042916-10964- B	4.4				
31	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010949	Classroom	2	In classroom 208 mid 02 Mid	WT-042916-10966- A	5.6	WT-042916-10966- B	4.3				
32	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010950	Classroom	2	In classroom 208 Right	WT-042916-10967- A	2.6	WT-042916-10967- B	3				
33	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010951	Cooler	2	In hallway adjacent to room 201	WT-042916-10968- A	< 1	WT-042916-10968- B	< 1				
34	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010952	Cooler	2	In hallway adjacent to room 204	WT-042916-10969- A	< 1	WT-042916-10969- B	< 1				
35	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010953	Cooler	3	In hallway adjacent to room 303	WT-042916-10970- A	< 1	WT-042916-10970- B	< 1				
36	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010954	Classroom	3	In classroom 304 -01 Right	WT-042916-10971- A	10.1	WT-042916-10971- B	1.3				
37	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010955	Cooler	3	In classroom 304 -02 Right	WT-042916-10972- A	26.9	WT-042916-10972- B	3.4	Filter will be installed and then retested			
38	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010956	Classroom	3	in classroom 304 -01 Left	WT-042916-10973- A	6.3	WT-042916-10973- B	9.4				
39	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010957	Classroom	3	In classroom 304 -02 Left	WT-042916-10974- A	10.1	WT-042916-10974- B	4.8				
40	ROOSEVELT HIGH SCHOOL @ MCFARLAND	5/17/2016	WS- 010958	Cooler	3	In hallway adjacent to room 306	WT-042916-10975- A	< 1	WT-042916-10975- B	< 1				

Footnotes:

- A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.
- B - Second draw sample is collected after a 60 second flush at that device after the first draw.