



Rosedale RC Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011530	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to office 102	High	Left	WF-03162021-011530	4/8/2021	FT-FY21-032021-011530-A	<1	FT-FY21-032021-011530-B	<1
WS- 011531	3/16/2021	3/16/2022	1	Cooler	In hallway adjacent to office 102	Low	Right	WF-03162021-011531	4/8/2021	FT-FY21-032021-011531-A	<1	FT-FY21-032021-011531-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 011534	1/27/2021	1/27/2022	1	Food Prep Sink	In kitchen 106		Left	WF-01272021-011534	4/8/2021	FT-FY21-032021-011534-A	<1	FT-FY21-032021-011534-B	<1
WS- 011536	1/27/2021	1/27/2022	1	Food Prep Sink	In kitchen 106		Right	WF-01272021-011536	4/8/2021	FT-FY21-032021-011536-A	<1	FT-FY21-032021-011536-B	<1