



# Rosedale RC Lead in Water Test Results

## FY26 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011528	11/19/2025	11/19/2026	1	Food Prep Sink	In kitchen 119	Left	WF-11192025-011528	4/3/2026	FT-FY26-03122026-011528-A	4.5	FT-FY26-03122026-011528-B	<2
WS- 011530	2/18/2026	2/18/2027	1	Cooler	In hallway adjacent to office 102	High Left	WF-02182026-011530	4/3/2026	FT-FY26-03122026-011530-A	<2	FT-FY26-03122026-011530-B	<2
WS- 011531	2/18/2026	2/18/2027	1	Cooler	In hallway adjacent to office 102	Low Right	WF-02182026-011531	4/3/2026	FT-FY26-03122026-011531-A	<2	FT-FY26-03122026-011531-B	<2
WS- 011534	11/26/2024	11/26/2025	1	Food Prep Sink	In kitchen 106	Left	WF-11262024-011534	4/3/2026	FT-FY26-03122026-011534-A	<2	FT-FY26-03122026-011534-B	<2
WS- 011537	11/19/2025	11/19/2026	1	Dishwashing Hose	In kitchen 106 (dishwashing hose)	Right	WF-11192025-011537	4/3/2026	FT-FY26-03122026-011537-A	<2	FT-FY26-03122026-011537-B	<2
WS- 011541	2/18/2026	2/18/2027	1	Cooler	In library		WF-02182026-011541	4/3/2026	FT-FY26-03122026-011541-A	<2	FT-FY26-03122026-011541-B	<2
WS- 011542	2/18/2026	2/18/2027	1	Break Room	In work room in library	Left	WF-02182026-011542	4/3/2026	FT-FY26-03122026-011542-A	<2	FT-FY26-03122026-011542-B	<2

## FY26 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 011536	11/19/2025	11/19/2026	1	Food Prep Sink	In kitchen 106	Right	WF-11192025-011536	4/3/2026	FT-FY26-03122026-011536-A	12.9	FT-FY26-03122026-011536-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.