



Rosedale RC Lead Water Test Results



FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011530	5/25/17	5/25/18	1	Cooler	In hallway adjacent to office 102	Left High	WF-52017-011530	2/21/18	FT-FY18--52017-011530-A	<1	FT-FY18--52017-011530-B	<1
WS-011542	5/25/17	5/25/18	1	Break Room	In work room in library	Left	WF-52017-011542	2/21/18	FT-FY18--52017-011542-A	<1	FT-FY18--52017-011542-B	<1

Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation												
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-011528	5/25/17	5/25/18	1	Food Prep Sink	In kitchen 119	Left	WF-52017-011528	2/21/18	FT-FY18--52017-011528-A	<1	FT-FY18--52017-011528-B	<1
WS-011534	5/25/17	5/25/18	1	Food Prep Sink	In kitchen 106	Left	WF-52017-011534	2/21/18	FT-FY18--52017-011534-A	<1	FT-FY18--52017-011534-B	<1
WS-011536	5/25/17	5/25/18	1	Food Prep Sink	In kitchen 106	Right	WF-52017-011536	2/21/18	FT-FY18--52017-011536-A	<1	FT-FY18--52017-011536-B	<1