



# Ross Elementary School Lead in Water Test Results

## FY23 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 007910	5/17/2022	5/17/2023	Basement	Bottle Filler	In staff lounge B06	WF-05172022-007910	1/9/2023	FT-FY23-11182022-007910-A	<1	FT-FY23-11182022-007910-B	1.5	
WS- 007911	5/17/2022	5/17/2023	Basement	Cooler	In staff lounge B06	WF-05172022-007911	1/9/2023	FT-FY23-11182022-007911-A	<1	FT-FY23-11182022-007911-B	2.7	
WS- 007912	5/17/2022	5/17/2023	Basement	Break Room	In staff lounge B06	WF-05172022-007912	1/9/2023	FT-FY23-11182022-007912-A	2.6	FT-FY23-11182022-007912-B	1.2	
WS- 007913	5/17/2022	5/17/2023	Basement	Break Room	In lactation room 007	WF-05172022-007913	1/9/2023	FT-FY23-11182022-007913-A	<1	FT-FY23-11182022-007913-B	<1	
WS- 007917	5/17/2022	5/17/2023	3	Combo Fountain	In art lab 302	WF-05172022-007917	1/9/2023	FT-FY23-11182022-007917-A	4.6	FT-FY23-11182022-007917-B	1.3	
WS- 007920	5/17/2022	5/17/2023	3	Combo Fountain	In music room 303	WF-05172022-007920	1/9/2023	FT-FY23-11182022-007920-A	2.5	FT-FY23-11182022-007920-B	1.0	
WS- 010096	5/17/2022	5/17/2023	Basement	Bottle Filler	In cafeteria	WF-05172022-010096	1/9/2023	FT-FY23-11182022-010096-A	2.3	FT-FY23-11182022-010096-B	2.0	
WS- 010097	5/17/2022	5/17/2023	2	Bottle Filler	In hallway adjacent to room 204	WF-05172022-010097	1/9/2023	FT-FY23-11182022-010097-A	1.9	FT-FY23-11182022-010097-B	1.3	
WS- 010098	5/17/2022	5/17/2023	1	Bottle Filler	In hallway adjacent to room 105	WF-05172022-010098	1/9/2023	FT-FY23-11182022-010098-A	4.0	FT-FY23-11182022-010098-B	1.7	
WS- 010099	5/17/2022	5/17/2023	Basement	Bottle Filler	In hallway adjacent to main office	WF-05172022-010099	1/9/2023	FT-FY23-11182022-010099-A	1.0	FT-FY23-11182022-010099-B	1.2	
WS- 010319	5/17/2022	5/17/2023	2	Cooler	In hallway adjacent to room 204	High Left	WF-05172022-010319	1/9/2023	FT-FY23-11182022-010319-A	4.4	FT-FY23-11182022-010319-B	<1
WS- 010320	5/17/2022	5/17/2023	2	Cooler	In hallway adjacent to room 204	Low Right	WF-05172022-010320	1/9/2023	FT-FY23-11182022-010320-A	1.2	FT-FY23-11182022-010320-B	4.7
WS- 010325	5/17/2022	5/17/2023	1	Cooler	In hallway adjacent to room 105	High Left	WF-05172022-010325	1/9/2023	FT-FY23-11182022-010325-A	<1	FT-FY23-11182022-010325-B	1.1
WS- 010326	5/17/2022	5/17/2023	1	Cooler	In hallway adjacent to room 105	Low Right	WF-05172022-010326	1/9/2023	FT-FY23-11182022-010326-A	3.1	FT-FY23-11182022-010326-B	2.8
WS- 010327	8/23/2022	8/23/2023	1	Classroom Faucet	In classroom 105	WF-08232022-010327	1/9/2023	FT-FY23-11182022-010327-A	2.4	FT-FY23-11182022-010327-B	<1	
WS- 010328	8/23/2022	8/23/2023	1	Classroom Faucet	In classroom 106	WF-08232022-010328	1/9/2023	FT-FY23-11182022-010328-A	2.6	FT-FY23-11182022-010328-B	1.3	
WS- 010329	8/23/2022	8/23/2023	1	Classroom Faucet	In classroom 109	WF-08232022-010329	1/9/2023	FT-FY23-11182022-010329-A	3.5	FT-FY23-11182022-010329-B	1.0	
WS- 010330	8/23/2022	8/23/2023	1	Classroom Faucet	In classroom 102	WF-08232022-010330	1/9/2023	FT-FY23-11182022-010330-A	1.8	FT-FY23-11182022-010330-B	1.2	
WS- 010331	5/17/2022	5/17/2023	Basement	Cooler	In hallway adjacent to main office	Low Right	WF-05172022-010331	1/9/2023	FT-FY23-11182022-010331-A	1.2	FT-FY23-11182022-010331-B	4.1
WS- 010332	5/17/2022	5/17/2023	Basement	Cooler	In hallway adjacent to main office	High Left	WF-05172022-010332	1/9/2023	FT-FY23-11182022-010332-A	<1	FT-FY23-11182022-010332-B	3.0
WS- 010334	5/17/2022	5/17/2023	Basement	Health Suite	In health suite	WF-05172022-010334	1/9/2023	FT-FY23-11182022-010334-A	1.7	FT-FY23-11182022-010334-B	2.1	
WS- 010335	5/17/2022	5/17/2023	Basement	Cooler	In cafeteria	High Left	WF-05172022-010335	1/9/2023	FT-FY23-11182022-010335-A	1.2	FT-FY23-11182022-010335-B	1.2
WS- 010336	5/17/2022	5/17/2023	Basement	Cooler	In cafeteria	Low Right	WF-05172022-010336	1/9/2023	FT-FY23-11182022-010336-A	1.4	FT-FY23-11182022-010336-B	3.7

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 010338	1/4/2022	1/4/2023	Basement	Food Prep Sink	In kitchen	WF-01042022-010338	1/9/2023	FT-FY23-11182022-010338-A	1.5	FT-FY23-11182022-010338-B	1.6

## FY23 Filter Test

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 007914	5/17/2022	5/17/2023	Basement	Combo Fountain	In lactation room 007	WF-05172022-007914	1/9/2023	FT-FY23-11182022-007914-A	6.0	FT-FY23-11182022-007914-B	<1