



Ross Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-007910	5/9/2023	5/9/2024	Basement	Bottle Filler	In staff lounge B06	WF-05092023-007910	11/3/2023	FT-FY24-10102023-007910-A	<1	FT-FY24-10102023-007910-B	<1
WS-007911	5/9/2023	5/9/2024	Basement	Cooler	In staff lounge B06	WF-05092023-007911	11/3/2023	FT-FY24-10102023-007911-A	<1	FT-FY24-10102023-007911-B	<1
WS-007912	5/9/2023	5/9/2024	Basement	Break Room	In staff lounge B06	WF-05092023-007912	11/3/2023	FT-FY24-10102023-007912-A	<1	FT-FY24-10102023-007912-B	<1
WS-007913	5/9/2023	5/9/2024	Basement	Break Room	In lactation room 007	WF-05092023-007913	11/3/2023	FT-FY24-10102023-007913-A	1.1	FT-FY24-10102023-007913-B	<1
WS-007914	5/9/2023	5/9/2024	Basement	Combo Fountain	In lactation room 007	WF-05092023-007914	11/3/2023	FT-FY24-10102023-007914-A	<1	FT-FY24-10102023-007914-B	<1
WS-007917	5/9/2023	5/9/2024	3	Combo Fountain	In art lab 302	WF-05092023-007917	11/3/2023	FT-FY24-10102023-007917-A	<1	FT-FY24-10102023-007917-B	<1
WS-007920	5/9/2023	5/9/2024	3	Combo Fountain	In music room 303	WF-05092023-007920	11/3/2023	FT-FY24-10102023-007920-A	<1	FT-FY24-10102023-007920-B	<1
WS-010096	5/9/2023	5/9/2024	Basement	Bottle Filler	In cafeteria	WF-05092023-010096	11/3/2023	FT-FY24-10102023-010096-A	<1	FT-FY24-10102023-010096-B	<1
WS-010097	5/9/2023	5/9/2024	2	Bottle Filler	In hallway adjacent to room 204	WF-05092023-010097	11/3/2023	FT-FY24-10102023-010097-A	<1	FT-FY24-10102023-010097-B	<1
WS-010098	5/9/2023	5/9/2024	1	Bottle Filler	In hallway adjacent to room 105	WF-05092023-010098	11/3/2023	FT-FY24-10102023-010098-A	<1	FT-FY24-10102023-010098-B	<1
WS-010099	5/9/2023	5/9/2024	Basement	Bottle Filler	In hallway adjacent to main office	WF-05092023-010099	11/3/2023	FT-FY24-10102023-010099-A	<1	FT-FY24-10102023-010099-B	<1
WS-010319	5/9/2023	5/9/2024	2	Cooler	In hallway adjacent to room 204 High Left	WF-05092023-010319	11/3/2023	FT-FY24-10102023-010319-A	<1	FT-FY24-10102023-010319-B	<1
WS-010320	5/9/2023	5/9/2024	2	Cooler	In hallway adjacent to room 204 Low Right	WF-05092023-010320	11/3/2023	FT-FY24-10102023-010320-A	<1	FT-FY24-10102023-010320-B	<1
WS-010325	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to room 105 High Left	WF-05092023-010325	11/3/2023	FT-FY24-10102023-010325-A	<1	FT-FY24-10102023-010325-B	<1
WS-010326	5/9/2023	5/9/2024	1	Cooler	In hallway adjacent to room 105 Low Right	WF-05092023-010326	11/3/2023	FT-FY24-10102023-010326-A	<1	FT-FY24-10102023-010326-B	<1
WS-010327	8/18/2023	8/18/2024	1	Classroom Faucet	In classroom 105	WF-08182023-010327	11/3/2023	FT-FY24-10102023-010327-A	<1	FT-FY24-10102023-010327-B	<1
WS-010328	8/18/2023	8/18/2024	1	Classroom Faucet	In classroom 106	WF-08182023-010328	11/3/2023	FT-FY24-10102023-010328-A	<1	FT-FY24-10102023-010328-B	<1
WS-010329	8/18/2023	8/18/2024	1	Classroom Faucet	In classroom 109	WF-08182023-010329	11/3/2023	FT-FY24-10102023-010329-A	<1	FT-FY24-10102023-010329-B	<1
WS-010330	8/18/2023	8/18/2024	1	Classroom Faucet	In classroom 102	WF-08182023-010330	11/3/2023	FT-FY24-10102023-010330-A	<1	FT-FY24-10102023-010330-B	1.2
WS-010331	5/9/2023	5/9/2024	Basement	Cooler	In hallway adjacent to main office Low Right	WF-05092023-010331	11/3/2023	FT-FY24-10102023-010331-A	<1	FT-FY24-10102023-010331-B	<1
WS-010332	5/9/2023	5/9/2024	Basement	Cooler	In hallway adjacent to main office High Left	WF-05092023-010332	11/3/2023	FT-FY24-10102023-010332-A	<1	FT-FY24-10102023-010332-B	<1
WS-010334	5/9/2023	5/9/2024	Basement	Health Suite	In health suite	WF-05092023-010334	11/3/2023	FT-FY24-10102023-010334-A	<1	FT-FY24-10102023-010334-B	<1
WS-010335	5/9/2023	5/9/2024	Basement	Cooler	In cafeteria High Left	WF-05092023-010335	11/3/2023	FT-FY24-10102023-010335-A	<1	FT-FY24-10102023-010335-B	<1
WS-010336	5/9/2023	5/9/2024	Basement	Cooler	In cafeteria Low Right	WF-05092023-010336	11/3/2023	FT-FY24-10102023-010336-A	<1	FT-FY24-10102023-010336-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010338	12/21/2022	12/21/2023	Basement	Food Prep Sink	In kitchen	WF-12212022-010338	11/3/2023	FT-FY24-10102023-010338-A	<1	FT-FY24-10102023-010338-B	<1