



Ross Elementary School Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-007910	5/6/2024	5/6/2025	Basement	Bottle Filler	In staff lounge B06	WF-05062024-007910	10/28/2024	FT-FY25-10082024-007910-A	<2	FT-FY25-10082024-007910-B	<2	
WS-007911	5/6/2024	5/6/2025	Basement	Cooler	In staff lounge B06	WF-05062024-007911	10/28/2024	FT-FY25-10082024-007911-A	<2	FT-FY25-10082024-007911-B	<2	
WS-007912	5/6/2024	5/6/2025	Basement	Break Room	In staff lounge B06	WF-05062024-007912	10/28/2024	FT-FY25-10082024-007912-A	<2	FT-FY25-10082024-007912-B	<2	
WS-007913	5/6/2024	5/6/2025	Basement	Break Room	In lactation room 007	WF-05062024-007913	10/28/2024	FT-FY25-10082024-007913-A	<2	FT-FY25-10082024-007913-B	<2	
WS-007914	5/6/2024	5/6/2025	Basement	Combo Fountain	In lactation room 007	WF-05062024-007914	10/28/2024	FT-FY25-10082024-007914-A	<2	FT-FY25-10082024-007914-B	<2	
WS-007917	5/6/2024	5/6/2025	3	Combo Fountain	In art lab 302	WF-05062024-007917	10/28/2024	FT-FY25-10082024-007917-A	<2	FT-FY25-10082024-007917-B	<2	
WS-007920	5/6/2024	5/6/2025	3	Combo Fountain	In music room 303	WF-05062024-007920	10/28/2024	FT-FY25-10082024-007920-A	<2	FT-FY25-10082024-007920-B	<2	
WS-010096	5/6/2024	5/6/2025	Basement	Bottle Filler	In cafeteria	WF-05062024-010096	10/28/2024	FT-FY25-10082024-010096-A	<2	FT-FY25-10082024-010096-B	<2	
WS-010097	5/6/2024	5/6/2025	2	Bottle Filler	In hallway adjacent to room 204	WF-05062024-010097	10/28/2024	FT-FY25-10082024-010097-A	<2	FT-FY25-10082024-010097-B	<2	
WS-010098	5/6/2024	5/6/2025	1	Bottle Filler	In hallway adjacent to room 105	WF-05062024-010098	10/28/2024	FT-FY25-10082024-010098-A	<2	FT-FY25-10082024-010098-B	<2	
WS-010099	5/6/2024	5/6/2025	Basement	Bottle Filler	In hallway adjacent to main office	WF-05062024-010099	10/28/2024	FT-FY25-10082024-010099-A	<2	FT-FY25-10082024-010099-B	<2	
WS-010320	5/6/2024	5/6/2025	2	Cooler	In hallway adjacent to room 204	Low Right	WF-05062024-010320	10/28/2024	FT-FY25-10082024-010320-A	<2	FT-FY25-10082024-010320-B	<2
WS-010325	5/6/2024	5/6/2025	1	Cooler	In hallway adjacent to room 105	High Left	WF-05062024-010325	10/28/2024	FT-FY25-10082024-010325-A	<2	FT-FY25-10082024-010325-B	<2
WS-010326	5/6/2024	5/6/2025	1	Cooler	In hallway adjacent to room 105	Low Right	WF-05062024-010326	10/28/2024	FT-FY25-10082024-010326-A	<2	FT-FY25-10082024-010326-B	<2
WS-010327	8/15/2024	8/15/2025	1	Classroom Faucet	In classroom 105	WF-08152024-010327	10/28/2024	FT-FY25-10082024-010327-A	<2	FT-FY25-10082024-010327-B	<2	
WS-010328	8/15/2024	8/15/2025	1	Classroom Faucet	In classroom 106	WF-08152024-010328	10/28/2024	FT-FY25-10082024-010328-A	<2	FT-FY25-10082024-010328-B	<2	
WS-010329	8/15/2024	8/15/2025	1	Classroom Faucet	In classroom 109	WF-08152024-010329	10/28/2024	FT-FY25-10082024-010329-A	<2	FT-FY25-10082024-010329-B	<2	
WS-010330	8/15/2024	8/15/2025	1	Classroom Faucet	In classroom 102	WF-08152024-010330	10/28/2024	FT-FY25-10082024-010330-A	<2	FT-FY25-10082024-010330-B	<2	
WS-010331	5/6/2024	5/6/2025	Basement	Cooler	In hallway adjacent to main office	Low Right	WF-05062024-010331	10/28/2024	FT-FY25-10082024-010331-A	<2	FT-FY25-10082024-010331-B	<2
WS-010332	5/6/2024	5/6/2025	Basement	Cooler	In hallway adjacent to main office	High Left	WF-05062024-010332	10/28/2024	FT-FY25-10082024-010332-A	<2	FT-FY25-10082024-010332-B	<2
WS-010334	5/6/2024	5/6/2025	Basement	Health Suite	In health suite	WF-05062024-010334	10/28/2024	FT-FY25-10082024-010334-A	<2	FT-FY25-10082024-010334-B	<2	
WS-010335	5/6/2024	5/6/2025	Basement	Cooler	In cafeteria	High Left	WF-05062024-010335	10/28/2024	FT-FY25-10082024-010335-A	<2	FT-FY25-10082024-010335-B	<2
WS-010336	5/6/2024	5/6/2025	Basement	Cooler	In cafeteria	Low Right	WF-05062024-010336	10/28/2024	FT-FY25-10082024-010336-A	<2	FT-FY25-10082024-010336-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-010338	11/29/2023	11/29/2024	Basement	Food Prep Sink	In kitchen	WF-11292023-010338	10/28/2024	FT-FY25-10082024-010338-A	<2	FT-FY25-10082024-010338-B	<2

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.