



Savoy Elementary School Lead in Water Test Results

FY22 Filter Test

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|---|-----------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 008924 | 5/24/2021 | 5/24/2022 | 1 | Cooler | In hallway adjacent to multi-purpose room | High Left | WF-05242021-008924 | 2/19/2022 | FT-FY22-01182022-008924-A | <1 | FT-FY22-01182022-008924-B | <1 |
| WS- 008925 | 5/24/2021 | 5/24/2022 | 1 | Cooler | In hallway adjacent to multi-purpose room | Low Right | WF-05242021-008925 | 2/19/2022 | FT-FY22-01182022-008925-A | <1 | FT-FY22-01182022-008925-B | <1 |
| WS- 008928 | 5/24/2021 | 5/24/2022 | 1 | Cooler | In hallway across from room 107 | High Left | WF-05242021-008928 | 2/19/2022 | FT-FY22-01182022-008928-A | <1 | FT-FY22-01182022-008928-B | <1 |
| WS- 008929 | 5/24/2021 | 5/24/2022 | 1 | Cooler | In hallway across from room 107 | Low Right | WF-05242021-008929 | 2/19/2022 | FT-FY22-01182022-008929-A | <1 | FT-FY22-01182022-008929-B | <1 |
| WS- 008930 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 109 | Left | WF-08302021-008930 | 2/19/2022 | FT-FY22-01182022-008930-A | <1 | FT-FY22-01182022-008930-B | <1 |
| WS- 008931 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 109 | Right | WF-05242021-008931 | 2/19/2022 | FT-FY22-01182022-008931-A | <1 | FT-FY22-01182022-008931-B | <1 |
| WS- 008932 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 111 | Left | WF-08302021-008932 | 2/19/2022 | FT-FY22-01182022-008932-A | <1 | FT-FY22-01182022-008932-B | <1 |
| WS- 008933 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 111 | Right | WF-05242021-008933 | 2/19/2022 | FT-FY22-01182022-008933-A | <1 | FT-FY22-01182022-008933-B | <1 |
| WS- 008934 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 113 | Left | WF-08302021-008934 | 2/19/2022 | FT-FY22-01182022-008934-A | <1 | FT-FY22-01182022-008934-B | <1 |
| WS- 008935 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 113 | Right | WF-05242021-008935 | 2/19/2022 | FT-FY22-01182022-008935-A | <1 | FT-FY22-01182022-008935-B | <1 |
| WS- 008936 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 115 | Left | WF-08302021-008936 | 2/19/2022 | FT-FY22-01182022-008936-A | <1 | FT-FY22-01182022-008936-B | <1 |
| WS- 008937 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 115 | Right | WF-05242021-008937 | 2/19/2022 | FT-FY22-01182022-008937-A | <1 | FT-FY22-01182022-008937-B | <1 |
| WS- 008938 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 120 | Left | WF-08302021-008938 | 2/19/2022 | FT-FY22-01182022-008938-A | <1 | FT-FY22-01182022-008938-B | <1 |
| WS- 008939 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 120 | Right | WF-05242021-008939 | 2/19/2022 | FT-FY22-01182022-008939-A | <1 | FT-FY22-01182022-008939-B | <1 |
| WS- 008940 | 8/30/2021 | 8/30/2022 | 1 | Combo Faucet | In classroom 122 | Left | WF-08302021-008940 | 2/19/2022 | FT-FY22-01182022-008940-A | <1 | FT-FY22-01182022-008940-B | <1 |
| WS- 008941 | 5/24/2021 | 5/24/2022 | 1 | Combo Fountain | In classroom 122 | Right | WF-05242021-008941 | 2/19/2022 | FT-FY22-01182022-008941-A | <1 | FT-FY22-01182022-008941-B | <1 |
| WS- 008942 | 5/24/2021 | 5/24/2022 | 1 | Health Suite | In health suite 108 | | WF-05242021-008942 | 2/19/2022 | FT-FY22-01182022-008942-A | <1 | FT-FY22-01182022-008942-B | <1 |
| WS- 008944 | 5/24/2021 | 5/24/2022 | 2 | Cooler | In hallway adjacent to room 203 | High Left | WF-05242021-008944 | 2/19/2022 | FT-FY22-01182022-008944-A | <1 | FT-FY22-01182022-008944-B | <1 |
| WS- 008946 | 5/24/2021 | 5/24/2022 | 2 | Break Room | In staff lounge 203 | | WF-05242021-008946 | 2/19/2022 | FT-FY22-01182022-008946-A | <1 | FT-FY22-01182022-008946-B | <1 |
| WS- 008965 | 5/24/2021 | 5/24/2022 | 3 | Cooler | In hallway across from room 300 | High Left | WF-05242021-008965 | 2/19/2022 | FT-FY22-01182022-008965-A | <1 | FT-FY22-01182022-008965-B | <1 |
| WS- 008966 | 5/24/2021 | 5/24/2022 | 3 | Cooler | In hallway across from room 300 | Low Right | WF-05242021-008966 | 2/19/2022 | FT-FY22-01182022-008966-A | <1 | FT-FY22-01182022-008966-B | <1 |
| WS- 008971 | 5/24/2021 | 5/24/2022 | 3 | Cooler | In hallway adjacent to room 306 | High Left | WF-05242021-008971 | 2/19/2022 | FT-FY22-01182022-008971-A | <1 | FT-FY22-01182022-008971-B | <1 |
| WS- 008972 | 5/24/2021 | 5/24/2022 | 3 | Cooler | In hallway adjacent to room 306 | Low Right | WF-05242021-008972 | 2/19/2022 | FT-FY22-01182022-008972-A | <1 | FT-FY22-01182022-008972-B | <1 |
| WS- 012562 | 5/24/2021 | 5/24/2022 | 1 | Break Room | In main office adjacent to room 110 | | WF-05242021-012562 | 2/19/2022 | FT-FY22-01182022-012562-A | <1 | FT-FY22-01182022-012562-B | <1 |

Food Prep Sink

| Less than 5ppb - Devices requiring no remediation | | | | | | | | | | | | |
|---|-----------------------|------------------------|-------|----------------|---|------|---------------------|---------------|---------------------------|----------------------------------|---------------------------|----------------------------------|
| Record ID | Filter Installed Date | Filter Expiration Date | Floor | Device Type | Device Location | | Water Filter's Name | Date Analyzed | 1st Draw - Sample ID | FT Final Result - 1st Draw (ppb) | 2nd Draw - Sample ID | FT Final Result - 2nd Draw (ppb) |
| WS- 008920 | 1/11/2022 | 1/11/2023 | 1 | Food Prep Sink | In kitchen first clockwise from entry door | Left | WF-01112022-008920 | 2/19/2022 | FT-FY22-01182022-008920-A | <1 | FT-FY22-01182022-008920-B | <1 |
| WS- 008921 | 1/11/2022 | 1/11/2023 | 1 | Food Prep Sink | In kitchen second clockwise from entry door | Mid | WF-01112022-008921 | 2/19/2022 | FT-FY22-01182022-008921-A | <1 | FT-FY22-01182022-008921-B | <1 |
| WS- 008923 | 1/11/2022 | 1/11/2023 | 1 | Food Prep Sink | In kitchen fourth clockwise from entry door | | WF-01112022-008923 | 2/19/2022 | FT-FY22-01182022-008923-A | <1 | FT-FY22-01182022-008923-B | <1 |