



Savoy Elementary School Lead in Water Test Results



FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008924	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to multi-purpose room	High Left	WF-06222020-008924	1/29/2021	FT-FY21-012021-008924-A	<1	FT-FY21-012021-008924-B	<1
WS- 008925	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to multi-purpose room	Low Right	WF-06222020-008925	1/29/2021	FT-FY21-012021-008925-A	<1	FT-FY21-012021-008925-B	<1
WS- 008926	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 125	High Left	WF-06222020-008926	1/29/2021	FT-FY21-012021-008926-A	<1	FT-FY21-012021-008926-B	<1
WS- 008927	6/22/2020	6/22/2021	1	Cooler	In hallway adjacent to room 125	Low Right	WF-06222020-008927	1/29/2021	FT-FY21-012021-008927-A	<1	FT-FY21-012021-008927-B	<1
WS- 008928	6/22/2020	6/22/2021	1	Cooler	In hallway across from room 107	High Left	WF-06222020-008928	1/29/2021	FT-FY21-012021-008928-A	<1	FT-FY21-012021-008928-B	<1
WS- 008929	6/22/2020	6/22/2021	1	Cooler	In hallway across from room 107	Low Right	WF-06222020-008929	1/29/2021	FT-FY21-012021-008929-A	<1	FT-FY21-012021-008929-B	<1
WS- 008930	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 109	Left	WF-09092020-008930	1/29/2021	FT-FY21-012021-008930-A	<1	FT-FY21-012021-008930-B	<1
WS- 008931	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 109	Right	WF-06222020-008931	1/29/2021	FT-FY21-012021-008931-A	<1	FT-FY21-012021-008931-B	<1
WS- 008932	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 111	Left	WF-09092020-008932	1/29/2021	FT-FY21-012021-008932-A	<1	FT-FY21-012021-008932-B	<1
WS- 008933	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 111	Right	WF-06222020-008933	1/29/2021	FT-FY21-012021-008933-A	<1	FT-FY21-012021-008933-B	<1
WS- 008934	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 113	Left	WF-09092020-008934	1/29/2021	FT-FY21-012021-008934-A	<1	FT-FY21-012021-008934-B	<1
WS- 008935	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 113	Right	WF-06222020-008935	1/29/2021	FT-FY21-012021-008935-A	<1	FT-FY21-012021-008935-B	<1
WS- 008936	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 115	Left	WF-09092020-008936	1/29/2021	FT-FY21-012021-008936-A	<1	FT-FY21-012021-008936-B	<1
WS- 008937	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 115	Right	WF-06222020-008937	1/29/2021	FT-FY21-012021-008937-A	<1	FT-FY21-012021-008937-B	<1
WS- 008938	9/9/2020	9/9/2021	1	Combo Faucet	In classroom 120	Left	WF-09092020-008938	1/29/2021	FT-FY21-012021-008938-A	<1	FT-FY21-012021-008938-B	<1
WS- 008939	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 120	Right	WF-06222020-008939	1/29/2021	FT-FY21-012021-008939-A	<1	FT-FY21-012021-008939-B	<1
WS- 008941	6/22/2020	6/22/2021	1	Combo Fountain	In classroom 122	Right	WF-06222020-008941	1/29/2021	FT-FY21-012021-008941-A	<1	FT-FY21-012021-008941-B	<1
WS- 008942	6/22/2020	6/22/2021	1	Health Suite	In health suite 108		WF-06222020-008942	1/29/2021	FT-FY21-012021-008942-A	<1	FT-FY21-012021-008942-B	<1
WS- 008944	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 203	High Left	WF-06222020-008944	1/29/2021	FT-FY21-012021-008944-A	<1	FT-FY21-012021-008944-B	<1
WS- 008945	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 203	Low Right	WF-06222020-008945	1/29/2021	FT-FY21-012021-008945-A	<1	FT-FY21-012021-008945-B	<1
WS- 008946	6/22/2020	6/22/2021	2	Break Room	In staff lounge 203		WF-06222020-008946	1/29/2021	FT-FY21-012021-008946-A	<1	FT-FY21-012021-008946-B	<1
WS- 008957	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 208	High Left	WF-06222020-008957	1/29/2021	FT-FY21-012021-008957-A	<1	FT-FY21-012021-008957-B	<1
WS- 008958	6/22/2020	6/22/2021	2	Cooler	In hallway adjacent to room 208	Low Right	WF-06222020-008958	1/29/2021	FT-FY21-012021-008958-A	<1	FT-FY21-012021-008958-B	<1
WS- 008963	6/22/2020	6/22/2021	2	Cooler	In media center room 215	High Left	WF-06222020-008963	1/29/2021	FT-FY21-012021-008963-A	<1	FT-FY21-012021-008963-B	<1
WS- 008964	6/22/2020	6/22/2021	2	Cooler	In media center room 215	Low Right	WF-06222020-008964	1/29/2021	FT-FY21-012021-008964-A	<1	FT-FY21-012021-008964-B	<1
WS- 008965	6/22/2020	6/22/2021	3	Cooler	In hallway across from room 300	High Left	WF-06222020-008965	1/29/2021	FT-FY21-012021-008965-A	<1	FT-FY21-012021-008965-B	<1
WS- 008966	6/22/2020	6/22/2021	3	Cooler	In hallway across from room 300	Low Right	WF-06222020-008966	1/29/2021	FT-FY21-012021-008966-A	<1	FT-FY21-012021-008966-B	<1
WS- 008971	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 306	High Left	WF-06222020-008971	1/29/2021	FT-FY21-012021-008971-A	<1	FT-FY21-012021-008971-B	<1
WS- 008972	6/22/2020	6/22/2021	3	Cooler	In hallway adjacent to room 306	Low Right	WF-06222020-008972	1/29/2021	FT-FY21-012021-008972-A	<1	FT-FY21-012021-008972-B	<1
WS- 012562	6/22/2020	6/22/2021	1	Break Room	In main office adjacent to room 110		WF-06222020-012562	1/29/2021	FT-FY21-012021-012562-A	<1	FT-FY21-012021-012562-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
---	--	--	--	--	--	--	--	--	--	--	--	--

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008920	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-01182021-008920	1/29/2021	FT-FY21-012021-008920-A	4.5	FT-FY21-012021-008920-B	<1
WS- 008921	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-01182021-008921	1/29/2021	FT-FY21-012021-008921-A	1.8	FT-FY21-012021-008921-B	<1
WS- 008923	1/18/2021	1/18/2022	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01182021-008923	1/29/2021	FT-FY21-012021-008923-A	1.6	FT-FY21-012021-008923-B	<1