



Savoy Elementary School Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008924	8/30/2022	8/30/2023	1	Cooler	In hallway adjacent to multi-purpose room High Left	WF-08302022-008924	11/7/2022	FT-FY23-10102022-008924-A	<1	FT-FY23-10102022-008924-B	<1
WS- 008925	8/30/2022	8/30/2023	1	Cooler	In hallway adjacent to multi-purpose room Low Right	WF-08302022-008925	11/7/2022	FT-FY23-10102022-008925-A	<1	FT-FY23-10102022-008925-B	<1
WS- 008928	5/16/2022	5/16/2023	1	Cooler	In hallway across from room 107 High Left	WF-05162022-008928	11/7/2022	FT-FY23-10102022-008928-A	<1	FT-FY23-10102022-008928-B	<1
WS- 008929	5/16/2022	5/16/2023	1	Cooler	In hallway across from room 107 Low Right	WF-05162022-008929	11/7/2022	FT-FY23-10102022-008929-A	<1	FT-FY23-10102022-008929-B	<1
WS- 008931	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 109 Right	WF-05162022-008931	11/7/2022	FT-FY23-10102022-008931-A	<1	FT-FY23-10102022-008931-B	<1
WS- 008932	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 111 Left	WF-08222022-008932	11/7/2022	FT-FY23-10102022-008932-A	1.1	FT-FY23-10102022-008932-B	<1
WS- 008933	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 111 Right	WF-05162022-008933	11/7/2022	FT-FY23-10102022-008933-A	<1	FT-FY23-10102022-008933-B	<1
WS- 008934	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 113 Left	WF-08222022-008934	11/7/2022	FT-FY23-10102022-008934-A	2.2	FT-FY23-10102022-008934-B	<1
WS- 008935	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 113 Right	WF-05162022-008935	11/7/2022	FT-FY23-10102022-008935-A	<1	FT-FY23-10102022-008935-B	<1
WS- 008936	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 115 Left	WF-08222022-008936	11/7/2022	FT-FY23-10102022-008936-A	1.0	FT-FY23-10102022-008936-B	<1
WS- 008937	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 115 Right	WF-05162022-008937	11/7/2022	FT-FY23-10102022-008937-A	<1	FT-FY23-10102022-008937-B	<1
WS- 008938	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 120 Left	WF-08222022-008938	11/7/2022	FT-FY23-10102022-008938-A	1.1	FT-FY23-10102022-008938-B	<1
WS- 008939	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 120 Right	WF-05162022-008939	11/7/2022	FT-FY23-10102022-008939-A	<1	FT-FY23-10102022-008939-B	<1
WS- 008940	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 122 Left	WF-08222022-008940	11/7/2022	FT-FY23-10102022-008940-A	1.5	FT-FY23-10102022-008940-B	<1
WS- 008941	5/16/2022	5/16/2023	1	Combo Fountain	In classroom 122 Right	WF-05162022-008941	11/7/2022	FT-FY23-10102022-008941-A	<1	FT-FY23-10102022-008941-B	<1
WS- 008942	5/16/2022	5/16/2023	1	Health Suite	In health suite 108	WF-05162022-008942	11/7/2022	FT-FY23-10102022-008942-A	<1	FT-FY23-10102022-008942-B	<1
WS- 008946	5/16/2022	5/16/2023	2	Break Room	In staff lounge 203	WF-05162022-008946	11/7/2022	FT-FY23-10102022-008946-A	<1	FT-FY23-10102022-008946-B	<1
WS- 008957	5/16/2022	5/16/2023	2	Cooler	In hallway adjacent to room 208 High Left	WF-05162022-008957	11/7/2022	FT-FY23-10102022-008957-A	<1	FT-FY23-10102022-008957-B	<1
WS- 008958	5/16/2022	5/16/2023	2	Cooler	In hallway adjacent to room 208 Low Right	WF-05162022-008958	11/7/2022	FT-FY23-10102022-008958-A	<1	FT-FY23-10102022-008958-B	<1
WS- 008963	5/16/2022	5/16/2023	2	Cooler	In media center room 215 High Left	WF-05162022-008963	11/7/2022	FT-FY23-10102022-008963-A	<1	FT-FY23-10102022-008963-B	<1
WS- 008964	5/16/2022	5/16/2023	2	Cooler	In media center room 215 Low Right	WF-05162022-008964	11/7/2022	FT-FY23-10102022-008964-A	<1	FT-FY23-10102022-008964-B	<1
WS- 008965	5/16/2022	5/16/2023	3	Cooler	In hallway across from room 300 High Left	WF-05162022-008965	11/7/2022	FT-FY23-10102022-008965-A	<1	FT-FY23-10102022-008965-B	<1
WS- 008966	5/16/2022	5/16/2023	3	Cooler	In hallway across from room 300 Low Right	WF-05162022-008966	11/7/2022	FT-FY23-10102022-008966-A	<1	FT-FY23-10102022-008966-B	<1
WS- 008971	5/16/2022	5/16/2023	3	Cooler	In hallway adjacent to room 306 High Left	WF-05162022-008971	11/7/2022	FT-FY23-10102022-008971-A	<1	FT-FY23-10102022-008971-B	<1
WS- 008972	5/16/2022	5/16/2023	3	Cooler	In hallway adjacent to room 306 Low Right	WF-05162022-008972	11/7/2022	FT-FY23-10102022-008972-A	<1	FT-FY23-10102022-008972-B	<1
WS- 012562	5/16/2022	5/16/2023	1	Break Room	In main office adjacent to room 110	WF-05162022-012562	11/7/2022	FT-FY23-10102022-012562-A	<1	FT-FY23-10102022-012562-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008920	1/11/2022	1/11/2023	1	Food Prep Sink	In kitchen first clockwise from entry door Left	WF-01112022-008920	11/7/2022	FT-FY23-10102022-008920-A	<1	FT-FY23-10102022-008920-B	<1
WS- 008921	1/11/2022	1/11/2023	1	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-01112022-008921	11/7/2022	FT-FY23-10102022-008921-A	<1	FT-FY23-10102022-008921-B	<1
WS- 008923	1/11/2022	1/11/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-01112022-008923	11/7/2022	FT-FY23-10102022-008923-A	<1	FT-FY23-10102022-008923-B	<1

FY23 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008930	8/22/2022	8/22/2023	1	Combo Faucet	In classroom 109	Left	WF-08222022-008930	11/7/2022	FT-FY23-10102022-008930-A	5.2	FT-FY23-10102022-008930-B	<1