



SAVOY ES LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location		1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SAVOY ELEMENTARY SCHOOL	WS- 008920	8/19/2016	1	Food Prep Sink	In kitchen first clockwise from entry door	Left	FT-82016-008920-A	< 1	FT-82016-008920-B	< 1
2	SAVOY ELEMENTARY SCHOOL	WS- 008921	8/19/2016	1	Food Prep Sink	In kitchen second clockwise from entry door	Mid	FT-82016-008921-A	< 1	FT-82016-008921-B	< 1
3	SAVOY ELEMENTARY SCHOOL	WS- 008924	8/19/2016	1	Cooler	In hallway adjacent to multi-purpose room	High Left	FT-82016-008924-A	< 1	FT-82016-008924-B	< 1
4	SAVOY ELEMENTARY SCHOOL	WS- 008925	8/19/2016	1	Cooler	In hallway adjacent to multi-purpose room	Low Right	FT-82016-008925-A	< 1	FT-82016-008925-B	< 1
5	SAVOY ELEMENTARY SCHOOL	WS- 008926	8/19/2016	1	Cooler	In hallway adjacent to room 125	High Left	FT-82016-008926-A	< 1	FT-82016-008926-B	< 1
6	SAVOY ELEMENTARY SCHOOL	WS- 008927	8/19/2016	1	Cooler	In hallway adjacent to room 125	Low Right	FT-82016-008927-A	< 1	FT-82016-008927-B	< 1
7	SAVOY ELEMENTARY SCHOOL	WS- 008928	8/19/2016	1	Cooler	In hallway across from room 107	High Left	FT-82016-008928-A	< 1	FT-82016-008928-B	< 1
8	SAVOY ELEMENTARY SCHOOL	WS- 008929	8/19/2016	1	Cooler	In hallway across from room 107	Low Right	FT-82016-008929-A	< 1	FT-82016-008929-B	< 1
9	SAVOY ELEMENTARY SCHOOL	WS- 008931	8/19/2016	1	Fountain	In classroom 109	Right	FT-82016-008931-A	< 1	FT-82016-008931-B	< 1
10	SAVOY ELEMENTARY SCHOOL	WS- 008933	8/19/2016	1	Fountain	In classroom 111	Right	FT-82016-008933-A	< 1	FT-82016-008933-B	< 1
11	SAVOY ELEMENTARY SCHOOL	WS- 008935	8/19/2016	1	Fountain	In classroom 113	Right	FT-82016-008935-A	< 1	FT-82016-008935-B	< 1
12	SAVOY ELEMENTARY SCHOOL	WS- 008937	8/19/2016	1	Fountain	In classroom 115	Right	FT-82016-008937-A	< 1	FT-82016-008937-B	< 1
13	SAVOY ELEMENTARY SCHOOL	WS- 008939	8/19/2016	1	Fountain	In classroom 120	Right	FT-82016-008939-A	< 1	FT-82016-008939-B	< 1
14	SAVOY ELEMENTARY SCHOOL	WS- 008941	8/19/2016	1	Fountain	In classroom 122	Right	FT-82016-008941-A	< 1	FT-82016-008941-B	< 1
15	SAVOY ELEMENTARY SCHOOL	WS- 008942	8/19/2016	1	Health Suite	In health suite 108		FT-82016-008942-A	< 1	FT-82016-008942-B	< 1
16	SAVOY ELEMENTARY SCHOOL	WS- 008944	8/19/2016	2	Cooler	In hallway adjacent to room 203	High Left	FT-82016-008944-A	< 1	FT-82016-008944-B	< 1
17	SAVOY ELEMENTARY SCHOOL	WS- 008945	8/19/2016	2	Cooler	In hallway adjacent to room 203	Low Right	FT-82016-008945-A	< 1	FT-82016-008945-B	< 1
18	SAVOY ELEMENTARY SCHOOL	WS- 008957	8/19/2016	2	Cooler	In hallway adjacent to room 208	High Left	FT-82016-008957-A	< 1	FT-82016-008957-B	< 1
19	SAVOY ELEMENTARY SCHOOL	WS- 008958	8/19/2016	2	Cooler	In hallway adjacent to room 208	Low Right	FT-82016-008958-A	< 1	FT-82016-008958-B	< 1
20	SAVOY ELEMENTARY SCHOOL	WS- 008963	8/19/2016	2	Cooler	In media center room 215	High Left	FT-82016-008963-A	< 1	FT-82016-008963-B	< 1
21	SAVOY ELEMENTARY SCHOOL	WS- 008964	8/19/2016	2	Cooler	In media center room 215	Low Right	FT-82016-008964-A	< 1	FT-82016-008964-B	< 1
22	SAVOY ELEMENTARY SCHOOL	WS- 008965	8/19/2016	3	Cooler	In hallway across from room 300	High Left	FT-82016-008965-A	< 1	FT-82016-008965-B	< 1
23	SAVOY ELEMENTARY SCHOOL	WS- 008966	8/19/2016	3	Cooler	In hallway across from room 300	Low Right	FT-82016-008966-A	< 1	FT-82016-008966-B	< 1
24	SAVOY ELEMENTARY SCHOOL	WS- 008971	8/19/2016	3	Cooler	In hallway adjacent to room 306	High Left	FT-82016-008971-A	< 1	FT-82016-008971-B	< 1
25	SAVOY ELEMENTARY SCHOOL	WS- 008972	8/19/2016	3	Cooler	In hallway adjacent to room 306	Low Right	FT-82016-008972-A	< 1	FT-82016-008972-B	< 1