



SAVOY LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008979	Classroom	3	In room 310	WT-042916-8996- A	2.17	WT-042916-8996- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008978	Classroom	3	In room 309	WT-042916-8995- A	41.9	WT-042916-8995- B	1.33	Filter will be installed and then retested			
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008977	Classroom	3	In room 308	WT-042916-8994- A	15.7	WT-042916-8994- B	< 1	Filter will be installed and then retested			
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008976	Classroom	3	In room 306	WT-042916-8993- A	< 1	WT-042916-8993- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008975	Classroom	3	In room 306	WT-042916-8992- A	< 1	WT-042916-8992- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008974	Classroom	3	In room 307	WT-042916-8991- A	5.56	WT-042916-8991- B	2.75				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008973	Classroom	3	In room 306	WT-042916-8990- A	< 1	WT-042916-8990- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008972	Cooler	3	In hallway adjacent to room 306	WT-042916-8989- A	< 1	WT-042916-8989- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008971	Cooler	3	In hallway adjacent to room 306	WT-042916-8988- A	< 1	WT-042916-8988- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008970	Classroom	3	In room 305	WT-042916-8987- A	1.3	WT-042916-8987- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008969	Classroom	3	In room 304	WT-042916-8986- A	1.62	WT-042916-8986- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008968	Classroom	3	In room 301	WT-042916-8985- A	< 1	WT-042916-8985- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008967	Classroom	3	In room 302	WT-042916-8984- A	< 1	WT-042916-8984- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008966	Cooler	3	In hallways across from the room 300	WT-042916-8983- A	< 1	WT-042916-8983- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008965	Cooler	3	In hallway across from the room 300	WT-042916-8982- A	< 1	WT-042916-8982- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008964	Classroom	2	In media center room 215	WT-042916-8981- A	< 1	WT-042916-8981- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008963	Cooler	2	In room media center room 215	WT-042916-8980- A	< 1	WT-042916-8980- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008962	Classroom	2	In room 211	WT-042916-8979- A	< 1	WT-042916-8979- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008961	Classroom	2	In room 210	WT-042916-8978- A	4.99	WT-042916-8978- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008960	Classroom	2	In room 209	WT-042916-8977- A	4.42	WT-042916-8977- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008959	Classroom	2	In room 208	WT-042916-8976- A	13.3	WT-042916-8976- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008958	Cooler	2	In hallway adjacent to room 208	WT-042916-8975- A	< 1	WT-042916-8975- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008957	Cooler	2	In hallway adjacent to room 208	WT-042916-8974- A	< 1	WT-042916-8974- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008956	Classroom	2	In room 206	WT-042916-8973- A	3.89	WT-042916-8973- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008955	Classroom	2	In science lab room 206 clockwise 4	WT-042916-8972- A	3.78	WT-042916-8972- B	1.55				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008954	Classroom	2	In science lab room 206 clockwise 4	WT-042916-8971- A	1.47	WT-042916-8971- B	1.27				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008953	Classroom	2	In science lab room 206 clockwise 3	WT-042916-8970- A	3.1	WT-042916-8970- B	1.29				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008952	Classroom	2	In science lab room 206 clockwise 3	WT-042916-8969- A	1.17	WT-042916-8969- B	1.03				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008951	Classroom	2	In science lab room 206 clockwise 2	WT-042916-8968- A	1.63	WT-042916-8968- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008950	Classroom	2	In science lab room 206 clockwise 2	WT-042916-8967- A	1.04	WT-042916-8967- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008949	Classroom	2	In science lab room 206 clockwise 1	WT-042916-8966- A	1.57	WT-042916-8966- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008948	Classroom	2	In science lab room 206 clockwise 1	WT-042916-8965- A	3.08	WT-042916-8965- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008947	Classroom	2	In room 202	WT-042916-8964- A	< 1	WT-042916-8964- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008946	Classroom	2	In teacher's lounge	WT-042916-8963- A	< 1	WT-042916-8963- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008945	Cooler	1	In hallway adjacent to room 203	WT-042916-8962- A	< 1	WT-042916-8962- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008944	Cooler	2	In hallway adjacent to room 203	WT-042916-8961- A	< 1	WT-042916-8961- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008943	Classroom	1	In room200	WT-042916-8960- A	2.77	WT-042916-8960- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008942	Health Suite	1	In nurse suite 108	WT-042916-8959- A	< 1	WT-042916-8959- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008941	Fountain	1	In room 122	WT-042916-8958- A	< 1	WT-042916-8958- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008940	Classroom	1	In room 122	WT-042916-8957- A	2.89	WT-042916-8957- B	1.03				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008939	Fountain	1	In room 120	WT-042916-8956- A	< 1	WT-042916-8956- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008938	Classroom	1	In room 120	WT-042916-8955- A	3.96	WT-042916-8955- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008937	Fountain	1	In room 115	WT-042916-8954- A	< 1	WT-042916-8954- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008936	Classroom	1	In room 115	WT-042916-8953- A	6.51	WT-042916-8953- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008935	Fountain	1	In room 113	WT-042916-8952- A	< 1	WT-042916-8952- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008934	Classroom	1	In room 113	WT-042916-8951- A	10.3	WT-042916-8951- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008933	Fountain	1	In room 111	WT-042916-8950- A	< 1	WT-042916-8950- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008932	Classroom	1	In room 111	WT-042916-8949- A	1.07	WT-042916-8949- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008931	Fountain	1	In room 109	WT-042916-8948- A	< 1	WT-042916-8948- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008930	Classroom	1	In room 109	WT-042916-8947- A	1.32	WT-042916-8947- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008929	Cooler	1	In hallway across from the room 107	WT-042916-8946- A	< 1	WT-042916-8946- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008928	Cooler	1	In hallway across from the room 107	WT-042916-8945- A	< 1	WT-042916-8945- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008927	Cooler	1	In hallway adjacent to room 125	WT-042916-8944- A	< 1	WT-042916-8944- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008926	Cooler	1	Adjacent to room 125	WT-042916-8943- A	< 1	WT-042916-8943- B	< 1				
SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008925	Kitchen	1	In hallway adjacent to multi purpose room	WT-042916-8942- A	< 1	WT-042916-8942- B	< 1				



SAVOY LEAD WATER TEST RESULTS

May 16th, 2016



Building Location	Sample Collected Date	Water Source ID	Device Type	Floor	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)	Remediation	Retest Date	Retest 1st Draw	Retest 2nd Draw
56 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008924	Cooler	1	Adjacent to multipurpose room	WT-042916-8941- A	< 1	WT-042916-8941- B	< 1				
57 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008923	Kitchen	1	In kitchen	WT-042916-8940- A	< 1	WT-042916-8940- B	< 1				
58 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008922	Kitchen	1	In kitchen	WT-042916-8939- A	< 1	WT-042916-8939- B	1.73				
59 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008921	Kitchen	1	In kitchen	WT-042916-8938- A	< 1	WT-042916-8938- B	3.11				
60 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008920	Kitchen	1	In kitchen	WT-042916-8937- A	3.61	WT-042916-8937- B	< 1				
61 SAVOY ELEMENTARY SCHOOL	5/7/2016	WS- 008919	Utility	1	In the custodian room	WT-042916-8936- A	4.01	WT-042916-8936- B	8.14				

Footnotes:

A - First draw sample is collected after the plumbing system has not been used for at least 6 hours.

B - Second draw sample is collected after a 60 second flush at that device after the first draw.