



SAVOY ES LEAD WATER TEST RESULTS



Initial Filter Test After Installation

Less than 1 ppb - Device Returned to Service										
	Building Location: Building Name	Water Source ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	SAVOY ELEMENTARY SCHOOL	WS- 012562	1/11/2017	1	Break Room	In main office adjacent to room 110	FT-102016-012562-A	< 1	FT-102016-012562-B	< 1
2	SAVOY ELEMENTARY SCHOOL	WS- 008946	1/11/2017	2	Break Room	In staff lounge 203	FT-102016-008946-A	< 1	FT-102016-008946-B	< 1
3	SAVOY ELEMENTARY SCHOOL	WS- 008930	1/11/2017	1	Combo Faucet	In classroom 109	Left FT-112016-008930-A	< 1	FT-112016-008930-B	< 1

Greater than 1 ppb - Devices Shut Off and Corrective Action Taken										
1	SAVOY ELEMENTARY SCHOOL	WS- 008934	1/11/2017	1	Combo Faucet	In classroom 113	Left FT-112016-008934-A	1.8	FT-112016-008934-B	< 1
2	SAVOY ELEMENTARY SCHOOL	WS- 008932	1/11/2017	1	Combo Faucet	In classroom 111	Left FT-112016-008932-A	2.4	FT-112016-008932-B	< 1
3	SAVOY ELEMENTARY SCHOOL	WS- 008936	1/11/2017	1	Combo Faucet	In classroom 115	Left FT-112016-008936-A	1.5	FT-112016-008936-B	< 1
4	SAVOY ELEMENTARY SCHOOL	WS- 008938	1/11/2017	1	Combo Faucet	In classroom 120	Left FT-112016-008938-A	1.9	FT-112016-008938-B	< 1
5	SAVOY ELEMENTARY SCHOOL	WS- 008940	1/11/2017	1	Combo Faucet	In classroom 122	Left FT-112016-008940-A	1.8	FT-112016-008940-B	< 1

First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

Less than 1 ppb - Device Returned to Service										
1	SAVOY ELEMENTARY SCHOOL	WS- 008940	2/8/2017	1	Combo Faucet	In classroom 122	Left FT-112016-008940-A	< 1	FT-112016-008940-B	< 1

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	SAVOY ELEMENTARY SCHOOL	WS- 008934	2/8/2017	1	Combo Faucet	In classroom 113	Left FT-112016-008934-A	2.9	FT-112016-008934-B	< 1
2	SAVOY ELEMENTARY SCHOOL	WS- 008932	2/8/2017	1	Combo Faucet	In classroom 111	Left FT-112016-008932-A	1.3	FT-112016-008932-B	< 1
3	SAVOY ELEMENTARY SCHOOL	WS- 008936	2/8/2017	1	Combo Faucet	In classroom 115	Left FT-112016-008936-A	2	FT-112016-008936-B	< 1
4	SAVOY ELEMENTARY SCHOOL	WS- 008938	2/8/2017	1	Combo Faucet	In classroom 120	Left FT-112016-008938-A	4.1	FT-112016-008938-B	< 1

Second Filter Re-Test (After Device Replacement)

Greater than 1 ppb - Devices Remain Shut off, Continued Remediation										
1	SAVOY ELEMENTARY SCHOOL	WS- 008934	3/14/2017	1	Combo Faucet	In classroom 113	Left FT-112016-008934-A	4.3	FT-112016-008934-B	< 1
2	SAVOY ELEMENTARY SCHOOL	WS- 008932	3/14/2017	1	Combo Faucet	In classroom 111	Left FT-112016-008932-A	2.9	FT-112016-008932-B	< 1
3	SAVOY ELEMENTARY SCHOOL	WS- 008936	3/14/2017	1	Combo Faucet	In classroom 115	Left FT-112016-008936-A	2.7	FT-112016-008936-B	< 1
4	SAVOY ELEMENTARY SCHOOL	WS- 008938	3/14/2017	1	Combo Faucet	In classroom 120	Left FT-112016-008938-A	10	FT-112016-008938-B	< 1

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb