



# Savoy ES Lead Water Test Results



## FY19 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008924	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to multi-purpose room High Left	WF-05162018-008924	11/2/2018	FT-FY19-102018-008924-A	< 1	FT-FY19-102018-008924-B	< 1
WS-008925	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to multi-purpose room Low Right	WF-05162018-008925	11/2/2018	FT-FY19-102018-008925-A	< 1	FT-FY19-102018-008925-B	< 1
WS-008926	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to room 125 High Left	WF-05162018-008926	11/2/2018	FT-FY19-102018-008926-A	< 1	FT-FY19-102018-008926-B	< 1
WS-008927	5/16/2018	5/16/2019	1	Cooler	In hallway adjacent to room 125 Low Right	WF-05162018-008927	11/2/2018	FT-FY19-102018-008927-A	< 1	FT-FY19-102018-008927-B	< 1
WS-008928	5/16/2018	5/16/2019	1	Cooler	In hallway across from room 107 High Left	WF-05162018-008928	11/2/2018	FT-FY19-102018-008928-A	< 1	FT-FY19-102018-008928-B	< 1
WS-008929	5/16/2018	5/16/2019	1	Cooler	In hallway across from room 107 Low Right	WF-05162018-008929	11/2/2018	FT-FY19-102018-008929-A	< 1	FT-FY19-102018-008929-B	< 1
WS-008930	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 109 Left	WF-09242018-008930	11/2/2018	FT-FY19-102018-008930-A	< 1	FT-FY19-102018-008930-B	< 1
WS-008931	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 109 Right	WF-05162018-008931	11/2/2018	FT-FY19-102018-008931-A	< 1	FT-FY19-102018-008931-B	< 1
WS-008932	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 111 Left	WF-09242018-008932	11/2/2018	FT-FY19-102018-008932-A	< 1	FT-FY19-102018-008932-B	< 1
WS-008933	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 111 Right	WF-05162018-008933	11/2/2018	FT-FY19-102018-008933-A	< 1	FT-FY19-102018-008933-B	< 1
WS-008934	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 113 Left	WF-09242018-008934	11/2/2018	FT-FY19-102018-008934-A	< 1	FT-FY19-102018-008934-B	< 1
WS-008935	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 113 Right	WF-05162018-008935	11/2/2018	FT-FY19-102018-008935-A	< 1	FT-FY19-102018-008935-B	< 1
WS-008936	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 115 Left	WF-09242018-008936	11/2/2018	FT-FY19-102018-008936-A	< 1	FT-FY19-102018-008936-B	< 1
WS-008937	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 115 Right	WF-05162018-008937	11/2/2018	FT-FY19-102018-008937-A	< 1	FT-FY19-102018-008937-B	< 1
WS-008938	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 120 Left	WF-09242018-008938	11/2/2018	FT-FY19-102018-008938-A	< 1	FT-FY19-102018-008938-B	< 1
WS-008939	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 120 Right	WF-05162018-008939	11/2/2018	FT-FY19-102018-008939-A	< 1	FT-FY19-102018-008939-B	< 1
WS-008940	9/24/2018	9/24/2019	1	Combo Faucet	In classroom 122 Left	WF-09242018-008940	11/2/2018	FT-FY19-102018-008940-A	< 1	FT-FY19-102018-008940-B	< 1
WS-008941	5/16/2018	5/16/2019	1	Combo Fountain	In classroom 122 Right	WF-05162018-008941	11/2/2018	FT-FY19-102018-008941-A	< 1	FT-FY19-102018-008941-B	< 1
WS-008942	5/16/2018	5/16/2019	1	Health Suite	In health suite 108	WF-05162018-008942	11/2/2018	FT-FY19-102018-008942-A	< 1	FT-FY19-102018-008942-B	< 1
WS-008944	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to room 203 High Left	WF-05162018-008944	11/2/2018	FT-FY19-102018-008944-A	< 1	FT-FY19-102018-008944-B	< 1
WS-008945	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to room 203 Low Right	WF-05162018-008945	11/2/2018	FT-FY19-102018-008945-A	< 1	FT-FY19-102018-008945-B	< 1
WS-008946	5/16/2018	5/16/2019	2	Break Room	In staff lounge 203	WF-05162018-008946	11/2/2018	FT-FY19-102018-008946-A	< 1	FT-FY19-102018-008946-B	< 1
WS-008957	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to room 208 High Left	WF-05162018-008957	11/2/2018	FT-FY19-102018-008957-A	< 1	FT-FY19-102018-008957-B	< 1
WS-008958	5/16/2018	5/16/2019	2	Cooler	In hallway adjacent to room 208 Low Right	WF-05162018-008958	11/2/2018	FT-FY19-102018-008958-A	< 1	FT-FY19-102018-008958-B	< 1
WS-008963	5/16/2018	5/16/2019	2	Cooler	In media center room 215 High Left	WF-05162018-008963	11/2/2018	FT-FY19-102018-008963-A	< 1	FT-FY19-102018-008963-B	< 1
WS-008964	5/16/2018	5/16/2019	2	Cooler	In media center room 215 Low Right	WF-05162018-008964	11/2/2018	FT-FY19-102018-008964-A	< 1	FT-FY19-102018-008964-B	< 1
WS-008965	5/16/2018	5/16/2019	3	Cooler	In hallway across from room 300 High Left	WF-05162018-008965	11/2/2018	FT-FY19-102018-008965-A	< 1	FT-FY19-102018-008965-B	< 1
WS-008966	5/16/2018	5/16/2019	3	Cooler	In hallway across from room 300 Low Right	WF-05162018-008966	11/2/2018	FT-FY19-102018-008966-A	< 1	FT-FY19-102018-008966-B	< 1
WS-008971	5/16/2018	5/16/2019	3	Cooler	In hallway adjacent to room 306 High Left	WF-05162018-008971	11/2/2018	FT-FY19-102018-008971-A	< 1	FT-FY19-102018-008971-B	< 1
WS-008972	5/16/2018	5/16/2019	3	Cooler	In hallway adjacent to room 306 Low Right	WF-05162018-008972	11/2/2018	FT-FY19-102018-008972-A	< 1	FT-FY19-102018-008972-B	< 1
WS-012562	5/16/2018	5/16/2019	1	Break Room	In main office adjacent to room 110	WF-05162018-012562	11/2/2018	FT-FY19-102018-012562-A	< 1	FT-FY19-102018-012562-B	< 1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008920	1	Food Prep Sink	In kitchen first clockwise from entry door      Left	11/2/2018	FT-FY19-102018-008920-A	< 1	FT-FY19-102018-008920-B	< 1
WS- 008921	1	Food Prep Sink	In kitchen second clockwise from entry door      Mid	11/2/2018	FT-FY19-102018-008921-A	< 1	FT-FY19-102018-008921-B	< 1