



Savoy Elementary School Lead in Water Test Results

FY24 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008918	5/8/2023	5/8/2024	1	Bottle Filler	In hallway adjacent to multi-purpose room	WF-05082023-008918	12/4/2023	FT-FY24-10102023-008918-A	<1	FT-FY24-10102023-008918-B	<1
WS-008924	5/8/2023	5/8/2024	1	Cooler	In hallway adjacent to multi-purpose room High Left	WF-05082023-008924	12/4/2023	FT-FY24-10102023-008924-A	<1	FT-FY24-10102023-008924-B	<1
WS-008925	5/8/2023	5/8/2024	1	Cooler	In hallway adjacent to multi-purpose room Low Right	WF-05082023-008925	12/4/2023	FT-FY24-10102023-008925-A	<1	FT-FY24-10102023-008925-B	<1
WS-008926	5/8/2023	5/8/2024	1	Cooler	In hallway adjacent to room 125 High Left	WF-05082023-008926	12/4/2023	FT-FY24-10102023-008926-A	<1	FT-FY24-10102023-008926-B	<1
WS-008928	5/8/2023	5/8/2024	1	Cooler	In hallway across from room 107 High Left	WF-05082023-008928	12/4/2023	FT-FY24-10102023-008928-A	<1	FT-FY24-10102023-008928-B	<1
WS-008929	5/8/2023	5/8/2024	1	Cooler	In hallway across from room 107 Low Right	WF-05082023-008929	12/4/2023	FT-FY24-10102023-008929-A	<1	FT-FY24-10102023-008929-B	<1
WS-008931	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 109 Right	WF-05082023-008931	12/4/2023	FT-FY24-10102023-008931-A	<1	FT-FY24-10102023-008931-B	<1
WS-008932	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 111 Left	WF-08162023-008932	12/4/2023	FT-FY24-10102023-008932-A	<1	FT-FY24-10102023-008932-B	<1
WS-008933	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 111 Right	WF-05082023-008933	12/4/2023	FT-FY24-10102023-008933-A	<1	FT-FY24-10102023-008933-B	<1
WS-008934	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 113 Left	WF-08162023-008934	12/4/2023	FT-FY24-10102023-008934-A	<1	FT-FY24-10102023-008934-B	<1
WS-008936	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 115 Left	WF-08162023-008936	12/4/2023	FT-FY24-10102023-008936-A	<1	FT-FY24-10102023-008936-B	<1
WS-008937	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 115 Right	WF-05082023-008937	12/4/2023	FT-FY24-10102023-008937-A	<1	FT-FY24-10102023-008937-B	<1
WS-008938	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 120 Left	WF-08162023-008938	12/4/2023	FT-FY24-10102023-008938-A	<1	FT-FY24-10102023-008938-B	<1
WS-008939	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 120 Right	WF-05082023-008939	12/4/2023	FT-FY24-10102023-008939-A	<1	FT-FY24-10102023-008939-B	<1
WS-008940	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 122 Left	WF-08162023-008940	12/4/2023	FT-FY24-10102023-008940-A	<1	FT-FY24-10102023-008940-B	<1
WS-008941	5/8/2023	5/8/2024	1	Combo Fountain	In classroom 122 Right	WF-05082023-008941	12/4/2023	FT-FY24-10102023-008941-A	<1	FT-FY24-10102023-008941-B	<1
WS-008942	5/8/2023	5/8/2024	1	Health Suite	In health suite 108	WF-05082023-008942	12/4/2023	FT-FY24-10102023-008942-A	<1	FT-FY24-10102023-008942-B	<1
WS-008944	5/8/2023	5/8/2024	2	Cooler	In hallway adjacent to room 203 High Left	WF-05082023-008944	12/4/2023	FT-FY24-10102023-008944-A	<1	FT-FY24-10102023-008944-B	<1
WS-008946	5/8/2023	5/8/2024	2	Break Room	In staff lounge 203	WF-05082023-008946	12/4/2023	FT-FY24-10102023-008946-A	<1	FT-FY24-10102023-008946-B	<1
WS-008957	5/8/2023	5/8/2024	2	Cooler	In hallway adjacent to room 208 High Left	WF-05082023-008957	12/4/2023	FT-FY24-10102023-008957-A	<1	FT-FY24-10102023-008957-B	<1
WS-008958	5/8/2023	5/8/2024	2	Cooler	In hallway adjacent to room 208 Low Right	WF-05082023-008958	12/4/2023	FT-FY24-10102023-008958-A	<1	FT-FY24-10102023-008958-B	<1
WS-008963	5/8/2023	5/8/2024	2	Cooler	In media center room 215 High Left	WF-05082023-008963	12/4/2023	FT-FY24-10102023-008963-A	<1	FT-FY24-10102023-008963-B	<1
WS-008964	5/8/2023	5/8/2024	2	Cooler	In media center room 215 Low Right	WF-05082023-008964	12/4/2023	FT-FY24-10102023-008964-A	<1	FT-FY24-10102023-008964-B	<1
WS-008965	5/8/2023	5/8/2024	3	Cooler	In hallway across from room 300 High Left	WF-05082023-008965	12/4/2023	FT-FY24-10102023-008965-A	<1	FT-FY24-10102023-008965-B	<1
WS-008966	5/8/2023	5/8/2024	3	Cooler	In hallway across from room 300 Low Right	WF-05082023-008966	12/4/2023	FT-FY24-10102023-008966-A	<1	FT-FY24-10102023-008966-B	<1
WS-008971	5/8/2023	5/8/2024	3	Cooler	In hallway adjacent to room 306 High Left	WF-05082023-008971	12/4/2023	FT-FY24-10102023-008971-A	<1	FT-FY24-10102023-008971-B	<1
WS-008972	5/8/2023	5/8/2024	3	Cooler	In hallway adjacent to room 306 Low Right	WF-05082023-008972	12/4/2023	FT-FY24-10102023-008972-A	<1	FT-FY24-10102023-008972-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-008921	12/22/2022	12/22/2023	1	Food Prep Sink	In kitchen second clockwise from entry door Mid	WF-12222022-008921	12/4/2023	FT-FY24-10102023-008921-A	<1	FT-FY24-10102023-008921-B	<1
WS-008923	12/22/2022	12/22/2023	1	Food Prep Sink	In kitchen fourth clockwise from entry door	WF-12222022-008923	12/4/2023	FT-FY24-10102023-008923-A	<1	FT-FY24-10102023-008923-B	<1

FY24 Filter Test

Greater than 5ppb - Devices requiring remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008930	8/16/2023	8/16/2024	1	Combo Faucet	In classroom 109	Left	WF-08162023-008930	12/4/2023	FT-FY24-10102023-008930-A	7.4	FT-FY24-10102023-008930-B	<1