



School w/in a School @ Goding ES Lead Water Test Results



FY19 Filter Test

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 008617	9/18/2018	9/18/2019	Ground Floor	Classroom Faucet	In classroom 002	WF-09182018-008617	10/26/2018	FT-FY19-102018-008617-A	< 1	FT-FY19-102018-008617-B	< 1
WS- 008618	9/18/2018	9/18/2019	Ground Floor	Classroom Faucet	In classroom 003	WF-09182018-008618	10/26/2018	FT-FY19-102018-008618-A	< 1	FT-FY19-102018-008618-B	< 1
WS- 010559	6/13/2018	6/13/2019	Ground Floor	Cooler	In hallway adjacent to custodian closet	WF-06132018-010559	10/26/2018	FT-FY19-102018-010559-A	< 1	FT-FY19-102018-010559-B	< 1
WS- 010560	6/13/2018	6/13/2019	Ground Floor	Health Suite	In health suite	WF-06132018-010560	10/26/2018	FT-FY19-102018-010560-A	< 1	FT-FY19-102018-010560-B	< 1
WS- 010561	9/18/2018	9/18/2019	Ground Floor	Classroom Faucet	In classroom 007	WF-09182018-010561	10/26/2018	FT-FY19-102018-010561-A	< 1	FT-FY19-102018-010561-B	< 1
WS- 010562	9/18/2018	9/18/2019	Ground Floor	Classroom Faucet	In classroom 006	WF-09182018-010562	10/26/2018	FT-FY19-102018-010562-A	< 1	FT-FY19-102018-010562-B	< 1
WS- 010563	6/13/2018	6/13/2019	Ground Floor	Cooler	In gym/cafeteria	WF-06132018-010563	10/26/2018	FT-FY19-102018-010563-A	< 1	FT-FY19-102018-010563-B	< 1
WS- 010568	6/13/2018	6/13/2019	1	Cooler	In hallway adjacent to custodians' clesset	WF-06132018-010568	10/26/2018	FT-FY19-102018-010568-A	< 1	FT-FY19-102018-010568-B	< 1
WS- 010570	6/13/2018	6/13/2019	1	Cooler	In hallway adjacent to room 103	WF-06132018-010570	10/26/2018	FT-FY19-102018-010570-A	< 1	FT-FY19-102018-010570-B	< 1
WS- 010571	6/13/2018	6/13/2019	1	Health Suite	In health suite adjacent to principal office	WF-06132018-010571	10/26/2018	FT-FY19-102018-010571-A	< 1	FT-FY19-102018-010571-B	< 1
WS- 010572	6/13/2018	6/13/2019	2	Cooler	In hallway adjacent to room 203	WF-06132018-010572	10/26/2018	FT-FY19-102018-010572-A	< 1	FT-FY19-102018-010572-B	< 1
WS- 010581	6/13/2018	6/13/2019	2	Cooler	In hallway adjacent to custodians' clesset	WF-06132018-010581	10/26/2018	FT-FY19-102018-010581-A	< 1	FT-FY19-102018-010581-B	< 1
WS- 010584	9/18/2018	9/18/2019	3	Classroom Faucet	In classroom 307	WF-09182018-010584	10/26/2018	FT-FY19-102018-010584-A	< 1	FT-FY19-102018-010584-B	< 1
WS- 010586	6/13/2018	6/13/2019	3	Cooler	In hallway adjacent to custodians' clesset	WF-06132018-010586	10/26/2018	FT-FY19-102018-010586-A	< 1	FT-FY19-102018-010586-B	< 1
WS- 010587	6/13/2018	6/13/2019	3	Cooler	In hallway adjacent to room 303	WF-06132018-010587	10/26/2018	FT-FY19-102018-010587-A	< 1	FT-FY19-102018-010587-B	< 1
WS- 010589	6/13/2018	6/13/2019	4	Cooler	In hallway adjacent to staff restroom	WF-06132018-010589	10/26/2018	FT-FY19-102018-010589-A	< 1	FT-FY19-102018-010589-B	< 1
WS- 010590	6/13/2018	6/13/2019	4	Cooler	In hallway adjacent to room 403	WF-06132018-010590	10/26/2018	FT-FY19-102018-010590-A	< 1	FT-FY19-102018-010590-B	< 1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation									
Record ID	Floor	Device Type	Device Location	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS- 010565	Ground Floor	Food Prep Sink	In kitchen Right	10/26/2018	FT-FY19-102018-010565-A	< 1	FT-FY19-102018-010565-B	< 1	