



# FRANCIS EC LEAD WATER TEST RESULTS



## Initial Filter Test After Installation

	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	Final Result - 2nd Draw (ppb)
1	FRANCIS EDUCATIONAL CAMPUS	WS- 008717	12/15/2016	1	Classroom Faucet	In classroom 104	FT-122016-008717-A	< 1	FT-122016-008717-B	< 1
2	FRANCIS EDUCATIONAL CAMPUS	WS- 008719	12/15/2016	1	Classroom Faucet	In classroom 102	FT-122016-008719-A	2.9	FT-122016-008719-B	< 1
3	FRANCIS EDUCATIONAL CAMPUS	WS- 008722	12/15/2016	1	Classroom Faucet	In classroom 101	FT-122016-008722-A	< 1	FT-122016-008722-B	< 1
4	FRANCIS EDUCATIONAL CAMPUS	WS- 008733	12/15/2016	1	Classroom Faucet	In classroom 110	FT-122016-008733-A	< 1	FT-122016-008733-B	< 1
5	FRANCIS EDUCATIONAL CAMPUS	WS- 008735	12/15/2016	1	Classroom Faucet	In classroom 109	FT-122016-008735-A	< 1	FT-122016-008735-B	< 1

## First Filter Re-Test (After Filter and Plumbing Check with Aerator Replacement)

2	FRANCIS EDUCATIONAL CAMPUS	WS- 008719	1/25/2017	1	Classroom Faucet	In classroom 102	FT-122016-008719-A	< 1	FT-122016-008719-B	< 1
---	----------------------------	------------	-----------	---	------------------	------------------	--------------------	-----	--------------------	-----

Note :

Filter re-tests are only performed to devices that have sampling results greater than 1 ppb