



# SCHOOL WITHOUT WALLS LEAD WATER TEST RESULTS



	Building Location: Building Name	RECORD ID	Date Analyzed	Floor	Device Type	Device Location	1st Draw - Sample ID	Final Result - 1st Draw (ug/L)	2nd Draw - Sample ID	Final Result - 2nd Draw (ug/L)
1	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012081	8/12/2016	3	Cooler	In hallway adjacent to elevator High Left	FT-82016-012081-A	< 1	FT-82016-012081-B	< 1
2	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012082	8/12/2016	3	Cooler	In hallway adjacent to elevator Low Right	FT-82016-012082-A	< 1	FT-82016-012082-B	< 1
3	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012086	8/12/2016	2	Cooler	In hallway adjacent to elevator High Left	FT-82016-012086-A	< 1	FT-82016-012086-B	< 1
4	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012087	8/12/2016	2	Cooler	In hallway adjacent to elevator Low Right	FT-82016-012087-A	< 1	FT-82016-012087-B	< 1
5	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012088	8/12/2016	1	Cooler	In hallway adjacent to elevator High Left	FT-82016-012088-A	< 1	FT-82016-012088-B	< 1
6	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012089	8/12/2016	1	Cooler	In hallway adjacent to elevator Low Right	FT-82016-012089-A	< 1	FT-82016-012089-B	< 1
7	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012090	8/12/2016	1	Food Prep Sink	In kitchen	FT-82016-012090-A	< 1	FT-82016-012090-B	< 1
8	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012091	8/12/2016	1	Health Suite	In health suite	FT-82016-012091-A	< 1	FT-82016-012091-B	< 1
9	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012136	8/12/2016	Basement	Cooler	In hallway adjacent to elevator High Left	FT-82016-012136-A	< 1	FT-82016-012136-B	< 1
10	SCHOOL WITHOUT WALLS HIGH SCHOOL	WS- 012137	8/12/2016	Basement	Cooler	In hallway adjacent to elevator Low Right	FT-82016-012137-A	< 1	FT-82016-012137-B	< 1