



# School without Walls Lead Water Test Results



## FY18 Filter Test

Less than 5 ppb - Devices Requiring No Remediation													
RECORD ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			WATER FILTERS Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012084	6/30/17	6/30/18	3	Break Room	In break room			WF-62017-012084	12/18/17	FT-FY18--62017-012084-A	<1	FT-FY18--62017-012084-B	<1
WS- 012086	6/30/17	6/30/18	2	Cooler	In hallway adjacent to elevator	Left	High	WF-62017-012086	12/18/17	FT-FY18--62017-012086-A	<1	FT-FY18--62017-012086-B	<1
WS- 012089	6/30/17	6/30/18	1	Cooler	In hallway adjacent to elevator	Right	Low	WF-62017-012089	12/18/17	FT-FY18--62017-012089-A	<1	FT-FY18--62017-012089-B	<1
WS- 012136	6/30/17	6/30/18	Basement	Cooler	In hallway adjacent to elevator	Left	High	WF-62017-012136	12/18/17	FT-FY18--62017-012136-A	<1	FT-FY18--62017-012136-B	<1

## Food Prep Sink

Less than 5 ppb - Devices Requiring No Remediation										
RECORD ID	Floor	Device Type	Device Location			Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012090	1	Food Prep Sink	In kitchen			12/18/17	FT-FY18-102017-012090-A	<1	FT-FY18-102017-012090-B	<1