



# School within School Trailers Lead in Water Test Results

## FY22 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015050	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 108A	WF-04212021-015050	1/9/2022	FT-FY22-12012021-015050-A	<1	FT-FY22-12012021-015050-B	<1
WS-015051	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 108A High Left	WF-04212021-015051	1/9/2022	FT-FY22-12012021-015051-A	<1	FT-FY22-12012021-015051-B	<1
WS-015052	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 108A Low Right	WF-04212021-015052	1/9/2022	FT-FY22-12012021-015052-A	<1	FT-FY22-12012021-015052-B	<1
WS-015053	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 111B	WF-04212021-015053	1/9/2022	FT-FY22-12012021-015053-A	<1	FT-FY22-12012021-015053-B	<1
WS-015054	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 111B High Left	WF-04212021-015054	1/9/2022	FT-FY22-12012021-015054-A	<1	FT-FY22-12012021-015054-B	<1
WS-015055	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 111B Low Right	WF-04212021-015055	1/9/2022	FT-FY22-12012021-015055-A	<1	FT-FY22-12012021-015055-B	<1
WS-015056	4/21/2021	4/21/2022	Ground Floor	Health Suite	In health suite 103C	WF-04212021-015056	1/9/2022	FT-FY22-12012021-015056-A	<1	FT-FY22-12012021-015056-B	<1
WS-015058	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 208	WF-04212021-015058	1/9/2022	FT-FY22-12012021-015058-A	<1	FT-FY22-12012021-015058-B	<1
WS-015059	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 208 High Left	WF-04212021-015059	1/9/2022	FT-FY22-12012021-015059-A	<1	FT-FY22-12012021-015059-B	<1
WS-015060	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 208 Low Right	WF-04212021-015060	1/9/2022	FT-FY22-12012021-015060-A	<1	FT-FY22-12012021-015060-B	<1
WS-015061	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 211B	WF-04212021-015061	1/9/2022	FT-FY22-12012021-015061-A	<1	FT-FY22-12012021-015061-B	<1
WS-015062	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 211B High Left	WF-04212021-015062	1/9/2022	FT-FY22-12012021-015062-A	<1	FT-FY22-12012021-015062-B	<1
WS-015063	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 211B Low Right	WF-04212021-015063	1/9/2022	FT-FY22-12012021-015063-A	<1	FT-FY22-12012021-015063-B	<1
WS-015064	4/21/2021	4/21/2022	Ground Floor	Health Suite	In MES health suite 204A restroom	WF-04212021-015064	1/9/2022	FT-FY22-12012021-015064-A	<1	FT-FY22-12012021-015064-B	<1
WS-015065	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 310	WF-10132021-015065	1/9/2022	FT-FY22-12012021-015065-A	<1	FT-FY22-12012021-015065-B	<1
WS-015066	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 301	WF-10132021-015066	1/9/2022	FT-FY22-12012021-015066-A	<1	FT-FY22-12012021-015066-B	<1
WS-015067	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 309	WF-10132021-015067	1/9/2022	FT-FY22-12012021-015067-A	<1	FT-FY22-12012021-015067-B	<1
WS-015068	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 302	WF-10132021-015068	1/9/2022	FT-FY22-12012021-015068-A	<1	FT-FY22-12012021-015068-B	<1
WS-015069	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 308	WF-10132021-015069	1/9/2022	FT-FY22-12012021-015069-A	<1	FT-FY22-12012021-015069-B	<1
WS-015070	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 302	WF-04212021-015070	1/9/2022	FT-FY22-12012021-015070-A	<1	FT-FY22-12012021-015070-B	<1
WS-015071	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 302 High Left	WF-04212021-015071	1/9/2022	FT-FY22-12012021-015071-A	<1	FT-FY22-12012021-015071-B	<1
WS-015072	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 302 Low Right	WF-04212021-015072	1/9/2022	FT-FY22-12012021-015072-A	<1	FT-FY22-12012021-015072-B	<1
WS-015073	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 303	WF-04212021-015073	1/9/2022	FT-FY22-12012021-015073-A	<1	FT-FY22-12012021-015073-B	<1
WS-015074	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 303 High Left	WF-04212021-015074	1/9/2022	FT-FY22-12012021-015074-A	<1	FT-FY22-12012021-015074-B	<1
WS-015075	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 303 Low Right	WF-04212021-015075	1/9/2022	FT-FY22-12012021-015075-A	<1	FT-FY22-12012021-015075-B	<1
WS-015076	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 303	WF-10132021-015076	1/9/2022	FT-FY22-12012021-015076-A	<1	FT-FY22-12012021-015076-B	<1
WS-015077	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 307	WF-10132021-015077	1/9/2022	FT-FY22-12012021-015077-A	<1	FT-FY22-12012021-015077-B	<1
WS-015078	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 304	WF-10132021-015078	1/9/2022	FT-FY22-12012021-015078-A	<1	FT-FY22-12012021-015078-B	<1
WS-015079	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 306	WF-10132021-015079	1/9/2022	FT-FY22-12012021-015079-A	<1	FT-FY22-12012021-015079-B	<1
WS-015080	10/13/2021	10/13/2022	Ground Floor	Bathroom	In bathroom of room 305	WF-10132021-015080	1/9/2022	FT-FY22-12012021-015080-A	<1	FT-FY22-12012021-015080-B	<1
WS-015082	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 408	WF-04212021-015082	1/9/2022	FT-FY22-12012021-015082-A	<1	FT-FY22-12012021-015082-B	<1
WS-015083	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 408 High Left	WF-04212021-015083	1/9/2022	FT-FY22-12012021-015083-A	<1	FT-FY22-12012021-015083-B	<1
WS-015084	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 408 Low Right	WF-04212021-015084	1/9/2022	FT-FY22-12012021-015084-A	<1	FT-FY22-12012021-015084-B	<1
WS-015085	4/21/2021	4/21/2022	Ground Floor	Bottle Filler	In hallway adjacent to 411B	WF-04212021-015085	1/9/2022	FT-FY22-12012021-015085-A	<1	FT-FY22-12012021-015085-B	<1
WS-015086	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 411B High Left	WF-04212021-015086	1/9/2022	FT-FY22-12012021-015086-A	<1	FT-FY22-12012021-015086-B	<1

WS-015087	4/21/2021	4/21/2022	Ground Floor	Cooler	In hallway adjacent to 411B	Low Right	WF-04212021-015087	1/9/2022	FT-FY22-12012021-015087-A	<1	FT-FY22-12012021-015087-B	<1
-----------	-----------	-----------	--------------	--------	-----------------------------	-----------	--------------------	----------	---------------------------	----	---------------------------	----

### Food Prep Sink

Less than 5ppb - Devices requiring no remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015088	10/13/2021	10/13/2022	Ground Floor	Food Prep Sink	In room 403 food prints	WF-10132021-015088	1/9/2022	FT-FY22-12012021-015088-A	<1	FT-FY22-12012021-015088-B	<1
WS-015092	4/21/2021	4/21/2022	Ground Floor	Food Prep Sink	In kitchen trailer 2nd clockwise from entry	WF-04212021-015092	1/9/2022	FT-FY22-12012021-015092-A	<1	FT-FY22-12012021-015092-B	<1