



School within a School @ Goding Lead in Water Test Results

FY25 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015805	5/14/2024	5/14/2025	Basement	Combo Fountain	In classroom 005	WF-05142024-015805	1/1/2025	FT-FY25-12042024-015805-A	<2	FT-FY25-12042024-015805-B	<2	
WS-015807	5/14/2024	5/14/2025	Basement	Combo Fountain	In classroom 007	WF-05142024-015807	1/1/2025	FT-FY25-12042024-015807-A	<2	FT-FY25-12042024-015807-B	<2	
WS-015808	5/14/2024	5/14/2025	Basement	Bottle Filler	In discovery commons activity area	WF-05142024-015808	1/1/2025	FT-FY25-12042024-015808-A	<2	FT-FY25-12042024-015808-B	<2	
WS-015809	5/14/2024	5/14/2025	Basement	Cooler	In discovery commons activity area	High Left	WF-05142024-015809	1/1/2025	FT-FY25-12042024-015809-A	<2	FT-FY25-12042024-015809-B	<2
WS-015810	5/14/2024	5/14/2025	Basement	Cooler	In discovery commons activity area	Low Right	WF-05142024-015810	1/1/2025	FT-FY25-12042024-015810-A	<2	FT-FY25-12042024-015810-B	<2
WS-015812	5/14/2024	5/14/2025	Basement	Combo Fountain	In classroom 009	WF-05142024-015812	1/1/2025	FT-FY25-12042024-015812-A	<2	FT-FY25-12042024-015812-B	<2	
WS-015814	5/14/2024	5/14/2025	Basement	Combo Fountain	In classroom 011	WF-05142024-015814	1/1/2025	FT-FY25-12042024-015814-A	<2	FT-FY25-12042024-015814-B	<2	
WS-015815	5/14/2024	5/14/2025	1	Bottle Filler	In gym	WF-05142024-015815	1/1/2025	FT-FY25-12042024-015815-A	<2	FT-FY25-12042024-015815-B	<2	
WS-015816	5/14/2024	5/14/2025	1	Cooler	In gym	WF-05142024-015816	1/1/2025	FT-FY25-12042024-015816-A	<2	FT-FY25-12042024-015816-B	<2	
WS-015817	5/14/2024	5/14/2025	1	Bottle Filler	In hallway between restrooms	WF-05142024-015817	1/1/2025	FT-FY25-12042024-015817-A	<2	FT-FY25-12042024-015817-B	<2	
WS-015818	5/14/2024	5/14/2025	1	Cooler	In hallway between restrooms	High Left	WF-05142024-015818	1/1/2025	FT-FY25-12042024-015818-A	<2	FT-FY25-12042024-015818-B	<2
WS-015819	5/14/2024	5/14/2025	1	Cooler	In hallway between restrooms	Low Right	WF-05142024-015819	1/1/2025	FT-FY25-12042024-015819-A	<2	FT-FY25-12042024-015819-B	<2
WS-015821	5/14/2024	5/14/2025	1	Combo Fountain	In classroom 105 test kitchen	High Left	WF-05142024-015821	1/1/2025	FT-FY25-12042024-015821-A	<2	FT-FY25-12042024-015821-B	<2
WS-015823	5/14/2024	5/14/2025	1	Combo Fountain	In classroom 105 test kitchen	Low Right	WF-05142024-015823	1/1/2025	FT-FY25-12042024-015823-A	<2	FT-FY25-12042024-015823-B	<2
WS-015824	5/14/2024	5/14/2025	1	Health Suite	In treatment room 107-B	WF-05142024-015824	1/1/2025	FT-FY25-12042024-015824-A	<2	FT-FY25-12042024-015824-B	<2	
WS-015826	5/14/2024	5/14/2025	1	Cooler	In hallway adjacent to room 107	High Left	WF-05142024-015826	1/1/2025	FT-FY25-12042024-015826-A	<2	FT-FY25-12042024-015826-B	<2
WS-015827	5/14/2024	5/14/2025	1	Cooler	In hallway adjacent to room 107	Low Right	WF-05142024-015827	1/1/2025	FT-FY25-12042024-015827-A	<2	FT-FY25-12042024-015827-B	<2
WS-015828	5/14/2024	5/14/2025	1	Break Room	In admin workroom 116	WF-05142024-015828	1/1/2025	FT-FY25-12042024-015828-A	<2	FT-FY25-12042024-015828-B	<2	
WS-015830	5/14/2024	5/14/2025	1	Health Suite	In health suite 124	WF-05142024-015830	1/1/2025	FT-FY25-12042024-015830-A	<2	FT-FY25-12042024-015830-B	<2	
WS-015832	5/14/2024	5/14/2025	1	Combo Fountain	In classroom 111	WF-05142024-015832	1/1/2025	FT-FY25-12042024-015832-A	<2	FT-FY25-12042024-015832-B	<2	
WS-015834	5/14/2024	5/14/2025	1	Combo Fountain	In classroom 126	WF-05142024-015834	1/1/2025	FT-FY25-12042024-015834-A	<2	FT-FY25-12042024-015834-B	<2	
WS-015836	5/14/2024	5/14/2025	1	Combo Fountain	In classroom 113	WF-05142024-015836	1/1/2025	FT-FY25-12042024-015836-A	<2	FT-FY25-12042024-015836-B	<2	
WS-015837	5/14/2024	5/14/2025	2	Bottle Filler	In classroom 200	WF-05142024-015837	1/1/2025	FT-FY25-12042024-015837-A	<2	FT-FY25-12042024-015837-B	<2	
WS-015838	5/14/2024	5/14/2025	2	Cooler	In classroom 200	High Left	WF-05142024-015838	1/1/2025	FT-FY25-12042024-015838-A	<2	FT-FY25-12042024-015838-B	<2
WS-015840	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 200	WF-05142024-015840	1/1/2025	FT-FY25-12042024-015840-A	<2	FT-FY25-12042024-015840-B	<2	
WS-015841	5/14/2024	5/14/2025	2	Break Room	In teacher collaboration room 201	WF-05142024-015841	1/1/2025	FT-FY25-12042024-015841-A	<2	FT-FY25-12042024-015841-B	<2	
WS-015843	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 210	WF-05142024-015843	1/1/2025	FT-FY25-12042024-015843-A	<2	FT-FY25-12042024-015843-B	<2	
WS-015845	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 207	WF-05142024-015845	1/1/2025	FT-FY25-12042024-015845-A	<2	FT-FY25-12042024-015845-B	<2	
WS-015846	5/14/2024	5/14/2025	2	Bottle Filler	In hallway adjacent to room 209	WF-05142024-015846	1/1/2025	FT-FY25-12042024-015846-A	<2	FT-FY25-12042024-015846-B	<2	
WS-015847	5/14/2024	5/14/2025	2	Cooler	In hallway adjacent to room 209	High Left	WF-05142024-015847	1/1/2025	FT-FY25-12042024-015847-A	<2	FT-FY25-12042024-015847-B	<2
WS-015848	5/14/2024	5/14/2025	2	Cooler	In hallway adjacent to room 209	Low Right	WF-05142024-015848	1/1/2025	FT-FY25-12042024-015848-A	<2	FT-FY25-12042024-015848-B	<2
WS-015850	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 209	WF-05142024-015850	1/1/2025	FT-FY25-12042024-015850-A	<2	FT-FY25-12042024-015850-B	<2	
WS-015852	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 213	WF-05142024-015852	1/1/2025	FT-FY25-12042024-015852-A	<2	FT-FY25-12042024-015852-B	<2	

WS-015854	5/14/2024	5/14/2025	2	Combo Fountain	In art room 216	High Left	WF-05142024-015854	1/1/2025	FT-FY25-12042024-015854-A	<2	FT-FY25-12042024-015854-B	<2
WS-015856	5/14/2024	5/14/2025	2	Combo Fountain	In art room 216	Low Right	WF-05142024-015856	1/1/2025	FT-FY25-12042024-015856-A	<2	FT-FY25-12042024-015856-B	<2
WS-015858	5/14/2024	5/14/2025	2	Combo Fountain	In classroom 215		WF-05142024-015858	1/1/2025	FT-FY25-12042024-015858-A	<2	FT-FY25-12042024-015858-B	<2
WS-015860	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 301	Low Left	WF-05142024-015860	1/1/2025	FT-FY25-12042024-015860-A	<2	FT-FY25-12042024-015860-B	<2
WS-015862	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 301	High Right	WF-05142024-015862	1/1/2025	FT-FY25-12042024-015862-A	<2	FT-FY25-12042024-015862-B	<2
WS-015865	5/14/2024	5/14/2025	3	Bottle Filler	In hallway across from room 308		WF-05142024-015865	1/1/2025	FT-FY25-12042024-015865-A	<2	FT-FY25-12042024-015865-B	<2
WS-015866	5/14/2024	5/14/2025	3	Cooler	In hallway across from room 308	High Left	WF-05142024-015866	1/1/2025	FT-FY25-12042024-015866-A	<2	FT-FY25-12042024-015866-B	<2
WS-015867	5/14/2024	5/14/2025	3	Cooler	In hallway across from room 308	Low Right	WF-05142024-015867	1/1/2025	FT-FY25-12042024-015867-A	<2	FT-FY25-12042024-015867-B	<2
WS-015869	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 308		WF-05142024-015869	1/1/2025	FT-FY25-12042024-015869-A	<2	FT-FY25-12042024-015869-B	<2
WS-015871	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 310		WF-05142024-015871	1/1/2025	FT-FY25-12042024-015871-A	<2	FT-FY25-12042024-015871-B	<2
WS-015874	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 311		WF-05142024-015874	1/1/2025	FT-FY25-12042024-015874-A	<2	FT-FY25-12042024-015874-B	<2
WS-015875	5/14/2024	5/14/2025	3	Break Room	In teacher collaboration room 316		WF-05142024-015875	1/1/2025	FT-FY25-12042024-015875-A	<2	FT-FY25-12042024-015875-B	<2
WS-015877	5/14/2024	5/14/2025	3	Combo Fountain	In classroom 313		WF-05142024-015877	1/1/2025	FT-FY25-12042024-015877-A	<2	FT-FY25-12042024-015877-B	<2
WS-015878	5/14/2024	5/14/2025	4	Break Room	In lactation room 401		WF-05142024-015878	1/1/2025	FT-FY25-12042024-015878-A	<2	FT-FY25-12042024-015878-B	<2
WS-015879	5/14/2024	5/14/2025	4	Break Room	In staff lounge 411		WF-05142024-015879	1/1/2025	FT-FY25-12042024-015879-A	<2	FT-FY25-12042024-015879-B	<2
WS-015880	5/14/2024	5/14/2025	4	Break Room	In teacher collaboration room 403		WF-05142024-015880	1/1/2025	FT-FY25-12042024-015880-A	<2	FT-FY25-12042024-015880-B	<2
WS-015882	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 402		WF-05142024-015882	1/1/2025	FT-FY25-12042024-015882-A	<2	FT-FY25-12042024-015882-B	<2
WS-015884	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 406		WF-05142024-015884	1/1/2025	FT-FY25-12042024-015884-A	<2	FT-FY25-12042024-015884-B	<2
WS-015885	5/14/2024	5/14/2025	4	Bottle Filler	In hallway adjacent to discovery commons activity area		WF-05142024-015885	1/1/2025	FT-FY25-12042024-015885-A	<2	FT-FY25-12042024-015885-B	<2
WS-015886	5/14/2024	5/14/2025	4	Cooler	In hallway adjacent to discovery commons activity area	High Left	WF-05142024-015886	1/1/2025	FT-FY25-12042024-015886-A	<2	FT-FY25-12042024-015886-B	<2
WS-015887	5/14/2024	5/14/2025	4	Cooler	In hallway adjacent to discovery commons activity area	Low Right	WF-05142024-015887	1/1/2025	FT-FY25-12042024-015887-A	<2	FT-FY25-12042024-015887-B	<2
WS-015889	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 408		WF-05142024-015889	1/1/2025	FT-FY25-12042024-015889-A	<2	FT-FY25-12042024-015889-B	<2
WS-015891	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 410		WF-05142024-015891	1/1/2025	FT-FY25-12042024-015891-A	<2	FT-FY25-12042024-015891-B	<2
WS-015893	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 405		WF-05142024-015893	1/1/2025	FT-FY25-12042024-015893-A	<2	FT-FY25-12042024-015893-B	<2
WS-015895	5/14/2024	5/14/2025	4	Combo Fountain	In classroom 413		WF-05142024-015895	1/1/2025	FT-FY25-12042024-015895-A	<2	FT-FY25-12042024-015895-B	<2
WS-015897	5/14/2024	5/14/2025	3	Bottle Filler	In reading/learning library room 305		WF-05142024-015897	1/1/2025	FT-FY25-12042024-015897-A	<2	FT-FY25-12042024-015897-B	<2
WS-015898	5/14/2024	5/14/2025	3	Cooler	In reading/learning library room 305	High Left	WF-05142024-015898	1/1/2025	FT-FY25-12042024-015898-A	<2	FT-FY25-12042024-015898-B	<2
WS-015899	5/14/2024	5/14/2025	3	Cooler	In reading/learning library room 305	Low Right	WF-05142024-015899	1/1/2025	FT-FY25-12042024-015899-A	<2	FT-FY25-12042024-015899-B	<2
WS-015901	5/14/2024	5/14/2025	3	Combo Fountain	In room 305-C		WF-05142024-015901	1/1/2025	FT-FY25-12042024-015901-A	<2	FT-FY25-12042024-015901-B	<2

Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015803	1/2/2024	1/2/2025	Basement	Food Prep Sink	In kitchen on island	WF-01022024-015803	1/1/2025	FT-FY25-12042024-015803-A	<2	FT-FY25-12042024-015803-B	<2	

Due to changes in water sampling analysis equipment at the laboratory from previous years, the level of detection (LOD) for lead in drinking water is now <2ppb.