



School within a School at Goding Lead in Water Test Results

FY23 Filter Test

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS-015800	8/17/2022	8/17/2023	Basement	Bottle Filler	In cafeteria	WF-08172022-015800	8/30/2022	FT-FY23-08192022-015800-A	<1	FT-FY23-08192022-015800-B	<1
WS-015801	8/17/2022	8/17/2023	Basement	Cooler	In cafeteria High Left	WF-08172022-015801	8/30/2022	FT-FY23-08192022-015801-A	1.4	FT-FY23-08192022-015801-B	<1
WS-015802	8/17/2022	8/17/2023	Basement	Cooler	In cafeteria Low Right	WF-08172022-015802	8/30/2022	FT-FY23-08192022-015802-A	<1	FT-FY23-08192022-015802-B	<1
WS-015805	8/17/2022	8/17/2023	Basement	Combo Fountain	In classroom 005	WF-08172022-015805	8/30/2022	FT-FY23-08192022-015805-A	<1	FT-FY23-08192022-015805-B	<1
WS-015807	8/17/2022	8/17/2023	Basement	Combo Fountain	In classroom 007	WF-08172022-015807	8/30/2022	FT-FY23-08192022-015807-A	<1	FT-FY23-08192022-015807-B	<1
WS-015808	8/17/2022	8/17/2023	Basement	Bottle Filler	In discovery commons activity area	WF-08172022-015808	8/30/2022	FT-FY23-08192022-015808-A	<1	FT-FY23-08192022-015808-B	<1
WS-015809	8/17/2022	8/17/2023	Basement	Cooler	In discovery commons activity area High Left	WF-08172022-015809	8/30/2022	FT-FY23-08192022-015809-A	<1	FT-FY23-08192022-015809-B	<1
WS-015810	8/17/2022	8/17/2023	Basement	Cooler	In discovery commons activity area Low Right	WF-08172022-015810	8/30/2022	FT-FY23-08192022-015810-A	<1	FT-FY23-08192022-015810-B	<1
WS-015812	8/17/2022	8/17/2023	Basement	Combo Fountain	In classroom 009	WF-08172022-015812	8/30/2022	FT-FY23-08192022-015812-A	<1	FT-FY23-08192022-015812-B	<1
WS-015815	8/17/2022	8/17/2023	1	Bottle Filler	In gym	WF-08172022-015815	8/30/2022	FT-FY23-08192022-015815-A	<1	FT-FY23-08192022-015815-B	<1
WS-015816	8/17/2022	8/17/2023	1	Cooler	In gym	WF-08172022-015816	8/30/2022	FT-FY23-08192022-015816-A	<1	FT-FY23-08192022-015816-B	<1
WS-015817	8/17/2022	8/17/2023	1	Bottle Filler	In hallway between restrooms	WF-08172022-015817	8/30/2022	FT-FY23-08192022-015817-A	<1	FT-FY23-08192022-015817-B	<1
WS-015818	8/17/2022	8/17/2023	1	Cooler	In hallway between restrooms High Left	WF-08172022-015818	8/30/2022	FT-FY23-08192022-015818-A	<1	FT-FY23-08192022-015818-B	<1
WS-015819	8/17/2022	8/17/2023	1	Cooler	In hallway between restrooms Low Right	WF-08172022-015819	8/30/2022	FT-FY23-08192022-015819-A	<1	FT-FY23-08192022-015819-B	<1
WS-015821	8/17/2022	8/17/2023	1	Combo Fountain	In classroom 105 test kitchen High Left	WF-08172022-015821	8/30/2022	FT-FY23-08192022-015821-A	1.2	FT-FY23-08192022-015821-B	<1
WS-015823	8/17/2022	8/17/2023	1	Combo Fountain	In classroom 105 test kitchen Low Right	WF-08172022-015823	8/30/2022	FT-FY23-08192022-015823-A	<1	FT-FY23-08192022-015823-B	<1
WS-015824	8/17/2022	8/17/2023	1	Health Suite	In treatment room 107-B	WF-08172022-015824	8/30/2022	FT-FY23-08192022-015824-A	<1	FT-FY23-08192022-015824-B	<1
WS-015825	8/17/2022	8/17/2023	1	Bottle Filler	In hallway adjacent to room 107	WF-08172022-015825	8/30/2022	FT-FY23-08192022-015825-A	<1	FT-FY23-08192022-015825-B	<1
WS-015826	8/17/2022	8/17/2023	1	Cooler	In hallway adjacent to room 107 High Left	WF-08172022-015826	8/30/2022	FT-FY23-08192022-015826-A	<1	FT-FY23-08192022-015826-B	<1
WS-015827	8/17/2022	8/17/2023	1	Cooler	In hallway adjacent to room 107 Low Right	WF-08172022-015827	8/30/2022	FT-FY23-08192022-015827-A	<1	FT-FY23-08192022-015827-B	<1
WS-015828	8/17/2022	8/17/2023	1	Break Room	In admin workroom 116	WF-08172022-015828	8/30/2022	FT-FY23-08192022-015828-A	1.5	FT-FY23-08192022-015828-B	<1
WS-015830	8/17/2022	8/17/2023	1	Health Suite	In health suite 124	WF-08172022-015830	8/30/2022	FT-FY23-08192022-015830-A	<1	FT-FY23-08192022-015830-B	<1
WS-015832	8/17/2022	8/17/2023	1	Combo Fountain	In classroom 111	WF-08172022-015832	8/30/2022	FT-FY23-08192022-015832-A	<1	FT-FY23-08192022-015832-B	<1
WS-015834	8/17/2022	8/17/2023	1	Combo Fountain	In classroom 126	WF-08172022-015834	8/30/2022	FT-FY23-08192022-015834-A	<1	FT-FY23-08192022-015834-B	<1
WS-015836	8/17/2022	8/17/2023	1	Combo Fountain	In classroom 113	WF-08172022-015836	8/30/2022	FT-FY23-08192022-015836-A	<1	FT-FY23-08192022-015836-B	<1
WS-015837	8/17/2022	8/17/2023	2	Bottle Filler	In classroom 200	WF-08172022-015837	8/30/2022	FT-FY23-08192022-015837-A	<1	FT-FY23-08192022-015837-B	<1
WS-015838	8/17/2022	8/17/2023	2	Cooler	In classroom 200 High Left	WF-08172022-015838	8/30/2022	FT-FY23-08192022-015838-A	<1	FT-FY23-08192022-015838-B	<1
WS-015840	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 200	WF-08172022-015840	8/30/2022	FT-FY23-08192022-015840-A	<1	FT-FY23-08192022-015840-B	<1
WS-015841	8/17/2022	8/17/2023	2	Break Room	In teacher collaboration room 201	WF-08172022-015841	8/30/2022	FT-FY23-08192022-015841-A	1.2	FT-FY23-08192022-015841-B	<1
WS-015843	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 210	WF-08172022-015843	8/30/2022	FT-FY23-08192022-015843-A	<1	FT-FY23-08192022-015843-B	<1
WS-015845	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 207	WF-08172022-015845	8/30/2022	FT-FY23-08192022-015845-A	<1	FT-FY23-08192022-015845-B	<1
WS-015846	8/17/2022	8/17/2023	2	Bottle Filler	In hallway adjacent to room 209	WF-08172022-015846	8/30/2022	FT-FY23-08192022-015846-A	<1	FT-FY23-08192022-015846-B	<1
WS-015847	8/17/2022	8/17/2023	2	Cooler	In hallway adjacent to room 209 High Left	WF-08172022-015847	8/30/2022	FT-FY23-08192022-015847-A	<1	FT-FY23-08192022-015847-B	<1
WS-015848	8/17/2022	8/17/2023	2	Cooler	In hallway adjacent to room 209 Low Right	WF-08172022-015848	8/30/2022	FT-FY23-08192022-015848-A	<1	FT-FY23-08192022-015848-B	<1
WS-015850	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 209	WF-08172022-015850	8/30/2022	FT-FY23-08192022-015850-A	<1	FT-FY23-08192022-015850-B	<1

WS-015852	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 213		WF-08172022-015852	8/30/2022	FT-FY23-08192022-015852-A	<1	FT-FY23-08192022-015852-B	<1
WS-015854	8/17/2022	8/17/2023	2	Combo Fountain	In art room 216	High Left	WF-08172022-015854	8/30/2022	FT-FY23-08192022-015854-A	<1	FT-FY23-08192022-015854-B	<1
WS-015856	8/17/2022	8/17/2023	2	Combo Fountain	In art room 216	Low Right	WF-08172022-015856	8/30/2022	FT-FY23-08192022-015856-A	<1	FT-FY23-08192022-015856-B	<1
WS-015858	8/17/2022	8/17/2023	2	Combo Fountain	In classroom 215		WF-08172022-015858	8/30/2022	FT-FY23-08192022-015858-A	<1	FT-FY23-08192022-015858-B	<1
WS-015860	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 301	Low Left	WF-08172022-015860	8/30/2022	FT-FY23-08192022-015860-A	<1	FT-FY23-08192022-015860-B	<1
WS-015862	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 301	High Right	WF-08172022-015862	8/30/2022	FT-FY23-08192022-015862-A	<1	FT-FY23-08192022-015862-B	<1
WS-015865	8/17/2022	8/17/2023	3	Bottle Filler	In hallway across from room 308		WF-08172022-015865	8/30/2022	FT-FY23-08192022-015865-A	<1	FT-FY23-08192022-015865-B	<1
WS-015866	8/17/2022	8/17/2023	3	Cooler	In hallway across from room 308	High Left	WF-08172022-015866	8/30/2022	FT-FY23-08192022-015866-A	<1	FT-FY23-08192022-015866-B	<1
WS-015867	8/17/2022	8/17/2023	3	Cooler	In hallway across from room 308	Low Right	WF-08172022-015867	8/30/2022	FT-FY23-08192022-015867-A	<1	FT-FY23-08192022-015867-B	<1
WS-015869	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 308		WF-08172022-015869	8/30/2022	FT-FY23-08192022-015869-A	<1	FT-FY23-08192022-015869-B	<1
WS-015871	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 310		WF-08172022-015871	8/30/2022	FT-FY23-08192022-015871-A	<1	FT-FY23-08192022-015871-B	<1
WS-015874	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 311		WF-08172022-015874	8/30/2022	FT-FY23-08192022-015874-A	<1	FT-FY23-08192022-015874-B	<1
WS-015875	8/17/2022	8/17/2023	3	Break Room	In teacher collaboration room 316		WF-08172022-015875	8/30/2022	FT-FY23-08192022-015875-A	<1	FT-FY23-08192022-015875-B	<1
WS-015877	8/17/2022	8/17/2023	3	Combo Fountain	In classroom 313		WF-08172022-015877	8/30/2022	FT-FY23-08192022-015877-A	<1	FT-FY23-08192022-015877-B	<1
WS-015878	8/17/2022	8/17/2023	4	Break Room	In lactation room 401		WF-08172022-015878	8/30/2022	FT-FY23-08192022-015878-A	<1	FT-FY23-08192022-015878-B	<1
WS-015879	8/17/2022	8/17/2023	4	Break Room	In staff lounge 411		WF-08172022-015879	8/30/2022	FT-FY23-08192022-015879-A	<1	FT-FY23-08192022-015879-B	<1
WS-015880	8/17/2022	8/17/2023	4	Break Room	In teacher collaboration room 403		WF-08172022-015880	8/30/2022	FT-FY23-08192022-015880-A	<1	FT-FY23-08192022-015880-B	<1
WS-015882	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 402		WF-08172022-015882	8/30/2022	FT-FY23-08192022-015882-A	<1	FT-FY23-08192022-015882-B	<1
WS-015884	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 406		WF-08172022-015884	8/30/2022	FT-FY23-08192022-015884-A	<1	FT-FY23-08192022-015884-B	<1
WS-015885	8/17/2022	8/17/2023	4	Bottle Filler	In hallway adjacent to discovery commons activity area		WF-08172022-015885	8/30/2022	FT-FY23-08192022-015885-A	<1	FT-FY23-08192022-015885-B	<1
WS-015886	8/17/2022	8/17/2023	4	Cooler	In hallway adjacent to discovery commons activity area	High Left	WF-08172022-015886	8/30/2022	FT-FY23-08192022-015886-A	<1	FT-FY23-08192022-015886-B	<1
WS-015887	8/17/2022	8/17/2023	4	Cooler	In hallway adjacent to discovery commons activity area	Low Right	WF-08172022-015887	8/30/2022	FT-FY23-08192022-015887-A	<1	FT-FY23-08192022-015887-B	<1
WS-015889	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 408		WF-08172022-015889	8/30/2022	FT-FY23-08192022-015889-A	<1	FT-FY23-08192022-015889-B	<1
WS-015891	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 410		WF-08172022-015891	8/30/2022	FT-FY23-08192022-015891-A	<1	FT-FY23-08192022-015891-B	<1
WS-015893	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 405		WF-08172022-015893	8/30/2022	FT-FY23-08192022-015893-A	<1	FT-FY23-08192022-015893-B	<1
WS-015895	8/17/2022	8/17/2023	4	Combo Fountain	In classroom 413		WF-08172022-015895	8/30/2022	FT-FY23-08192022-015895-A	<1	FT-FY23-08192022-015895-B	<1
WS-015897	8/17/2022	8/17/2023	3	Bottle Filler	In reading/learning library room 305		WF-08172022-015897	8/30/2022	FT-FY23-08192022-015897-A	<1	FT-FY23-08192022-015897-B	<1
WS-015898	8/17/2022	8/17/2023	3	Cooler	In reading/learning library room 305	High Left	WF-08172022-015898	8/30/2022	FT-FY23-08192022-015898-A	<1	FT-FY23-08192022-015898-B	1.3
WS-015899	8/17/2022	8/17/2023	3	Cooler	In reading/learning library room 305	Low Right	WF-08172022-015899	8/30/2022	FT-FY23-08192022-015899-A	<1	FT-FY23-08192022-015899-B	<1
WS-015901	8/17/2022	8/17/2023	3	Combo Fountain	In room 305-C		WF-08172022-015901	8/30/2022	FT-FY23-08192022-015901-A	<1	FT-FY23-08192022-015901-B	<1

Food Prep Sink

Less than 5ppb - Devices requiring no remediation

Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)	
WS-015803	8/17/2022	8/17/2023	Basement	Food Prep Sink	In kitchen on island	WF-08172022-015803	8/30/2022	FT-FY23-08192022-015803-A	<1	FT-FY23-08192022-015803-B	<1	
WS-015820	8/17/2022	8/17/2023	1	Food Prep Sink	In classroom 105 test kitchen	High Left	WF-08172022-015820	8/30/2022	FT-FY23-08192022-015820-A	<1	FT-FY23-08192022-015820-B	<1
WS-015822	8/17/2022	8/17/2023	1	Food Prep Sink	In classroom 105 test kitchen	Low Right	WF-08172022-015822	8/30/2022	FT-FY23-08192022-015822-A	<1	FT-FY23-08192022-015822-B	<1